BID # CHA21-05 **ADDENDUM NUMBER 03**

REQUEST FOR PROPOSALS FOR:

Security Infrastructure Upgrades (Part A)

&

Alarm, Access Control & CCTV System Maintenance & Monitoring Services (Part B)

Statewide for the Community College System of New Hampshire

26 College Drive, Concord, NH 03301

August 9, 2021

TO: ALL CONTRACT BIDDERS OF RECORD

This Addendum forms a part of the Contract Documents and modifies the Request for Proposals dated June 28, 2021, with amendments and additions noted below. This Addendum consists of a total of One Hundred Thirty-Four (134) pages.

The new bid date is August 26, 2021, at 2 p.m.

BIDDER'S QUESTIONS

QUESTION #1: Video: This is assuming that all locations are utilizing Exacqvision video services. Can you please provide the MAC addresses for all Exacqvision Video Servers?
ANSWER #1: We will furnish MAC addresses to the successful bidder after a completed contract with CCSNH.

QUESTION #2: Access Control: Can you please provide your Software House Ccure9000 serial number(s). Also we would need to get control panel inventory for the facilities we did not visit.
ANSWER #2: See attached, per college, Safety Security RFP Info. We will furnish serial number(s) to the successful bidder after a completed contract with CCSNH.

QUESTION #3: Intrusion system: Can you please provide the intrusion system inventory for each facility to include: Make and model of the control panel, central station communication method (landline and/or cellular), number of keypads for each facility and zone list.
ANSWER #3: See attached, per college, Safety Security RFP Info. We don't have a zone list for you.

QUESTION #4: Provide the alarm panel/auto dialer info which the schools are working on.
ANSWER #4: See attached, per college, Safety Security RFP Info.

QUESTION #5: Furnish the Keypad/Alarm panel information.
ANSWER #5: See attached CCSNH RFP Keypad Info attached.

Substitute

Acknowledge receipt of this Addendum with the Proposal Form.
Failure to do so may disqualify the Bidder.

NOTE: IN THE EVENT THAT YOUR BID HAS BEEN SENT TO THIS OFFICE PRIOR TO RECEIVING THIS ADDENDUM, RETURN THE ADDENDUM WITHIN THE SPECIFIED TIME WITH ANY CHANGES YOU MAY

WISH TO MAKE AND MARK ON THE REMITTANCE ENVELOPE BID INVITATION NUMBER AND OPENING DATE. RETURNED ADDENDA WILL SUPERSEDE PREVIOUSLY SUBMITTED BID.

Bidder_____

By_____Date_____
(This Document Must Be Signed)

Name_____
(Please Print or Type Name)

Matthew Moore, P.E.
Director of Capitol Planning & Development
Community College System of New Hampshire
26 College Drive, Concord, N.H. 0330

Name	Description	Armed status	Active Status	Partition Name
GBCC-STUDENT CENTER REAR ENT-DSM		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-STUDENT CENTER REAR ENT-REX		Armed	Update Disabled	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-STUDENT CENTER GYM ENT-DSM		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-STUDENT CENTER GYM ENT-REX		Armed	Update Disabled	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-STUDENT CENTER HALLWALL EXIT--DSM		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-STUDENT CENTER HALLWALL ENT--DSM		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-STUDENT CENTER GREEN BEAN REAR ENT-DSM		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-STUDENT CENTER GREEN BEAN REAR ENT-REX		Armed	Update Disabled	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-STUDENT CENTER MAIN ENT-DSM		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-STUDENT CENTER MAIN ENT-REX		Armed	Update Disabled	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-STUDENT CENTER FITNESS CENTER ENT-DSM		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER

GBCC-STUDENT CENTER FITNESS CENTER ENT-REX		Armed	Update Disabled	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-DATA CENTER-DSM		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-LOADING DOCK-DSM		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-LOADING DOCK-REX		Armed	Update Disabled	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-NORTH ENTRANCE-DSM		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-NORTH ENTRANCE-REX		Armed	Update Disabled	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-MAIN ENT-DSM		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-MAIN ENT-REX		Armed	Update Disabled	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-BUSINESS ENT-DSM		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-BUSINESS ENT-REX		Armed	Update Disabled	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-VET TECH ENT-DSM		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-VET TECH ENT-REX		Armed	Update Disabled	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-STUDENT CENTER GYM RIGHT-DSM		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-STUDENT CENTER GYM RIGHT-REX		Armed	Update Disabled	4000-GBCC PORTSMOUTH/ROCHESTER

GBCC-STUDENT CENTER ROOM 95-DSM		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-STUDENT CENTER ROOM 95-REX		Armed	Update Disabled	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-STUDENT CENTER ROOM 96-DSM		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-STUDENT CENTER ROOM 96-REX		Armed	Update Disabled	4000-GBCC PORTSMOUTH/ROCHESTER
iSTAR Input7-4000-GBCC ROCHESTER Administration Lock Down		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
iSTAR Input8-4000-GBCC ROCHESTER Front Desk Lock down		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
Power Failure-GBCC-DATA CENTER ISTAR		Armed	Active	4000-GBCC PORTSMOUTH/ROCHESTER
External Battery Low-GBCC-DATA CENTER ISTAR		Armed	Active	4000-GBCC PORTSMOUTH/ROCHESTER
Power Failure-GBCC-STUDENT CENTER ISTAR		Armed	Active	4000-GBCC PORTSMOUTH/ROCHESTER
External Battery Low-GBCC-STUDENT CENTER ISTAR		Armed	Active	4000-GBCC PORTSMOUTH/ROCHESTER

Power Failure-4000-GBCC ROCHESTER DATA CLOSET ISTAR EDGE		Armed	Active	4000-GBCC PORTSMOUTH/ROCHESTER
External Battery Low-4000-GBCC ROCHESTER DATA CLOSET ISTAR EDGE		Armed	Active	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-STUDENT LIFE ASSISTANT OFFICE 85 LOCKDOWN-BTN		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
Communication Fail-GBCC-DATA CENTER ISTAR-INPUT BOARD 1		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-SECURITY DESK LOCKDOWN-BTN		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-ONE STOP OFFICE AREA LOCKDOWN-BTN		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-PRESIDENTS OFFICE AREA LOCKDOWN-BTN		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-BUSINESS AND TRAINING CENTER LOCKDOWN-BTN		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-HELP DESK/IT DEPT LOCKDOWN-BTN		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER

GBCC-ONE STOP-DSM		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-ONE STOP-REX		Armed	Update Disabled	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-CHEMESTRY LAB NE140-DSM		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-CHEMESTRY LAB NE140-REX		Armed	Update Disabled	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-LIFE SCIENCE NE141-DSM		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-LIFE SCIENCE NE141-REX		Armed	Update Disabled	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-LIFE SCIENCE NE142-DSM		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-LIFE SCIENCE NE142-REX		Armed	Update Disabled	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-LIFE SCIENCE NE143-DSM		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-LIFE SCIENCE NE143-REX		Armed	Update Disabled	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-BIO PREP NE149-DSM		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-BIO PREP NE149-REX		Armed	Update Disabled	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-BIO LAB NE149A-DSM		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-BIO LAB NE149A-REX		Armed	Update Disabled	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-BIO LAB 149C-DSM		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER

GBCC-BIO LAB 149C-REX		Armed	Update Disabled	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-LOADING DOCK 2-DSM		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-VET TECH NE154-DSM		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-BIOTECH EMERGENCY DOOR-CONT		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-1ST FL IDF NE151 ISTAR INPUT BOARD 1 COMM FAIL		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-NE148 MAINTENANCE-DSM		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-NE148 MAINTENANCE-REX		Armed	Update Disabled	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-LOADING DOCK 2-REX		Armed	Update Disabled	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-VET TECH NE154-REX		Armed	Update Disabled	4000-GBCC PORTSMOUTH/ROCHESTER
Power Failure-GBCC-1ST FL IDF NE151 ISTAR		Armed	Active	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-FITNESS CENTER OFFICE-DSM		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-FITNESS CENTER OFFICE-REX		Armed	Update Disabled	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-STUDENT CENTER DOOR OVER RIDE-BTN		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER

GBCC-DATA CENTER DOOR OVER RIDE-BTN		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-1ST FL IDF NE151 DOOR OVER RIDE-BTN		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
Power Failure-GBCC ROCHESTER DATA CLOSET ISTAR EDGE 2		Armed	Active	4000-GBCC PORTSMOUTH/ROCHESTER
External Battery Low-GBCC ROCHESTER DATA CLOSET ISTAR EDGE 2		Armed	Active	4000-GBCC PORTSMOUTH/ROCHESTER
4000-GBCC ROCHESTER WELDING LAB TO CNC LAB-DSM		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
4000-GBCC ROCHESTER WELDING LAB TO CNC LAB-REX		Armed	Update Disabled	4000-GBCC PORTSMOUTH/ROCHESTER
4000-GBCC ROCHESTER VESTIBULE 140 TO WELDING LAB-DSM		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
4000-GBCC ROCHESTER VESTIBULE 140 TO WELDING LAB-REX		Armed	Update Disabled	4000-GBCC PORTSMOUTH/ROCHESTER
4000-GBCC ROCHESTER VESTIBULE 140 TO CNC LAB-DSM		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER

4000-GBCC ROCHESTER VESTIBULE 140 TO CNC LAB-REX		Armed	Update Disabled	4000-GBCC PORTSMOUTH/ROCHESTER
iSTAR Input3-4000-GBCC ROCHESTER Main Entrance Intercom Release		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER

Name	Description	Armed status	Active Status	Partition Name
1001-iSTAR01/ACM1/I01/LRCC-TURNER-DOOR1-DMS		Armed	Inactive	1000-LRCC LACONIA
1002-iSTAR01/ACM1/I02/LRCC-TURNER-DOOR2-DSM		Armed	Inactive	1000-LRCC LACONIA
1003-iSTAR01/ACM1/I03/LRCC-TURNER-DOOR3-DSM		Armed	Inactive	1000-LRCC LACONIA
1004-iSTAR01/ACM1/I04/LRCC-TURNER-DOOR4-DSM		Armed	Inactive	1000-LRCC LACONIA
1005-iSTAR01/ACM1/I05/LRCC-TURNER-DOOR5-DSM		Armed	Inactive	1000-LRCC LACONIA
1001-iSTAR01/ACM1/I09/LRCC-TURNER-DOOR1-REX		Armed	Update Disabled	1000-LRCC LACONIA
1002-iSTAR01/ACM1/I10/LRCC-TURNER-DOOR2-REX		Armed	Update Disabled	1000-LRCC LACONIA
1003-iSTAR01/ACM1/I11/LRCC-TURNER-DOOR3-REX		Armed	Update Disabled	1000-LRCC LACONIA
1004-iSTAR01/ACM1/I12/LRCC-TURNER-DOOR4-REX		Armed	Update Disabled	1000-LRCC LACONIA
1005-iSTAR01/ACM1/I13/LRCC-TURNER-DOOR5-REX		Armed	Update Disabled	1000-LRCC LACONIA
1008-iSTAR01/ACM1/R08I1/LRCC-CAT-DOOR8-DSM		Armed	Inactive	1000-LRCC LACONIA
1008-iSTAR01/ACM1/R08I2/LRCC-CAT-DOOR8-REX		Armed	Update Disabled	1000-LRCC LACONIA
1007-iSTAR01/ACM1/R07I1/LRCC-CAT-DOOR7-DSM		Armed	Inactive	1000-LRCC LACONIA
1007-iSTAR01/ACM1/R07I2/LRCC-CAT-DOOR7-REX		Armed	Update Disabled	1000-LRCC LACONIA
1130-iSTAR01/1I01-LR CAT-G-IT CLOSET-DSM		Armed	Inactive	1000-LRCC LACONIA
1135-iSTAR01/1I02-LR CAT-G-CLASSROOM-DSM		Armed	Inactive	1000-LRCC LACONIA
1136-iSTAR01/1I03-LR CAT-G-NURSE FAC-DSM		Armed	Inactive	1000-LRCC LACONIA
1137-iSTAR01/1I04-LR CAT-G-NURSE FAC-DSM		Armed	Inactive	1000-LRCC LACONIA
1138-iSTAR01/1I05-LR CAT-G-NURSE FAC-DSM		Armed	Inactive	1000-LRCC LACONIA
1140-iSTAR01/1I06-LRCC-CAT-G-ANTE/COPY-DSM		Armed	Inactive	1000-LRCC LACONIA
1130-iSTAR01/1I09-LR CAT-G-IT CLOSET-REX		Armed	Update Disabled	1000-LRCC LACONIA
1135-iSTAR01/1I10-LR CAT-G-CLASSROOM-REX		Armed	Update Disabled	1000-LRCC LACONIA
1136-iSTAR01/1I11-LR CAT-G-NURSE FAC-REX		Armed	Update Disabled	1000-LRCC LACONIA
1138-iSTAR01/1I13-LR CAT-G-NURSE FAC-REX		Armed	Update Disabled	1000-LRCC LACONIA
1137-iSTAR01/1I12-LR CAT-G-NURSE FAC-REX		Armed	Update Disabled	1000-LRCC LACONIA
1140-iSTAR01/1I14-LRCC-CAT-G-ANTE/COPY-REX		Armed	Update Disabled	1000-LRCC LACONIA
1142-iSTAR01/2I01-LRCC-CAT-G-CLASSROOM-DSM		Armed	Inactive	1000-LRCC LACONIA
1147-iSTAR01/2I02-LRCC-CAT-G-SIDE ENT-DSM		Armed	Inactive	1000-LRCC LACONIA
1148-iSTAR01/2I03-LRCC-CAT-G-FACULTY-DSM		Armed	Inactive	1000-LRCC LACONIA
1149-iSTAR01/2I04-LRCC-CAT-G-FACULTY-DSM		Armed	Inactive	1000-LRCC LACONIA
1151-iSTAR01/2I05-LRCC-CAT-G-STORAGE-DSM		Armed	Inactive	1000-LRCC LACONIA

1152A-iSTAR01/2I06-LRCC-CAT-G-CLASSROOM-DSM		Armed	Inactive	1000-LRCC LACONIA
1152B-iSTAR01/2I07-LRCC-CAT-G-CLASSROOM EXT-DSM		Armed	Inactive	1000-LRCC LACONIA
1153A-iSTAR01/2I08-LRCC-CAT-G-CLASSROOM-DSM		Armed	Inactive	1000-LRCC LACONIA
1142-iSTAR01/2I09-LRCC-CAT-G-CLASSROOM-REX		Armed	Update Disabled	1000-LRCC LACONIA
1147-iSTAR01/2I10-LRCC-CAT-G-SIDE ENT-REX		Armed	Inactive	1000-LRCC LACONIA
1148-iSTAR01/2I11-LRCC-CAT-G-FACULTY-REX		Armed	Update Disabled	1000-LRCC LACONIA
1149-iSTAR01/2I12-LRCC-CAT-G-FACULTY-REX		Armed	Update Disabled	1000-LRCC LACONIA
1151-iSTAR01/2I13-LRCC-CAT-G-STORAGE-REX		Armed	Update Disabled	1000-LRCC LACONIA
1152A-iSTAR01/2I14-LRCC-CAT-G-CLASSROOM-REX		Armed	Update Disabled	1000-LRCC LACONIA
1152B-iSTAR01/2I15-LRCC-CAT-G-CLASSROOM EXT-REX		Armed	Update Disabled	1000-LRCC LACONIA
1153A-iSTAR01/2I16-LRCC-CAT-G-CLASSROOM-REX		Armed	Update Disabled	1000-LRCC LACONIA
1153B-iSTAR02/1I01-LRCC-CAT-G-BETWEEN CLASSROOMS-DSM		Armed	Inactive	1000-LRCC LACONIA
1154-iSTAR02/1I02-LRCC-CAT-G-STORAGE-DSM		Armed	Inactive	1000-LRCC LACONIA
1155-iSTAR02/1I03-LRCC-CAT-G-CONFERENCE RM-DSM		Armed	Inactive	1000-LRCC LACONIA
1156-iSTAR02/1I04-LRCC-CAT-G-NURSE STORAGE-DSM		Armed	Inactive	1000-LRCC LACONIA
1157-iSTAR02/1I05-LRCC-CAT-G-NURSE SIM-DSM		Armed	Inactive	1000-LRCC LACONIA
1158-iSTAR02/1I06-LRCC-CAT-G-CONTROL RM-DSM		Armed	Inactive	1000-LRCC LACONIA
1159-iSTAR02/1I07-LRCC-CAT-G-NURSE SIM-DSM		Armed	Inactive	1000-LRCC LACONIA
1160-iSTAR02/1I08-LRCC-CAT-G-NURSE CLASSROOM-DSM		Armed	Inactive	1000-LRCC LACONIA
1153B-iSTAR02/1I09-LRCC-CAT-G-BETWEEN CLASSROOMS-REX		Armed	Update Disabled	1000-LRCC LACONIA
1154-iSTAR02/1I10-LRCC-CAT-G-STORAGE-REX		Armed	Update Disabled	1000-LRCC LACONIA
1155-iSTAR02/1I11-LRCC-CAT-G-CONFERENCE RM-REX		Armed	Update Disabled	1000-LRCC LACONIA
1156-iSTAR02/1I12-LRCC-CAT-G-NURSE STORAGE-REX		Armed	Update Disabled	1000-LRCC LACONIA
1157-iSTAR02/1I13-LRCC-CAT-G-NURSE SIM-REX		Armed	Update Disabled	1000-LRCC LACONIA
1158-iSTAR02/1I14-LRCC-CAT-G-CONTROL RM-REX		Armed	Update Disabled	1000-LRCC LACONIA
1159-iSTAR02/1I15-LRCC-CAT-G-NURSE SIM-REX		Armed	Update Disabled	1000-LRCC LACONIA
1160-iSTAR02/1I16-LRCC-CAT-G-NURSE CLASSROOM-REX		Armed	Update Disabled	1000-LRCC LACONIA
1162-iSTAR02/2I01-LRCC-CAT-G-NURSE STORAGE-DSM		Armed	Inactive	1000-LRCC LACONIA
1163-iSTAR02/2I02-LRCC-CAT-G-MED STORAGE-DSM		Armed	Inactive	1000-LRCC LACONIA
1163A-iSTAR02/2I03-LRCC-CAT-G-NURSE STORAGE-DSM		Armed	Inactive	1000-LRCC LACONIA
1164-iSTAR02/2I04-LRCC-CAT-G-NURSE CLASSROOM-DSM		Armed	Inactive	1000-LRCC LACONIA
1162-iSTAR02/2I09-LRCC-CAT-G-NURSE STORAGE-REX		Armed	Update Disabled	1000-LRCC LACONIA

1163-iSTAR02/2I10-LRCC-CAT-G-MED STORAGE-REX		Armed	Update Disabled	1000-LRCC LACONIA
1163A-iSTAR02/2I11-LRCC-CAT-G-NURSE STORAGE-REX		Armed	Update Disabled	1000-LRCC LACONIA
1164-iSTAR02/2I12-LRCC-CAT-G-NURSE CLASSROOM-REX		Armed	Update Disabled	1000-LRCC LACONIA
1236-iSTAR03/1I01-LRCC-CAT-1ST-ACADEMIC COMMONS-DSM		Armed	Inactive	1000-LRCC LACONIA
1236A-iSTAR03/1I02-LRCC-CAT-1ST-ACADEMIC COMMONS REAR-DSM		Armed	Inactive	1000-LRCC LACONIA
1238-iSTAR03/1I03-LRCC-CAT-1ST-STORAGE-DSM		Armed	Inactive	1000-LRCC LACONIA
1239-iSTAR03/1I04-LRCC-CAT-1ST-KITCHEN-DSM		Armed	Inactive	1000-LRCC LACONIA
1243-iSTAR03/1I05-LRCC-CAT-1ST-CLASSROOM-DSM		Armed	Inactive	1000-LRCC LACONIA
1244-iSTAR03/1I06-LRCC-CAT-1ST-ANTE/COPY-DSM		Armed	Inactive	1000-LRCC LACONIA
1246-iSTAR03/1I07-LRCC-CAT-1ST-BIO/MICRO FAC-DSM		Armed	Inactive	1000-LRCC LACONIA
1247-iSTAR03/1I08-LRCC-CAT-1ST-PHYSICS STORAGE-DSM		Armed	Inactive	1000-LRCC LACONIA
1236-iSTAR03/1I09-LRCC-CAT-1ST-ACADEMIC COMMONS-REX		Armed	Update Disabled	1000-LRCC LACONIA
1236A-iSTAR03/1I10-LRCC-CAT-1ST-ACADEMIC COMMONS REAR-REX		Armed	Update Disabled	1000-LRCC LACONIA
1238-iSTAR03/1I11-LRCC-CAT-1ST-STORAGE-REX		Armed	Update Disabled	1000-LRCC LACONIA
1239-iSTAR03/1I12-LRCC-CAT-1ST-KITCHEN-REX		Armed	Update Disabled	1000-LRCC LACONIA
1243-iSTAR03/1I13-LRCC-CAT-1ST-CLASSROOM-REX		Armed	Update Disabled	1000-LRCC LACONIA
1244-iSTAR03/1I14-LRCC-CAT-1ST-ANTE/COPY-REX		Armed	Update Disabled	1000-LRCC LACONIA
1246-iSTAR03/1I15-LRCC-CAT-1ST-BIO/MICRO FAC-REX		Armed	Update Disabled	1000-LRCC LACONIA
1247-iSTAR03/1I16-LRCC-CAT-1ST-PHYSICS STORAGE-REX		Armed	Update Disabled	1000-LRCC LACONIA
1248-iSTAR03/2I01-LRCC-CAT-1ST-PHYSICS FAC-DSM		Armed	Inactive	1000-LRCC LACONIA
1249-iSTAR03/2I02-LRCC-CAT-1ST-PHYSICS LAB-DSM		Armed	Inactive	1000-LRCC LACONIA
1255-iSTAR03/2I03-LRCC-CAT-1ST-CONF RM-DSM		Armed	Inactive	1000-LRCC LACONIA
1256-iSTAR03/2I04-LRCC-CAT-1ST-CHEM STORAGE-DSM		Armed	Inactive	1000-LRCC LACONIA
1257-iSTAR03/2I05-LRCC-CAT-1ST-CHEM PREP-DSM		Armed	Inactive	1000-LRCC LACONIA
1258-iSTAR03/2I06-LRCC-CAT-1ST-CHEM LAB-DSM		Armed	Inactive	1000-LRCC LACONIA
1260A-iSTAR03/2I07-LRCC-CAT-1ST-PREP STORAGE-DSM		Armed	Inactive	1000-LRCC LACONIA
1260B-iSTAR03/2I08-LRCC-CAT-1ST-PREP STORAGE-DSM		Armed	Inactive	1000-LRCC LACONIA
1248-iSTAR03/2I09-LRCC-CAT-1ST-PHYSICS FAC-REX		Armed	Update Disabled	1000-LRCC LACONIA
1249-iSTAR03/2I10-LRCC-CAT-1ST-PHYSICS LAB-REX		Armed	Update Disabled	1000-LRCC LACONIA
1255-iSTAR03/2I11-LRCC-CAT-1ST-CONF RM-REX		Armed	Update Disabled	1000-LRCC LACONIA
1256-iSTAR03/2I12-LRCC-CAT-1ST-CHEM STORAGE-REX		Armed	Update Disabled	1000-LRCC LACONIA
1257-iSTAR03/2I13-LRCC-CAT-1ST-CHEM PREP-REX		Armed	Update Disabled	1000-LRCC LACONIA

1258-iSTAR03/2I14-LRCC-CAT-1ST-CHEM LAB-REX		Armed	Update Disabled	1000-LRCC LACONIA
1260A-iSTAR03/2I15-LRCC-CAT-1ST-PREP STORAGE-REX		Armed	Update Disabled	1000-LRCC LACONIA
1260B-iSTAR03/2I16-LRCC-CAT-1ST-PREP STORAGE-REX		Armed	Update Disabled	1000-LRCC LACONIA
1261A-iSTAR04/1I01-LRCC-CAT-1ST-261 TO 158 CLASSROOM-DSM		Armed	Inactive	1000-LRCC LACONIA
1261B-iSTAR04/1I02-LRCC-CAT-1ST-MICRO/BIO LAB-DSM		Armed	Inactive	1000-LRCC LACONIA
1261C-iSTAR04/1I03-LRCC-CAT-1ST-MICRO/BIO LAB-DSM		Armed	Inactive	1000-LRCC LACONIA
1262A-iSTAR04/1I04-LRCC-CAT-1ST-MICRO/BIO PREP-DSM		Armed	Inactive	1000-LRCC LACONIA
1262B-iSTAR04/1I05-LRCC-CAT-1ST-MICRO/BIO PREP-DSM		Armed	Inactive	1000-LRCC LACONIA
1263A-iSTAR04/1I06-LRCC-CAT-1ST-BIO LAB-DSM		Armed	Inactive	1000-LRCC LACONIA
1263B-iSTAR04/1I07-LRCC-CAT-1ST-BIO LAB-DSM		Armed	Inactive	1000-LRCC LACONIA
1264A-iSTAR04/1I08-LRCC-CAT-1ST-PREP STORAGE-DSM		Armed	Inactive	1000-LRCC LACONIA
1261A-iSTAR04/1I09-LRCC-CAT-1ST-261 TO 158 CLASSROOM-REX		Armed	Update Disabled	1000-LRCC LACONIA
1261B-iSTAR04/1I10-LRCC-CAT-1ST-MICRO/BIO LAB-REX		Armed	Update Disabled	1000-LRCC LACONIA
1261C-iSTAR04/1I11-LRCC-CAT-1ST-MICRO/BIO LAB-REX		Armed	Update Disabled	1000-LRCC LACONIA
1262A-iSTAR04/1I12-LRCC-CAT-1ST-MICRO/BIO PREP-REX		Armed	Update Disabled	1000-LRCC LACONIA
1262B-iSTAR04/1I13-LRCC-CAT-1ST-MICRO/BIO PREP-REX		Armed	Update Disabled	1000-LRCC LACONIA
1263A-iSTAR04/1I14-LRCC-CAT-1ST-BIO LAB-REX		Armed	Update Disabled	1000-LRCC LACONIA
1263B-iSTAR04/1I15-LRCC-CAT-1ST-BIO LAB-REX		Armed	Update Disabled	1000-LRCC LACONIA
1264A-iSTAR04/1I16-LRCC-CAT-1ST-PREP STORAGE-REX		Armed	Update Disabled	1000-LRCC LACONIA
1264B-iSTAR04/2I01-LRCC-CAT-1ST-PREP STORAGE-DSM		Armed	Inactive	1000-LRCC LACONIA
1265-iSTAR04/2I02-LRCC-CAT-1ST-STORAGE-DSM		Armed	Inactive	1000-LRCC LACONIA
1234-iSTAR04/2I03-LRCC-CAT-1ST-MAIN ENT-DSM		Armed	Inactive	1000-LRCC LACONIA
1264B-iSTAR04/2I09-LRCC-CAT-1ST-PREP STORAGE-REX		Armed	Update Disabled	1000-LRCC LACONIA
1265-iSTAR04/2I10-LRCC-CAT-1ST-STORAGE-REX		Armed	Update Disabled	1000-LRCC LACONIA
1234-iSTAR04/2I11-LRCC-CAT-1ST-MAIN ENT-REX		Armed	Update Disabled	1000-LRCC LACONIA
1008-iSTAR01/ACM1/I06-LRCC-TURNER-MAINT SHOP-DSM		Armed	Inactive	1000-LRCC LACONIA
1008-iSTAR01/ACM1/I06-LRCC-TURNER-MAINT SHOP-REX		Armed	Update Disabled	1000-LRCC LACONIA

LRCC OLD BUILDING ISTAR 1 LOCK DOORS-BTN	LRCC OLD BUILDING ISTAR 1 LOCK DOORS-BTN BUTTON IS ON THE ISTAR DOOR TO LOCK ALL DOORS ON THE PANEL INCASE OF NETWORK FAILURE	Armed	Inactive	1000-LRCC LACONIA
LRCC-CAT BUILDING ISTAR 1 AND 2 DOOR LOCK-BTN	LRCC-CAT BUILDING ISTAR 1 AND 2 DOOR LOCK-BTN BUTTON IS ON THE ISTAR DOOR TO LOCK ALL DOORS ON THE PANEL INCASE OF NETWORK FAILURE	Armed	Inactive	1000-LRCC LACONIA
LRCC-CAT BUILDING ISTAR 4 AND 4 DOOR LOCK-BTN	LRCC-CAT BUILDING ISTAR 4 AND 4 DOOR LOCK-BTN BUTTON LOCATED ON ISTAR 3 IN CAT BUILDING TO LOCK DOORS INCASE OF NETWORK LOSS	Armed	Inactive	1000-LRCC LACONIA
LRCC-AUTOMOTIVE REAR MAN DOOR-DSM	LRCC-AUTOMOTIVE REAR MAN DOOR-DSM	Armed	Inactive	1000-LRCC LACONIA
LRCC-AUTOMOTIVE REAR MAN DOOR-REX	LRCC-AUTOMOTIVE REAR MAN DOOR-REX	Armed	Update Disabled	1000-LRCC LACONIA
LRCC-AUTOMOTIVE MAIN LOBBY HC BUTTON-TRIP	LRCC-AUTOMOTIVE MAIN LOBBY HC BUTTON-TRIP	Armed	Inactive	1000-LRCC LACONIA
LRCC-AUTOMOTIVE MAIN ENTRANCE-DSM	LRCC-AUTOMOTIVE MAIN ENTRANCE-DSM	Armed	Inactive	1000-LRCC LACONIA
LRCC-AUTOMOTIVE MAIN ENTRANCE-REX	LRCC-AUTOMOTIVE MAIN ENTRANCE-REX	Armed	Update Disabled	1000-LRCC LACONIA

LRCC-AUTOMOTIVE MAIN LOBBY-DSM	LRCC-AUTOMOTIVE MAIN LOBBY-DSM	Armed	Inactive	1000-LRCC LACONIA
LRCC-AUTOMOTIVE MAIN LOBBY-REX	LRCC-AUTOMOTIVE MAIN LOBBY-REX	Armed	Update Disabled	1000-LRCC LACONIA
LRCC-AUTOMOTIVE CLASSROOM/LAB 115-DSM	LRCC-AUTOMOTIVE CLASSROOM/LAB 115-DSM	Armed	Inactive	1000-LRCC LACONIA
LRCC-AUTOMOTIVE CLASSROOM/LAB 115-REX	LRCC-AUTOMOTIVE CLASSROOM/LAB 115-REX	Armed	Update Disabled	1000-LRCC LACONIA
LRCC-AUTOMOTIVE CLASSROOM/LAB 114-DSM	LRCC-AUTOMOTIVE CLASSROOM/LAB 114-DSM	Armed	Inactive	1000-LRCC LACONIA
LRCC-AUTOMOTIVE CLASSROOM/LAB 114-REX	LRCC-AUTOMOTIVE CLASSROOM/LAB 114-REX	Armed	Update Disabled	1000-LRCC LACONIA
Communication Fail-iSTAR Output Board1-ACM1-LRCC-AUTOMOTIVE ISTAR		Armed	Inactive	1000-LRCC LACONIA
Communication Fail-iSTAR Input Board1-ACM1-LRCC-AUTOMOTIVE ISTAR		Armed	Inactive	1000-LRCC LACONIA
LRCC-AUTOMOTIVE REAR OVERHEAD-CONT	LRCC-AUTOMOTIVE REAR OVERHEAD-CONT	Armed	Inactive	1000-LRCC LACONIA
LRCC-AUTOMOTIVE CLASSROOM/LAB 115 OVERHEAD-CONT	LRCC-AUTOMOTIVE CLASSROOM/LAB 115 OVERHEAD-CONT	Armed	Inactive	1000-LRCC LACONIA
LRCC-AUTOMOTIVE CLASSROOM/LAB 114 OVERHEAD-CONT	LRCC-AUTOMOTIVE CLASSROOM/LAB 114 OVERHEAD-CONT	Armed	Inactive	1000-LRCC LACONIA
LRCC-EXT DOOR NEAR ROOM 113-DSM	LRCC-EXT DOOR NEAR ROOM 113-DSM	Armed	Active	1000-LRCC LACONIA
LRCC-EXT DOOR NEAR ROOM 113-REX	LRCC-EXT DOOR NEAR ROOM 113-REX	Armed	Update Disabled	1000-LRCC LACONIA
LRCC-AUTOMOTIVE BOILER-ALARM	LRCC-AUTOMOTIVE BOILER-ALARM	Armed	Inactive	1000-LRCC LACONIA
LRCC-EXT DOOR NEAR ROOM 124-DSM	LRCC-EXT DOOR NEAR ROOM 124-DSM	Armed	Inactive	1000-LRCC LACONIA
LRCC-EXT DOOR NEAR ROOM 124-REX	LRCC-EXT DOOR NEAR ROOM 124-REX	Armed	Update Disabled	1000-LRCC LACONIA

LRCC-CAT-1ST FLOOR EXT NEAR ROOM 124-DSM	LRCC-CAT-1ST FLOOR EXT NEAR ROOM 124-DSM	Armed	Inactive	1000-LRCC LACONIA
LRCC-CAT-1ST FLOOR EXT NEAR ROOM 124-REX	LRCC-CAT-1ST FLOOR EXT NEAR ROOM 124-REX	Armed	Update Disabled	1000-LRCC LACONIA
LRCC-AUTOMOTIVE IT CLOSET-DSM	LRCC-AUTOMOTIVE IT CLOSET-DSM	Armed	Inactive	1000-LRCC LACONIA
LRCC-AUTOMOTIVE IT CLOSET-REX	LRCC-AUTOMOTIVE IT CLOSET-REX	Armed	Update Disabled	1000-LRCC LACONIA
Wireless Reader Tamper - LRCC-AUTOMOTIVE IT CLOSET		Armed	Inactive	1000-LRCC LACONIA
Low Battery - LRCC-AUTOMOTIVE IT CLOSET		Armed	Inactive	1000-LRCC LACONIA
Manual Lock Override - LRCC-AUTOMOTIVE IT CLOSET		Armed	Inactive	1000-LRCC LACONIA
Push Button - LRCC-AUTOMOTIVE IT CLOSET		Unknown	Unknown	1000-LRCC LACONIA
LRCC-AUTOMOTIVE BOILER ROOM-DSM	LRCC-AUTOMOTIVE BOILER ROOM-DSM	Armed	Inactive	1000-LRCC LACONIA
LRCC-AUTOMOTIVE BOILER ROOM-REX	LRCC-AUTOMOTIVE BOILER ROOM-REX	Armed	Update Disabled	1000-LRCC LACONIA
Wireless Reader Tamper - LRCC-AUTOMOTIVE BOILER ROOM		Armed	Inactive	1000-LRCC LACONIA
Low Battery - LRCC-AUTOMOTIVE BOILER ROOM		Armed	Inactive	1000-LRCC LACONIA
Manual Lock Override - LRCC-AUTOMOTIVE BOILER ROOM		Armed	Inactive	1000-LRCC LACONIA
Push Button - LRCC-AUTOMOTIVE BOILER ROOM		Unknown	Unknown	1000-LRCC LACONIA
LRCC-AUTOMOTIVE STORAGE ROOM 103-DSM		Armed	Inactive	1000-LRCC LACONIA
LRCC-AUTOMOTIVE STORAGE ROOM 103-REX	LRCC-AUTOMOTIVE STORAGE ROOM 103-REX	Armed	Update Disabled	1000-LRCC LACONIA
Wireless Reader Tamper - LRCC-AUTOMOTIVE STORAGE ROOM		Armed	Inactive	1000-LRCC LACONIA
Low Battery - LRCC-AUTOMOTIVE STORAGE ROOM		Armed	Inactive	1000-LRCC LACONIA
Manual Lock Override - LRCC-AUTOMOTIVE STORAGE ROOM		Armed	Inactive	1000-LRCC LACONIA
Push Button - LRCC-AUTOMOTIVE STORAGE ROOM		Unknown	Unknown	1000-LRCC LACONIA
LRCC-AUTOMOTIVE ADMIN OFFICE-DSM	LRCC-AUTOMOTIVE ADMIN OFFICE-DSM	Armed	Inactive	1000-LRCC LACONIA
LRCC-AUTOMOTIVE ADMIN OFFICE-REX	LRCC-AUTOMOTIVE ADMIN OFFICE-REX	Armed	Update Disabled	1000-LRCC LACONIA
Wireless Reader Tamper - LRCC-AUTOMOTIVE ADMIN OFFICE		Armed	Inactive	1000-LRCC LACONIA

Low Battery - LRCC-AUTOMOTIVE ADMIN OFFICE		Armed	Inactive	1000-LRCC LACONIA
Manual Lock Override - LRCC-AUTOMOTIVE ADMIN OFFICE		Armed	Inactive	1000-LRCC LACONIA
Push Button - LRCC-AUTOMOTIVE ADMIN OFFICE		Unknown	Unknown	1000-LRCC LACONIA
LRCC-AUTOMOTIVE CLASSROOM 113-DSM	LRCC-AUTOMOTIVE CLASSROOM 113-DSM	Armed	Inactive	1000-LRCC LACONIA
LRCC-AUTOMOTIVE CLASSROOM 113-REX	LRCC-AUTOMOTIVE CLASSROOM 113-REX	Armed	Update Disabled	1000-LRCC LACONIA
Low Battery - LRCC DOOR 2-RDR		Armed	Inactive	1000-LRCC LACONIA
Manual Lock Override - LRCC DOOR 2-RDR		Armed	Inactive	1000-LRCC LACONIA
Push Button - LRCC DOOR 2-RDR		Unknown	Unknown	1000-LRCC LACONIA
LRCC-AUTOMOTIVE STORAGE ROOM 110-DSM	LRCC-AUTOMOTIVE STORAGE ROOM 110-DSM	Armed	Inactive	1000-LRCC LACONIA
LRCC-AUTOMOTIVE STORAGE ROOM 110-REX	LRCC-AUTOMOTIVE STORAGE ROOM 110-REX	Armed	Update Disabled	1000-LRCC LACONIA
Wireless Reader Tamper - LRCC DOOR 3-RDR		Armed	Inactive	1000-LRCC LACONIA
Low Battery - LRCC DOOR 3-RDR		Armed	Inactive	1000-LRCC LACONIA
Manual Lock Override - LRCC DOOR 3-RDR		Armed	Inactive	1000-LRCC LACONIA
Push Button - LRCC DOOR 3-RDR		Unknown	Unknown	1000-LRCC LACONIA
LRCC-AUTOMOTIVE CLASSROOM 115-DSM	LRCC-AUTOMOTIVE CLASSROOM 115-DSM	Armed	Inactive	1000-LRCC LACONIA
LRCC-AUTOMOTIVE CLASSROOM 115-REX	LRCC-AUTOMOTIVE CLASSROOM 115-REX	Armed	Update Disabled	1000-LRCC LACONIA
Wireless Reader Tamper - LRCC DOOR 4-RDR		Armed	Inactive	1000-LRCC LACONIA
Low Battery - LRCC DOOR 4-RDR		Armed	Inactive	1000-LRCC LACONIA
Manual Lock Override - LRCC DOOR 4-RDR		Armed	Inactive	1000-LRCC LACONIA
Push Button - LRCC DOOR 4-RDR		Armed	Inactive	1000-LRCC LACONIA
LRCC-AUTOMOTIVE CLASSROOM 114-DSM	LRCC-AUTOMOTIVE CLASSROOM 114-DSM	Armed	Active	1000-LRCC LACONIA
LRCC-AUTOMOTIVE CLASSROOM 114-REX	LRCC-AUTOMOTIVE CLASSROOM 114-REX	Armed	Update Disabled	1000-LRCC LACONIA
Low Battery - LRCC DOOR 1-RDR		Armed	Inactive	1000-LRCC LACONIA

Manual Lock Override - LRCC DOOR 1-RDR		Armed	Inactive	1000-LRCC LACONIA
Push Button - LRCC DOOR 1-RDR		Unknown	Unknown	1000-LRCC LACONIA
Wireless Reader Tamper - LRCC-AUTOMOTIVE CLASSROOM 113-RDR		Armed	Inactive	1000-LRCC LACONIA
Wireless Reader Tamper - LRCC DOOR 1-RDR		Armed	Inactive	1000-LRCC LACONIA
LRCC-AUTOMOTIVE LOCKDOWN-BTN		Armed	Inactive	1000-LRCC LACONIA
LRCC ISTAR 03 OUTPUT BOARD COMM FAIL		Armed	Active	1000-LRCC LACONIA
000000TEST		Armed	Inactive	1000-LRCC LACONIA
iSTAR04/2I04-LRCC-CAT BUILDING-LOCKDOWN BUTTON		Armed	Inactive	1000-LRCC LACONIA

Name	Description	Open Status	arm State stat	Mode Status	ice Filter Leve	Partition Name
MCC-NORTH WING 2ND FLOOR ENTRANCE DOOR	MCC-A KNOX BLDG 2ND FLOOR ENTRANCE DOOR	Closed	Normal	Unlocked	in:1	3000-MCC MANCHESTER
MCC-231 AMT LAB DOOR	MCC-231 AMT LAB DOOR	Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-235 COMPUTER SCIENCE CLASSROOM DOOR	MCC-235 COMPUTER SCIENCE CLASSROOM DOOR	Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-243 EXERCISE CLASSROOM DOOR	MCC-243 EXERCISE CLASSROOM DOOR	Closed	Normal	Unlocked	in:1	3000-MCC MANCHESTER
MCC-241 EXERCISE SCIENCE LAB LEFT DOOR	MCC-241 EXERCISE SCIENCE LAB LEFT DOOR	Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-241 EXERCISE SCIENCE LAB RIGHT DOOR	MCC-241 EXERCISE SCIENCE LAB RIGHT DOOR	Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-237 COMPUTER CLASSROOM DOOR	MCC-237 COMPUTER CLASSROOM DOOR	Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-CHILD DEVELOPMENT CENTER REAR ENTRANCE DOOR	MCC-CHILD DEVELOPMENT CENTER REAR ENTRANCE DOOR	Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-CHILD DEVELOPMENT CENTER MAIN ENTRANCE DOOR	MCC-CHILD DEVELOPMENT CENTER MAIN ENTRANCE DOOR	Open	Held Open	Locked	in:1	3000-MCC MANCHESTER
MCC-253 COMPUTER LAB DOOR	MCC-253 COMPUTER LAB DOOR	Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-COMPUTER /EXERCISE HALL ENTRANCE DOOR	MCC-COMPUTER /EXERCISE HALL ENTRANCE DOOR	Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-321 NURSING LAB RIGHT DOOR	MCC-321 NURSING LAB RIGHT DOOR	Closed	Normal	Locked	in:1	3000-MCC MANCHESTER

MCC-321 NURSING LAB LEFT DOOR	MCC-321 NURSING LAB LEFT DOOR	Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-325 COMPUTER LAB DOOR	MCC-325 COMPUTER LAB DOOR	Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-327 MEDICAL ASSISTING LAB RIGHT DOOR	MCC-327 MEDICAL ASSISTING LAB RIGHT DOOR	Closed	Normal	Unlocked	in:1	3000-MCC MANCHESTER
MCC-327 MEDICAL ASSISTING LAB LEFT DOOR	MCC-327 MEDICAL ASSISTING LAB LEFT DOOR	Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-258 HUMAN RESOURCES DOOR	MCC-258 HUMAN RESOURCES DOOR	Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-MAIN LOBBY DOOR	MCC-MAIN LOBBY DOOR	Closed	Normal	Unlocked	in:1	3000-MCC MANCHESTER
MCC-285 MICROBIOLOGY LAB DOOR	MCC-285 MICROBIOLOGY LAB DOOR	Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-289 SCIENCE LAB DOOR	MCC-289 SCIENCE LAB DOOR	Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-295 SCIENCE LAB DOOR	MCC-295 SCIENCE LAB DOOR	Open	Held Open	Locked	in:1	3000-MCC MANCHESTER
MCC-297 PHYSICS/EARTH SCIENCE LAB DOOR	MCC-297 PHYSICS/EARTH SCIENCE LAB DOOR	Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-HSCI SIDE ENTRANCE DOOR	MCC-HSCI SIDE ENTRANCE DOOR	Closed	Normal	Unlocked	in:1	3000-MCC MANCHESTER
MCC-276 COMPUTER LAB DOOR	MCC-276 COMPUTER LAB DOOR	Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-279 CHEMISTRY LAB LEFT DOOR	MCC-279 CHEMISTRY LAB LEFT DOOR	Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-279 CHEMISTRY LAB RIGHT DOOR	MCC-279 CHEMISTRY LAB RIGHT DOOR	Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-268 LIBRARY DOOR	MCC-268 LIBRARY DOOR	Closed	Normal	Unlocked	in:1	3000-MCC MANCHESTER

MCC-225-1 METALLURGY LAB LEFT DOOR	MCC-225-1 METALLURGY LAB LEFT DOOR	Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-225-METALLURGY LAB RIGHT DOOR	MCC-225-METALLURGY LAB RIGHT DOOR	Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-219 COMPUTER LAB DOOR	MCC-219 COMPUTER LAB DOOR	Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-222-COMPUTER LAB RIGHT DOOR	MCC-222-COMPUTER LAB RIGHT DOOR	Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-222-COMPUTER LAB LEFT DOOR	MCC-222-COMPUTER LAB LEFT DOOR	Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-217 ELECTRICAL TECH LAB DOOR	MCC-217 ELECTRICAL TECH LAB DOOR	Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-215-ELECTRICAL TECH LAB LEFT DOOR	MCC-215-ELECTRICAL TECH LAB LEFT DOOR	Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-215-ELECTRICAL TECH LAB RIGHT DOOR	MCC-215-ELECTRICAL TECH LAB RIGHT DOOR	Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-216 COMPUTER LAB DOOR	MCC-216 COMPUTER LAB DOOR	Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-211 WELDING LAB DOOR	MCC-211 WELDING LAB DOOR	Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-209 HVAC DOOR	MCC-209 HVAC DOOR	Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-207 HVAC CLASSROOM DOOR	MCC-207 HVAC CLASSROOM DOOR	Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-203 CAD LAB DOOR	MCC-203 CAD LAB DOOR	Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-133-WELDING LAB DOOR	MCC-133-WELDING LAB DOOR	Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-133-WELDING LAB REAR DOOR	MCC-133-WELDING LAB REAR DOOR	Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-135-AIR CON LAB DOOR	MCC-135-AIR CON LAB DOOR	Closed	Normal	Locked	in:1	3000-MCC MANCHESTER

MCC-135-AIR CON LAB REAR DOOR	MCC-135-AIR CON LAB REAR DOOR	Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-137-HEATING LAB DOOR	MCC-137-HEATING LAB DOOR	Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-137-HEATING LAB REAR DOOR	MCC-137-HEATING LAB REAR DOOR	Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-139-BUILDING CONSTRUCTION DOOR	MCC-139-BUILDING CONSTRUCTION DOOR	Open	Held Open	Locked	in:1	3000-MCC MANCHESTER
MCC-139-BUILDING CONSTRUCTION REAR DOOR	MCC-139-BUILDING CONSTRUCTION REAR DOOR	Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-CAFE EMPLOYEE ENTRANCE DOOR	MCC-CAFE EMPLOYEE ENTRANCE DOOR	Closed	Normal	Unlocked	in:1	3000-MCC MANCHESTER
MCC-GYM GLASS DOORS-DOOR	MCC-GYM GLASS DOORS-DOOR	Closed	Normal	Unlocked	in:1	3000-MCC MANCHESTER
MCC-PRESIDENTS OFFICE DOOR	MCC-PRESIDENTS OFFICE DOOR	Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-VAULT DOOR	MCC-VAULT DOOR	Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-ENTRANCE 46 1ST FLOOR	MCC-CENTRAL WING ENTRANCE DOOR 1ST FLOOR - near mens bathroom	Closed	Normal	Unlocked	in:1	3000-MCC MANCHESTER
MCC-106 GRAPHIC DESIGN LAB DOOR	MCC-106 GRAPHIC DESIGN LAB DOOR	Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-108 ART AND DESIGN LAB DOOR	MCC-108 ART AND DESIGN LAB DOOR	Closed	Normal	Locked	in:1 / out:1	3000-MCC MANCHESTER
MCC-110 ART AND DESIGN LAB DOOR	MCC-110 ART AND DESIGN LAB DOOR	Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-141 BUILDING CONSTRUCTION REAR DOOR	MCC-141 BUILDING CONSTRUCTION REAR DOOR	Closed	Normal	Locked	in:1	3000-MCC MANCHESTER

MCC-STUDENT ENTRANCE DOOR	MCC-STUDENT ENTRANCE DOOR	Closed	Normal	Unlocked	in:1	3000-MCC MANCHESTER
MCC-SERVER ROOM DOOR	MCC-SERVER ROOM DOOR	Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-3rd FL weightroom ENTRANCE DOOR		Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-AUTO LAB 1 REAR ENTRANCE DOOR		Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-AUTO LAB 1 ENTRANCE DOOR		Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-AUTO LAB 2 ENTRANCE DOOR		Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-AUTO 123 CLASSROOM 4 DOOR		Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-AUTO 122 CLASSROOM 3 DOOR		Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-AUTO 121 CLASSROOM 2 DOOR		Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-AUTO 120 CLASSROOM 1 DOOR		Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-AUTO LAB 2 REAR ENTRANCE DOOR		Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-AUTO MAIN ENTRANCE DOOR		Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-AUTO STUDENT ENTRANCE DOOR		Closed	Normal	Unlocked	in:1	3000-MCC MANCHESTER
MCC-AUTO 121 CLASSROOM 2 REAR DOOR		Closed	Normal	Locked	in:1	3000-MCC MANCHESTER

MCC-AUTO 122 CLASSROOM 3 REAR DOOR		Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-102 ROBOTICS CLASS DOOR		Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-102 ROBOTICS LAB DOOR		Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-ADVANCED TECH 101 HVAC MOTORS DOOR		Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-ADVANCED TECH 102 ETECH MOTORS 2 DOOR		Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-ADVANCED TECH 103 ETECH MOTORS 1 DOOR		Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-ADVANCED TECH 113 TELE/DATA DOOR		Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-ADVANCED TECH109 PLC LAB DOOR		Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-ADVANCED TECH CHILLER LAB DOOR		Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-ADVANCED TECH 224 HVAC 101 DOOR		Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-ADVANCED TECH 219 ETEC DOC DOOR		Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-ADVANCED TECH OUTDOOR LAB DOOR		Closed	Normal	Locked	in:1	3000-MCC MANCHESTER

MCC-ADVANCED TECH 213 AHU LAB DOOR		Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-ADVANCED TECH 223 RELATED ELECTRICITY DOOR		Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-ADVANCED TECH 218 COMPUTER LAB LEFT DOOR		Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-ADVANCED TECH 218 COMPUTER LAB RIGHT DOOR		Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-ADVANCED TECH 217 HVAC DDC DOOR		Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-ADVANCED TECH MAIN ENTRANCE DOOR		Closed	Normal	Unlocked	in:1	3000-MCC MANCHESTER
MCC-BURSAR FRONT ENTRANCE DOOR		Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-BURSAR REAR ENTRANCE DOOR		Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-240 ADVANCED MANUFACTURING SINGLE DOOR		Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-ENTRANCE 43 DOOR		Closed	Normal	Unlocked	in:1	3000-MCC MANCHESTER

Name	Description	Controller Name	Online Status	Certificate signing status
NCC-NASHUA 3RD FLOOR HSH EDGE 1	PANEL LOCATED IN IDF CLOSET BUILDING H ON 3RD FLOOR	iSTAR Edge	Online	Unknown
NCC-NASHUA 3RD FLOOR HSH EDGE 2	PANEL LOCATED IN IDF CLOSET BUILDING H ON 3RD FLOOR	iSTAR Edge	Online	Unknown
NCC-NASHUA 2ND FLOOR HSH	PANEL LOCATED IN IDF BULDING H	iSTAR Classic/Pro	Online	Unknown
NCC-NASHUA 1ST FLOOR AUTO EXT	PANEL LOCATED IN IDF CLOSET NEXT TO AUTOMOTIVE	iSTAR Classic/Pro	Online	Unknown
NCC-NASHUA 1ST FLOOR MAIN IDF	PANEL LOCATED IN IMAIN IDF ROOM 101	iSTAR Classic/Pro	Online	Unknown
NCC-NASHUA 1ST FLOOR LIBRARY 132A	PANEL LOCATED IN IDF CLOSET IN LIBRARY COMPUTER LAB	iSTAR Classic/Pro	Online	Unknown
NCC-NASHUA 1ST FLOOR WOMENS LOCKER RM	PANEL LOCATED IN IDF CLOSET NEXT TO WOMENS LOCKER ROOM BY BASKETBALL COURTS	iSTAR Classic/Pro	Online	Unknown
NCC-NASHUA 2ND FLOOR LAB STORAGE	LOCATED IN LAB STORAGE ROOM ON 2NF FLOOR IN STORAGE ROOM BETWEEN RM 218 AND RM 220	iSTAR Classic/Pro	Online	Unknown

Partition Name
4500-NCC NASHUA
4500-NCC NASHUA
4500-NCC NASHUA
4500-NCC NASHUA
4500-NCC NASHUA
4500-NCC NASHUA
4500-NCC NASHUA
4500-NCC NASHUA

Name	Description	Open Status	Alarm State status	Mode Status
NHTI-GRAPPONE MAIN ENTRANCE 1 DOOR	NHTI-GRAPPONE MAIN ENTRANCE DOOR	Closed	Normal	Unlocked
NHTI-GRAPPONE REAR ENTRANCE DOOR	NHTI-GRAPPONE REAR ENTRANCE DOOR	Closed	Normal	Unlocked
NHTI-GRAPPONE NURSING LAB AREA DOOR	NHTI-GRAPPONE NURSING LAB AREA DOOR	Closed	Normal	Unlocked
NHTI-GRAPPONE 133 CLASSROOM DOOR	NHTI-GRAPPONE 133 CLASSROOM DOOR	Closed	Normal	Locked
NHTI-GRAPPONE 136 NURSING SKILLS LAB DOOR	NHTI-GRAPPONE 136 NURSING SKILLS LAB DOOR	Closed	Normal	Locked
NHTI-GRAPPONE 218 COMPUTER LAB DOOR	NHTI-GRAPPONE 218 COMPUTER LAB DOOR	Closed	Normal	Locked
NHTI-FARNUM F103 NETWORKING DOOR	NHTI-FARNUM F103 NETWORKING DOOR	Closed	Normal	Locked
NHTI-FARNUM MAIN ENTRANCE DOOR	NHTI-FARNUM MAIN ENTRANCE DOOR	Closed	Normal	Unlocked
NHTI-SWEENEY MAIN ENTRANCE DOOR	NHTI-SWEENEY MAIN ENTRANCE DOOR	Closed	Normal	Unlocked
NHTI-SWEENEY BISTRO EMPLOYEE ENTRANCE DOOR	NHTI-SWEENEY BISTRO EMPLOYEE ENTRANCE DOOR	Closed	Normal	Locked
NHTI-LIBRARY BOOK STORE ENTRANCE DOOR	NHTI-LIBRARY BOOK STORE ENTRANCE DOOR	Closed	Normal	Locked
NHTI-LIBRARY SHIPPING/RECIEVING DOOR	NHTI-LIBRARY SHIPPING/RECIEVING DOOR	Closed	Normal	Locked
NHTI-LIBRARY REAR DOOR	NHTI-LIBRARY REAR DOOR	Closed	Normal	Locked
NHTI-MAINTENANCE ENTRANCE DOOR	NHTI-MAINTENANCE ENTRANCE DOOR	Closed	Normal	Unlocked

NHTI-MACRURY 137 DENTAL COMPUTER ROOM DOOR	NHTI-MACRURY DENTAL COMPUTER ROOM DOOR	Closed	Normal	Unlocked
NHTI-MACRURY QUAD ENTRANCE DOOR	NHTI-MACRURY QUAD ENTRANCE DOOR DENTAL ANNEX	Closed	Normal	Unlocked
NHTI-MACRURY MAIN ENTRANCE DOOR	Faces Farnum Hall	Closed	Normal	Unlocked
NHTI-MACRURY REAR ENTRANCE DOOR	NHTI-MACRURY REAR ENTRANCE DOOR	Closed	Normal	Unlocked
NHTI-MACRURY M113 LIBRARY DOOR	NHTI-MACRURY M113 LIBRARY DOOR	Closed	Normal	Locked
NHTI-MACRURY M208 COMPUTER LAB DOOR	NHTI-MACRURY M208 COMPUTER LAB DOOR	Closed	Normal	Locked
NHTI-MACRURY M201 PARAMEDIC SUITE DOOR	NHTI-MACRURY M201 PARAMEDIC SUITE DOOR	Closed	Normal	Locked
NHTI-MACRURY M201C PARAMEDIC AMBULANCE DOOR	NHTI-MACRURY M201C PARAMEDIC AMBULANCE DOOR	Closed	Normal	Locked
NHTI-MACRURY M201D PARAMEDIC BREAKOUT DOOR	NHTI-MACRURY M201D PARAMEDIC BREAKOUT DOOR	Closed	Normal	Locked
NHTI- LANGLEY HALL A WING 1ST FLOOR INTERIOR DOOR	NHTI- LANGLEY HALL A WING 1ST FLOOR INTERIOR DOOR O THE LANGLEY MAIN RESIDENT LOBBY.	Open	Normal	Unlocked
NHTI- LANGLEY HALL A WING EXTERIOR DOOR	NHTI- LANGLEY HALL A WING EXTERIOR DOOR	Closed	Normal	Locked
NHTI- LANGLEY HALL MAIN LOBBY DOOR	NHTI- LANGLEY HALL MAIN LOBBY DOOR	Open	Held Open	Locked

NHTI- LANGLEY HALL B WING EXTERIOR DOOR	NHTI- LANGLEY HALL B WING EXTERIOR DOOR	Closed	Normal	Locked
NHTI- LANGLEY HALL C WING EXTERIOR DOOR	NHTI-LANGLEY HALL C WING EXTERIOR DOOR	Closed	Normal	Locked
NHTI- LANGLEY HALL BOILER ROOM EXTERIOR DOOR	NHTI- LANGLEY HALL BOILER ROOM EXTERIOR DOOR	Closed	Normal	Locked
NHTI-SOUTH HALL EAST DOOR	NHTI-SOUTH HALL EASTDOOR	Closed	Normal	Locked
NHTI-SOUTH HALL WEST DOOR	NHTI-SOUTH HALL WEST DOOR	Closed	Normal	Locked
NHTI-SOUTH HALL FRONT DOOR	NHTI-SOUTH HALL FRONT DOOR	Closed	Normal	Locked
NHTI-SOUTH HALL ELECTRICAL DOOR	NHTI-SOUTH HALL ELECTRICAL DOOR	Closed	Normal	Locked
NHTI-LITTLE HALL SLIDER TO CAPITAL COMMONS DOOR	NHTI-LITTLE HALL SLIDER TO CAPITAL COMMONS DOOR	Closed	Normal	Unlocked
NHTI-LITTLE HALL SLIDER TO STREET DOOR	NHTI-LITTLE HALL SLIDER TO STREET DOOR	Closed	Normal	Unlocked
NHTI-LITTLE HALL L112 CLASSROOM DOOR	NHTI-LITTLE HALL L112 CLASSROOM DOOR	Closed	Normal	Locked
NHTI-LITTLE HALL L128 CLASSROOM DOOR	NHTI-LITTLE HALL L128 CLASSROOM DOOR	Closed	Normal	Locked
NHTI-LITTLE HALL L204 CLASSROOM DOOR	NHTI-LITTLE HALL L204 CLASSROOM DOOR	Closed	Normal	Locked
NHTI-LITTLE HALL L231 CLASSROOM DOOR	NHTI-LITTLE HALL L231 CLASSROOM DOOR	Closed	Normal	Locked
NHTI-CAPITAL COMMONS DATA CLOSET DOOR	NHTI-CAPITAL COMMONS DATA CLOSET DOOR	Closed	Normal	Locked
NHTI-CAPITAL COMMONS MANAGERS OFFICE DOOR	NHTI-CAPITAL COMMONS MANAGERS OFFICE DOOR	Open	Held Open	Locked
NHTI-CAPITAL COMMONS RECIEVING DOOR	NHTI-CAPITAL COMMONS RECIEVING DOOR	Open	Held Open	Locked

NHTI-WELLNESS CENTER FITNESS ROOM DOOR	NHTI-WELLNESS CENTER FITNESS ROOM DOOR	Closed	Normal	Locked
NHTI-STUDENT CENTER ENTRANCE DOOR	NHTI-STUDENT CENTER ENTRANCE DOOR	Closed	Normal	Unlocked
NHTI-WELLNESS CENTER ENTRANCE DOOR	NHTI-WELNESS CENTER ENTRANCE DOOR	Closed	Normal	Unlocked
NHTI-STUDENT CENTER AFFAIR DOOR	NHTI-STUDENT CENTER AFFAIR DOOR	Closed	Normal	Locked
NHTI-WELLNESS CENTER ACTIVITY IN/OUT	NHTI-WELLNESS CENTER ACTIVITY IN/OUT	Closed	Normal	Locked
NHTI-WELLNESS CENTER OFFICE DOOR	NHTI-WELLNESS CENTER OFFICE DOOR	Closed	Normal	Locked
NHTI-GRAPPONE MAIN ENTRANCE 2 DOOR		Closed	Normal	Unlocked
NHTI-SWEENEY REAR ENTRANCE DOOR		Closed	Normal	Unlocked
NHTI-STROUT HALL EAST DOOR	NHTI-STROUT HALL EAST DOOR	Closed	Normal	Locked
NHTI-STROUT HALL WEST DOOR	NHTI-STROUT HALL WEST DOOR	Closed	Normal	Locked
NHTI-STROUT HALL FRONT DOOR	NHTI-STROUT HALL FRONT DOOR	Closed	Normal	Locked
NHTI-CFDC MAIN ENTRANCE DOOR	NHTI-CFDC MAIN ENTRANCE DOOR	Open	Held Open	Locked
NHTI- LANGLEY HALL A WING 2ND FLOOR HALL DOOR		Closed	Normal	Unlocked
NHTI- LANGLEY HALL A WING 1ST FLOOR HALL DOOR		Closed	Normal	Unlocked
7000-CO-SERVER ROOM FRONT DOOR		Closed	Normal	Locked
7000-CO-SERVER ROOM REAR DOOR		Closed	Normal	Locked
7000-CO-BACK ENTRANCE DOOR		Closed	Normal	Locked
7000-CO-FRONT ENTRANCE DOOR		Closed	Normal	Locked
7000-CO-CHECK PRINTER DOOR		Closed	Normal	Locked
7000-CO-MIDDLE DOOR		Open	Held Open	Locked
NHTI-LIBRARY EXTERIOR MAIN ENTRANCE DOOR		Closed	Normal	Unlocked
NHTI-LIBRARY INTERIOR MAIN ENTRANCE DOOR		Closed	Normal	Unlocked
NHTI-FARNUM REAR ENTRANCE DOOR		Closed	Normal	Locked
NHTI-CFDC -TODDLER EAST EXIT DOOR		Closed	Normal	Locked
NHTI-CFDC -INFANT EAST EXIT DOOR		Closed	Normal	Locked

NHTI-CFDC -WEST CORRIDOR EXIT DOOR		Closed	Normal	Locked
NHTI-CFDC -PRESCHOOL WEST EXIT DOOR		Open	Forced	Locked
NHTI-CFDC -PRESCHOOL SOUTH EXIT DOOR		Closed	Normal	Locked
NHTI-CFDC -KINDERGARTEN EAST EXIT DOOR		Closed	Normal	Locked
NHTI-CAPITAL COMMONS SOUTHEAST DINING DOOR		Closed	Normal	Locked
NHTI-CAPITAL COMMONS SOUTHWEST DINING DOOR		Closed	Normal	Locked
NHTI-CAPITAL COMMONS CAFE TO PATIO DOOR		Closed	Normal	Locked
NHTI-CAPITAL COMMONS SERVERY EXTERIOR DOOR		Closed	Normal	Locked
NHTI-SWEENEY-BISTRO LOADING ENTRANCE		Closed	Normal	Locked
NHTI-SWEENEY-BISTRO EXTERIOR ENTRANCE		Closed	Normal	Locked
NHTI-SWEENEY-BISTRO FOYER ENTRANCE		Closed	Normal	Locked
NHTI-MACRURY-LOBBY ENTRANCE	DENTAL PATIENT LOBBY	Closed	Normal	Unlocked
NHTI-SWEENEY S301 OFFICE DOOR		Closed	Normal	Locked
NHTI-SWEENEY S318 IT CLASSROOM DOOR		Closed	Normal	Locked
NHTI-SWEENEY S308 CISCO LAB DOOR		Closed	Normal	Locked
NHTI-SWEENEY S309 CISCO LAB CLASSROOM DOOR		Closed	Normal	Locked
NHTI-SWEENEY S306 DH OFFICE DOOR		Closed	Normal	Locked
NHTI-SWEENEY S307 FACULTY OFFICE DOOR		Closed	Normal	Locked
NHTI-FARNUM F104 FACULTY ADJUNCT DOOR		Closed	Normal	Locked
NHTI-CAMPUS SAFTY ENTRANCE DOOR		Closed	Normal	Unlocked
NHTI-SWEENEY S131 FIRE ALARM ROOM DOOR		Closed	Normal	Locked
NHTI-SWEENEY S220A IT ROOM DOOR		Closed	Normal	Locked
NHTI-SWEENEY PLANETARIUM DOUBLE DOOR		Closed	Normal	Locked
NHTI-LITTLE HALL REAR DOUBLE DOOR		Closed	Normal	Locked
NHTI-CAPITAL COMMONS DINING SLIDER DOOR		Closed	Normal	Unlocked
NHTI-MACRURY SIDE ENTRANCE DOOR		Closed	Normal	Unlocked
NHTI- LANGLEY HALL A WING 2ND FLOOR INTERIOR DOOR	NHTI- LANGLEY HALL A WING 2ND FLOOR INTERIOR DOOR	Closed	Normal	Unlocked

Clearance Filter Level Status	Partition Name
in:1	6000-NHTI CONCORD
in:1	6000-NHTI CONCORD
in:1	6000-NHTI CONCORD
in:1	6000-NHTI CONCORD
in:1	6000-NHTI CONCORD
in:1	6000-NHTI CONCORD
in:1	6000-NHTI CONCORD
in:1	6000-NHTI CONCORD
in:1	6000-NHTI CONCORD
in:1	6000-NHTI CONCORD
in:1	6000-NHTI CONCORD
in:1	6000-NHTI CONCORD
in:1	6000-NHTI CONCORD
in:1 / out:1	6000-NHTI CONCORD
in:1	6000-NHTI CONCORD

in:1	6000-NHTI CONCORD
in:1	6000-NHTI CONCORD
in:1	6000-NHTI CONCORD
in:1	6000-NHTI CONCORD
in:1	6000-NHTI CONCORD
in:1	6000-NHTI CONCORD
in:1	6000-NHTI CONCORD
in:1	6000-NHTI CONCORD
in:1	6000-NHTI CONCORD
in:1 / out:1	6000-NHTI CONCORD
in:1	6000-NHTI CONCORD
in:1 / out:1	6000-NHTI CONCORD

in:1	6000-NHTI CONCORD
in:1	6000-NHTI CONCORD
in:1	6000-NHTI CONCORD
in:1	6000-NHTI CONCORD
in:1 / out:1	6000-NHTI CONCORD
in:1 / out:1	6000-NHTI CONCORD
in:1	6000-NHTI CONCORD
in:1	6000-NHTI CONCORD
in:1	6000-NHTI CONCORD
in:1	6000-NHTI CONCORD
in:1	6000-NHTI CONCORD
in:1	6000-NHTI CONCORD
in:1	6000-NHTI CONCORD
in:1	6000-NHTI CONCORD
in:1	6000-NHTI CONCORD
in:1	6000-NHTI CONCORD

in:1	6000-NHTI CONCORD
in:1	6000-NHTI CONCORD
in:1	6000-NHTI CONCORD
in:1	6000-NHTI CONCORD
in:1 / out:1	6000-NHTI CONCORD
in:1	6000-NHTI CONCORD
	6000-NHTI CONCORD
in:1	6000-NHTI CONCORD
in:1 / out:1	6000-NHTI CONCORD
in:1 / out:1	6000-NHTI CONCORD
in:1 / out:1	6000-NHTI CONCORD
in:1	6500-NHTI CFDC
in:1	6000-NHTI CONCORD
in:1	6000-NHTI CONCORD
in:1	7000-CO
in:1	7000-CO
in:1	7000-CO
in:1	7000-CO
in:1	7000-CO
in:1	7000-CO
in:1	6000-NHTI CONCORD
in:1	6000-NHTI CONCORD
	6000-NHTI CONCORD
	6500-NHTI CFDC
	6500-NHTI CFDC

	6500-NHTI CFDC
	6500-NHTI CFDC
	6500-NHTI CFDC
	6500-NHTI CFDC
	6000-NHTI CONCORD
	6000-NHTI CONCORD
	6000-NHTI CONCORD
	6000-NHTI CONCORD
	6000-NHTI CONCORD
	6000-NHTI CONCORD
	6000-NHTI CONCORD
in:1	6000-NHTI CONCORD
in:1	6000-NHTI CONCORD
in:1	6000-NHTI CONCORD
in:1	6000-NHTI CONCORD
in:1	6000-NHTI CONCORD
in:1	6000-NHTI CONCORD
in:1	6000-NHTI CONCORD
in:1	6000-NHTI CONCORD
in:1	6000-NHTI CONCORD
in:1	6000-NHTI CONCORD
	6000-NHTI CONCORD
	6000-NHTI CONCORD
	6000-NHTI CONCORD
	6000-NHTI CONCORD
in:1 / out:1	6000-NHTI CONCORD

Name	Description	Controller Name	Online Status	Certificate signing status
RVCC CLAREMONT ISTAR01-1ST FLOOR SERVER ROOM	RVCC CLAREMONT ISTAR01-1ST FLOOR SERVER ROOM	iSTAR Classic/Pro	Online	Unknown
RVCC KEENE ISTAR EDGE01-1ST FLOOR SERVER ROOM		iSTAR Edge	Online	Unknown
RVCC LEBANON ISTAR		iSTAR Classic/Pro	Online	Unknown
RVCC CLAREMONT ISTAR 2	1 DOOR ISTAR	iSTAR Edge	Online	Unknown

Partition Name
2000-RVCC CLAREMONT/KEENE/LEBANON
2000-RVCC CLAREMONT/KEENE/LEBANON
2000-RVCC CLAREMONT/KEENE/LEBANON
2000-RVCC CLAREMONT/KEENE/LEBANON

Name	Description	Controller Name	Online Status	Certificate signing status
WMCC-iSTAR EDGE		iSTAR Edge	Online	Unknown

Partition Name
5000-WMCC BERLIN

Name	Description	Open Status	Alarm State status	Mode Status
7000-CO-SERVER ROOM FRONT DOOR		Closed	Normal	Locked
7000-CO-SERVER ROOM REAR DOOR		Closed	Normal	Locked
7000-CO-BACK ENTRANCE DOOR		Closed	Normal	Locked
7000-CO-FRONT ENTRANCE DOOR		Closed	Normal	Locked
7000-CO-CHECK PRINTER DOOR		Closed	Normal	Locked
7000-CO-MIDDLE DOOR		Closed	Normal	Locked

Clearance Filter Level Status	Partition Name
in:1	7000-CO
in:1	7000-CO
in:1	7000-CO
in:1	7000-CO
in:1	7000-CO
in:1	7000-CO

COMMUNITY COLLEGE
system of New Hampshire

	Chancellor's Office	NHTI Concord's CC	White Mountains CC	River Valley CC	Lakes Region CC	Manchester CC	Nashua CC	Great Bay CC
Keypad Make/Model	Digital Monitoring Products XR 100	**Strout Hall (1):** Honeywell K4392V2-H/M7240 REV-E **South Hall (1):** Inovonics EchoStream Receiver EN4216MR **Langley Hall (1):** DSC Power 832 PC5010 F53CAN-22839-AL-E/18001721RO **Sweeney Hall (2):** United Security Products, INC. AD-2000/U108018 United Security Products, INC. AD-2000/U108018 **Student Center (2):** United Security Products AD-2000/U068016 United Security Products AD-2000/U068016 **MacRury Hall (1):** United Security Products, INC. AD-2000/U108018 **Learning Commons (1):** DSC Power 832 PC5040/18001721RO **Grappone Hall (1):** United Security Products, INC. AD2001/U028019	(2) Digital Monitoring Products XT 50 @ Berlin DSC Maxsys 4010 v3.0. @ Littleton	Digital Monitoring Products XR 100	Digital Monitoring Products XR 100	Digital Monitoring Products XR 100	Digital Monitoring Products XR 100	Digital Monitoring Products XR 100
Keypad Count	3	10	3	3	7	4	10	2
Hardwired/Cell	Hardwired	Hardwired	Hardwired	Hardwired	Hardwired	Hardwired	Hardwired	Hardwired
Notes:			Littleton alarm monitoring conducted by Capital Alarms					

UPDATED: 10/19/20

Door Report summary

Name	Description	Open Status	Alarm State status	Mode Status	Clearance Filter Level Status	Partition Name
7000-CO-SERVER ROOM FRONT DOOR		Closed	Normal	Locked	in:1	7000-CO
7000-CO-SERVER ROOM REAR DOOR		Closed	Normal	Locked	in:1	7000-CO
7000-CO-BACK ENTRANCE DOOR		Closed	Normal	Locked	in:1	7000-CO
7000-CO-FRONT ENTRANCE DOOR		Closed	Normal	Locked	in:1	7000-CO
7000-CO-CHECK PRINTER DOOR		Closed	Normal	Locked	in:1	7000-CO
7000-CO-MIDDLE DOOR		Closed	Normal	Locked	in:1	7000-CO
Name	Description	Open Status	Alarm State status	Mode Status	Clearance Filter Level Status	Partition Name
GBCC-STUDENT CENTER REAR ENT-DR	Double Swipe Setup toggle mode cancellation sched: 4000-Double Swipe Relock	Closed	Normal	Locked	in:1	4000-GBCC PORTSMOUTH/ ROCHESTER
GBCC-STUDENT CENTER GYM ENT-DR		Closed	Normal	Locked	in:1	4000-GBCC PORTSMOUTH/ ROCHESTER
GBCC-STUDENT CENTER HALLWALL EXIT--DR		Open	Held Open	Locked	in:1	4000-GBCC PORTSMOUTH/ ROCHESTER
GBCC-STUDENT CENTER HALLWALL ENT--DR		Open	Held Open	Locked	in:1	4000-GBCC PORTSMOUTH/ ROCHESTER
GBCC-STUDENT CENTER GREEN BEAN REAR ENT-DR		Closed	Normal	Locked	in:1	4000-GBCC PORTSMOUTH/ ROCHESTER
GBCC-STUDENT CENTER MAIN ENT-DR	Double Swipe Setup toggle mode cancellation sched: 4000-Double Swipe Relock	Closed	Normal	Locked	in:1	4000-GBCC PORTSMOUTH/ ROCHESTER
GBCC-STUDENT CENTER FITNESS CENTER ENT-DR		Closed	Normal	Locked	in:1	4000-GBCC PORTSMOUTH/ ROCHESTER
GBCC-DATA CENTER-DR		Closed	Normal	Locked	in:1	4000-GBCC PORTSMOUTH/ ROCHESTER
GBCC-LOADING DOCK-DR		Closed	Normal	Locked	in:1	4000-GBCC PORTSMOUTH/ ROCHESTER
GBCC-NORTH ENTRANCE-DR		Closed	Normal	Locked	in:1	4000-GBCC PORTSMOUTH/ ROCHESTER
GBCC-MAIN ENT-DR	Double Swipe Setup toggle mode cancellation sched: 4000-Double Swipe Relock	Closed	Normal	Locked	in:1	4000-GBCC PORTSMOUTH/ ROCHESTER
GBCC-BUSINESS ENT-DR		Closed	Normal	Locked	in:1	4000-GBCC PORTSMOUTH/ ROCHESTER
GBCC-VET TECH ENT-DR		Closed	Normal	Locked	in:1	4000-GBCC PORTSMOUTH/ ROCHESTER
GBCC-STUDENT CENTER GYM RIGHT-DR		Closed	Normal	Locked	in:1	4000-GBCC PORTSMOUTH/ ROCHESTER

GBCC-STUDENT CENTER ROOM 95-DR		Closed	Normal	Locked	in:1	4000-GBCC PORTSMOUTH/ ROCHESTER
GBCC-STUDENT CENTER ROOM 96-DR		Closed	Normal	Locked	in:1	4000-GBCC PORTSMOUTH/ ROCHESTER
GBCC- ROCHESTER MAIN ENTRANCE DOOR	Double Swipe Setup toggle mode cancellation sched: 4000-Double Swipe Relock	Closed	Normal	Locked	in:1	4000-GBCC PORTSMOUTH/ ROCHESTER
GBCC-ROCHESTER SIDE ENTRANCE DOOR		Closed	Normal	Locked	in:1	4000-GBCC PORTSMOUTH/ ROCHESTER
GBCC-ROCHESTER VESTIBULE 164 LAB DOOR		Closed	Normal	Locked	in:1	4000-GBCC PORTSMOUTH/ ROCHESTER
GBCC- ROCHESTER ADVANCED MANUFACTURING LAB DOOR		Closed	Normal	Locked	in:1	4000-GBCC PORTSMOUTH/ ROCHESTER
GBCC-ONE STOP DOOR		Closed	Normal	Locked	in:1	4000-GBCC PORTSMOUTH/ ROCHESTER
GBCC-CHEMESTRY LAB NE140 DOOR		Closed	Normal	Locked	in:1	4000-GBCC PORTSMOUTH/ ROCHESTER
GBCC-LIFE SCIENCE NE141 DOOR		Closed	Normal	Locked	in:1	4000-GBCC PORTSMOUTH/ ROCHESTER
GBCC-LIFE SCIENCE NE142 DOOR		Closed	Normal	Locked	in:1	4000-GBCC PORTSMOUTH/ ROCHESTER
GBCC-LIFE SCIENCE NE143 DOOR		Closed	Normal	Locked	in:1	4000-GBCC PORTSMOUTH/ ROCHESTER
GBCC-BIO PREP NE149 DOOR		Closed	Normal	Locked	in:1	4000-GBCC PORTSMOUTH/ ROCHESTER
GBCC-BIO LAB NE149A DOOR		Closed	Normal	Locked	in:1	4000-GBCC PORTSMOUTH/ ROCHESTER
GBCC-BIO LAB 149C DOOR		Closed	Normal	Locked	in:1	4000-GBCC PORTSMOUTH/ ROCHESTER
GBCC-LOADING DOCK 2 DOOR		Closed	Normal	Locked	in:1	4000-GBCC PORTSMOUTH/ ROCHESTER
GBCC-VET TECH NE154 DOOR		Open	Forced	Locked	in:1	4000-GBCC PORTSMOUTH/ ROCHESTER
GBCC-NE148 MAINTENANCE DOOR		Open	Held Open	Locked	in:1	4000-GBCC PORTSMOUTH/ ROCHESTER
GBCC-STUDENT CENTER FITNESS CENTER OFFICE-DR		Closed	Normal	Locked	in:1	4000-GBCC PORTSMOUTH/ ROCHESTER
GBCC- ROCHESTER VESTIBULE 140 TO WELDING LAB		Closed	Normal	Unlocked	in:1	4000-GBCC PORTSMOUTH/ ROCHESTER
GBCC- ROCHESTER VESTIBULE 140 TO CNC LAB		Closed	Normal	Locked	in:1	4000-GBCC PORTSMOUTH/ ROCHESTER
GBCC- ROCHESTER WELDING LAB TO TO CNC LAB		Closed	Normal	Locked	in:1	4000-GBCC PORTSMOUTH/ ROCHESTER

Name	Description	Open Status	Alarm State status	Mode Status	Clearance Filter Level Status	Partition Name
1007-LRCC-CAT BUILDING EXIT TO METAL RAMP		Closed	Normal	Unlocked	in:1	1000-LRCC LACONIA
1008-LRCC-CAT EXIT TO LOWER LOT SOUTHERN	NEAR TRANSFORMER	Closed	Normal	Locked	in:1	1000-LRCC LACONIA
1001-LRCC TURNER BUILDING-MAINT DOOR		Closed	Normal	Locked	in:1	1000-LRCC LACONIA
1002-LRCC TURNER MAIN ENTRANCE.		Closed	Normal	Unlocked	in:1	1000-LRCC LACONIA
1003-LRCC TURNER BUILDING CAFE EXIT DOOR NEAR LOADING DOCK		Closed	Normal	Unlocked	in:1	1000-LRCC LACONIA
1004-LRCC TURNER CAFE EXIT BY BOOK STORE		Closed	Normal	Unlocked	in:1	1000-LRCC LACONIA
1005-LRCC TURNER CAFE EXIT BY KITCHEN		Closed	Normal	Unlocked	in:1	1000-LRCC LACONIA
1130-LRCC H/S G-IT CLOSET		Closed	Normal	Locked	in:1	1000-LRCC LACONIA
1152A-LRCC H\S BUILDING-CLASSROOM-FIRE SCIENCE		Open	Held Open	Locked	in:1	1000-LRCC LACONIA
1153A-LRCC H/S BUILDING CLASSROOM-FIRE SCIENCE		Open	Held Open	Locked	in:1	1000-LRCC LACONIA
1135-LRCC H/S BUILDING CLASSROOM-NURSING		Closed	Normal	Locked	in:1	1000-LRCC LACONIA
1136-LRCC H/S BUILDING NURSE FACULTY OFFICE		Closed	Normal	Locked	in:1	1000-LRCC LACONIA
1137-LRCC H\S NURSES FACULTY OFFICE		Closed	Normal	Locked	in:1	1000-LRCC LACONIA
1138-LRCC H/S NURSES FACULTY OFFICE		Closed	Normal	Locked	in:1	1000-LRCC LACONIA
1140-LRCC H/S FIRST FLOOR COPY ROOM		Closed	Normal	Locked	in:1	1000-LRCC LACONIA
1142-LRCC H\S CLASSROOM-NURSING		Closed	Normal	Locked	in:1	1000-LRCC LACONIA
1147-LRCC H/S SIDE EXIT LEADING TO BASKET BALL COURT		Closed	Normal	Locked	in:1	1000-LRCC LACONIA
1148-LRCC H\S -FACULTY OFFICE-FIRE SCIENCE		Closed	Normal	Locked	in:1	1000-LRCC LACONIA
1149-LRCC H/S FACULTY OFFICE-FIRE SCIENCE		Open	Held Open	Locked	in:1	1000-LRCC LACONIA
1151-LRCC H/S BUILDING STORAGE DOOR FIRE SCIENCE		Closed	Normal	Locked	in:1	1000-LRCC LACONIA
1152B-LRCC H/S BUILDING CLASSROOM EXTTERIOR DOOR FIRE SCIENCE		Closed	Normal	Locked	in:1	1000-LRCC LACONIA
1153B-LRCC H/S BUILDING DOOR BETWEEN RM 153 AND 152		Closed	Normal	Locked	in:1	1000-LRCC LACONIA

1154-LRCC H/S BUILDING STORAGE-FIRE SCIENCE		Open	Held Open	Locked	in:1	1000-LRCC LACONIA
1155-LRCC H/S BUILDING CONFERENCE RM		Closed	Normal	Locked	in:1	1000-LRCC LACONIA
1156-LRCC H/S BUILDING STORGE-NURSING		Closed	Normal	Locked	in:1	1000-LRCC LACONIA
1157-LRCC H/S BUILDING SIM ROOM-NURSING		Closed	Normal	Locked	in:1	1000-LRCC LACONIA
1158-LRCC H/S BUILDING NURSING CONTROL ROOM		Closed	Normal	Locked	in:1	1000-LRCC LACONIA
1159-LRCC H/S BUILDING NURSING SIM ROOM		Closed	Normal	Locked	in:1	1000-LRCC LACONIA
1160-LRCC H/S BUILDING NURSING LAB CLASSROOM		Closed	Normal	Locked	in:1	1000-LRCC LACONIA
1162-LRCC H/S NURSING STORAGE		Closed	Normal	Locked	in:1	1000-LRCC LACONIA
1163-LRCC H/S MEDICATION STORAGE-NURSING		Closed	Normal	Locked	in:1	1000-LRCC LACONIA
1163A-LRCC H/S BUILDING STORAGE-NURSING		Closed	Normal	Locked	in:1	1000-LRCC LACONIA
1164-LRCC H/S BUILDING CLASSROOM LAB-NURSING		Closed	Normal	Locked	in:1	1000-LRCC LACONIA
1236-LRCC H/S BUILDING ACADEMIC COMMONS MAIN		Closed	Normal	Locked	in:1	1000-LRCC LACONIA
1236A-LRCC H/S BUILDING ACADEMIC COMMONS REAR		Closed	Normal	Locked	in:1	1000-LRCC LACONIA
1239-LRCC H/S BUILDING KITCHEN		Closed	Normal	Locked	in:1	1000-LRCC LACONIA
1243LRCC H/S BUILDING GENERAL CLASSROOM		Closed	Normal	Locked	in:1	1000-LRCC LACONIA
1244-LRCC H/S SECOND FLOOR COPY RM		Closed	Normal	Locked	in:1	1000-LRCC LACONIA
1246-LRCC H/S BUILDING BIO/MICRO FAC OFFICE		Closed	Normal	Locked	in:1	1000-LRCC LACONIA
1247-LRCC H/S BUILDING PHYSICS STORAGE		Open	Held Open	Locked	in:1	1000-LRCC LACONIA
1248-LRCC H/S BUILDING PHYSICS OFFICE		Closed	Normal	Locked	in:1	1000-LRCC LACONIA
1249-LRCC H/S BUILDING PHYSICS LAB		Closed	Normal	Locked	in:1	1000-LRCC LACONIA
1255-LRCC H/S BUILDING CONF RM		Closed	Normal	Locked	in:1	1000-LRCC LACONIA
1256-LRCC H/S BUILDING CHEM STORAGE		Closed	Normal	Locked	in:1	1000-LRCC LACONIA
1257-LRCC H/S BUILDING CHEM PREP		Closed	Normal	Locked	in:1	1000-LRCC LACONIA
1258-LRCC H/S BUILDING CHEM LAB		Closed	Normal	Locked	in:1	1000-LRCC LACONIA

1260A-LRCC H/S BUILDING PREP STORAGE		Closed	Normal	Locked	in:1	1000-LRCC LACONIA
1260B-LRCC H/S BUILDING PREP STORAGE		Closed	Normal	Locked	in:1	1000-LRCC LACONIA
1261A-LRCC H/S BUILDING 261 TO 258 CLASSROOM		Closed	Normal	Locked	in:1	1000-LRCC LACONIA
1234-LRCC H/S MAIN ENTRANCE		Closed	Normal	Unlocked	in:1	1000-LRCC LACONIA
1261B-LRCC H/S BUILDING MICRO/BIO LAB		Closed	Normal	Locked	in:1	1000-LRCC LACONIA
1261C-LRCC H/S BUILDING MICRO/BIO LAB		Closed	Normal	Locked	in:1	1000-LRCC LACONIA
1262A-LRCC H/S BUILDING MICRO/BIO PREP		Closed	Normal	Locked	in:1	1000-LRCC LACONIA
1262B-LRCC H/S BUILDING MICRO/BIO PREP		Closed	Normal	Locked	in:1	1000-LRCC LACONIA
1263A-LRCC H/S BUILDING BIO LAB		Closed	Normal	Locked	in:1	1000-LRCC LACONIA
1263B H/S BUILDING BIO LAB		Closed	Normal	Locked	in:1	1000-LRCC LACONIA
1264A-LRCC H/S BUILDING PREP STORAGE		Closed	Normal	Locked	in:1	1000-LRCC LACONIA
1264B- LRCC H/S BUILDING PREP STORAGE		Closed	Normal	Locked	in:1	1000-LRCC LACONIA
1265-LRCC H/S BUILDING STORAGE		Closed	Normal	Locked	in:1	1000-LRCC LACONIA
1009-TURNER-MAINT SHOP INSIDE DOOR		Closed	Normal	Locked	in:1	1000-LRCC LACONIA
1238-LRCC H/S 1ST-STORAGE		Closed	Normal	Locked	in:1	1000-LRCC LACONIA
TURNER BUILDING LOCKDOWN-DR		Closed	Normal	Locked	in:1	1000-LRCC LACONIA
CAT/H/S BUILDING LOCKDOWN-DR		Closed	Normal	Locked	in:1	1000-LRCC LACONIA
LRCC-AUTOMOTIVE REAR MAN DOOR	LRCC-AUTOMOTIVE REAR MAN DOOR	Closed	Normal	Locked	in:1	1000-LRCC LACONIA
LRCC-AUTOMOTIVE GLASS INTERIOR SHOP DOORS	LRCC-AUTOMOTIVE GLASS INTERIOR SHOP DOORS	Closed	Normal	Locked	in:1	1000-LRCC LACONIA
LRCC-AUTO DOOR MAIN ENTRANCE	LRCC-AUTOMOTIVEMAIN ENTRANCE	Closed	Normal	Unlocked	in:1	1000-LRCC LACONIA
LRCC-AUTOMOTIVE CLASSROOM/LAB 115 DOOR	LRCC-AUTOMOTIVE CLASSROOM/LAB 115 DOOR	Closed	Normal	Locked	in:1	1000-LRCC LACONIA
LRCC-AUTOMOTIVE CLASSROOM/LAB 114 DOOR	LRCC-AUTOMOTIVE CLASSROOM/LAB 114 DOOR	Closed	Normal	Locked	in:1	1000-LRCC LACONIA
LRCC TURNER EXTERIOR DOOR LEADING TO GAS PUMP	LRCC-EXTERIOR DOOR TO GAS PUMP	Closed	Normal	Unlocked	in:1	1000-LRCC LACONIA
LRCC TURNER EXTERIOR DOOR LEADING TO FRONT PARKING	LRCC-EXT DOOR TO FRONT LOT PARKING	Open	Forced	Unlocked	in:1	1000-LRCC LACONIA

LRCC CAT 1ST FLOOR EXIT DOOR 106 SIDE NORTHERN	LRCC-CAT-1ST FLOOR EXT near pottery DOOR 106 SIDE	Closed	Normal	Unlocked	in:1	1000-LRCC LACONIA
LRCC-AUTOMOTIVE IT CLOSET DOOR	LRCC-AUTOMOTIVE IT CLOSET DOOR WIRELESS ADDRESS 0 CCURE ADDRESS 1	Closed	Normal	Locked	in:1	1000-LRCC LACONIA
LRCC-AUTOMOTIVE BOILER ROOM	LRCC-AUTOMOTIVE BOILER ROOM WIRELESS ADDRESS 1 CCURE ADDRESS 2	Closed	Normal	Locked	in:1	1000-LRCC LACONIA
LRCC-AUTOMOTIVE STORAGE ROOM 103 DOOR	LRCC-AUTOMOTIVE STORAGE ROOM 103 DOOR WIRELESS ADDRESS 2 CCURE ADDRESS 3	Closed	Normal	Locked	in:1	1000-LRCC LACONIA
LRCC-AUTOMOTIVE ADMIN OFFICE DOOR	LRCC-AUTOMOTIVE ADMIN OFFICE DOOR WIRELESS ADDRESS 3 CCURE ADDRESS 4	Open	Forced	Locked	in:1	1000-LRCC LACONIA
LRCC-AUTOMOTIVE CLASSROOM 114 DOOR	LRCC-AUTOMOTIVE CLASSROOM 114 DOOR WIRELESS ADDRESS 4 CCURE ADDRESS 5	Open	Forced	Locked	in:1	1000-LRCC LACONIA
LRCC-AUTOMOTIVE CLASSROOM 113 DOOR	LRCC-AUTOMOTIVE CLASSROOM 113 DOOR WIRELESS ADDRESS 5 CCURE ADDRESS 6	Closed	Normal	Locked	in:1	1000-LRCC LACONIA
LRCC-AUTOMOTIVE STORAGE ROOM 110 DOOR	LRCC-AUTOMOTIVE STORAGE ROOM 110 DOOR WIRELESS ADDRESS 6 CCURE ADDRESS 7	Closed	Normal	Locked	in:1	1000-LRCC LACONIA
LRCC-AUTOMOTIVE CLASSROOM 115 DOOR	LRCC-AUTOMOTIVE CLASSROOM 115 DOOR WIRELESS ADDRESS 7 CCURE ADDRESS 8	Closed	Normal	Locked	in:1	1000-LRCC LACONIA
Name	Description	Open Status	Alarm State status	Mode Status	Clearance Filter Level Status	Partition Name
MCC-NORTH WING 2ND FLOOR ENTRANCE DOOR	MCC-A KNOX BLDG 2ND FLOOR ENTRANCE DOOR	Closed	Normal	Unlocked	in:1	3000-MCC MANCHESTER
MCC-231 AMT LAB DOOR	MCC-231 AMT LAB DOOR	Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-235 COMPUTER SCIENCE CLASSROOM DOOR	MCC-235 COMPUTER SCIENCE CLASSROOM DOOR	Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-243 EXERCISE CLASSROOM DOOR	MCC-243 EXERCISE CLASSROOM DOOR	Closed	Normal	Unlocked	in:1	3000-MCC MANCHESTER
MCC-241 EXERCISE SCIENCE LAB LEFT DOOR	MCC-241 EXERCISE SCIENCE LAB LEFT DOOR	Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-241 EXERCISE SCIENCE LAB RIGHT DOOR	MCC-241 EXERCISE SCIENCE LAB RIGHT DOOR	Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-237 COMPUTER CLASSROOM DOOR	MCC-237 COMPUTER CLASSROOM DOOR	Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-CHILD DEVELOPMENT CENTER REAR ENTRANCE DOOR	MCC-CHILD DEVELOPMENT CENTER REAR ENTRANCE DOOR	Closed	Normal	Locked	in:1	3000-MCC MANCHESTER

MCC-CHILD DEVELOPMENT CENTER MAIN ENTRANCE DOOR	MCC-CHILD DEVELOPMENT CENTER MAIN ENTRANCE DOOR	Open	Held Open	Locked	in:1	3000-MCC MANCHESTER
MCC-253 COMPUTER LAB DOOR	MCC-253 COMPUTER LAB DOOR	Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-COMPUTER/EXERCISE HALL ENTRANCE DOOR	MCC-COMPUTER/EXERCISE HALL ENTRANCE DOOR	Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-321 NURSING LAB RIGHT DOOR	MCC-321 NURSING LAB RIGHT DOOR	Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-321 NURSING LAB LEFT DOOR	MCC-321 NURSING LAB LEFT DOOR	Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-325 COMPUTER LAB DOOR	MCC-325 COMPUTER LAB DOOR	Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-327 MEDICAL ASSISTING LAB RIGHT DOOR	MCC-327 MEDICAL ASSISTING LAB RIGHT DOOR	Closed	Normal	Unlocked	in:1	3000-MCC MANCHESTER
MCC-327 MEDICAL ASSISTING LAB LEFT DOOR	MCC-327 MEDICAL ASSISTING LAB LEFT DOOR	Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-258 HUMAN RESOURCES DOOR	MCC-258 HUMAN RESOURCES DOOR	Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-MAIN LOBBY DOOR	MCC-MAIN LOBBY DOOR	Closed	Normal	Unlocked	in:1	3000-MCC MANCHESTER
MCC-285 MICROBIOLOGY LAB DOOR	MCC-285 MICROBIOLOGY LAB DOOR	Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-289 SCIENCE LAB DOOR	MCC-289 SCIENCE LAB DOOR	Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-295 SCIENCE LAB DOOR	MCC-295 SCIENCE LAB DOOR	Open	Held Open	Locked	in:1	3000-MCC MANCHESTER
MCC-297 PHYSICS/EARTH SCIENCE LAB DOOR	MCC-297 PHYSICS/EARTH SCIENCE LAB DOOR	Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-HSCI SIDE ENTRANCE DOOR	MCC-HSCI SIDE ENTRANCE DOOR	Closed	Normal	Unlocked	in:1	3000-MCC MANCHESTER
MCC-276 COMPUTER LAB DOOR	MCC-276 COMPUTER LAB DOOR	Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-279 CHEMISTRY LAB LEFT DOOR	MCC-279 CHEMISTRY LAB LEFT DOOR	Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-279 CHEMISTRY LAB RIGHT DOOR	MCC-279 CHEMISTRY LAB RIGHT DOOR	Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-268 LIBRARY DOOR	MCC-268 LIBRARY DOOR	Closed	Normal	Unlocked	in:1	3000-MCC MANCHESTER
MCC-225-1 METALLURGY LAB LEFT DOOR	MCC-225-1 METALLURGY LAB LEFT DOOR	Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-225-METALLURGY LAB RIGHT DOOR	MCC-225-METALLURGY LAB RIGHT DOOR	Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-219 COMPUTER LAB DOOR	MCC-219 COMPUTER LAB DOOR	Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-222-COMPUTER LAB RIGHT DOOR	MCC-222-COMPUTER LAB RIGHT DOOR	Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-222-COMPUTER LAB LEFT DOOR	MCC-222-COMPUTER LAB LEFT DOOR	Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-217 ELECTRICAL TECH LAB DOOR	MCC-217 ELECTRICAL TECH LAB DOOR	Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-215-ELECTRICAL TECH LAB LEFT DOOR	MCC-215-ELECTRICAL TECH LAB LEFT DOOR	Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-215-ELECTRICAL TECH LAB RIGHT DOOR	MCC-215-ELECTRICAL TECH LAB RIGHT DOOR	Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-216 COMPUTER LAB DOOR	MCC-216 COMPUTER LAB DOOR	Closed	Normal	Locked	in:1	3000-MCC MANCHESTER

MCC-211 WELDING LAB DOOR	MCC-211 WELDING LAB DOOR	Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-209 HVAC DOOR	MCC-209 HVAC DOOR	Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-207 HVAC CLASSROOM DOOR	MCC-207 HVAC CLASSROOM DOOR	Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-203 CAD LAB DOOR	MCC-203 CAD LAB DOOR	Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-133-WELDING LAB DOOR	MCC-133-WELDING LAB DOOR	Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-133-WELDING LAB REAR DOOR	MCC-133-WELDING LAB REAR DOOR	Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-135-AIR CON LAB DOOR	MCC-135-AIR CON LAB DOOR	Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-135-AIR CON LAB REAR DOOR	MCC-135-AIR CON LAB REAR DOOR	Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-137-HEATING LAB DOOR	MCC-137-HEATING LAB DOOR	Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-137-HEATING LAB REAR DOOR	MCC-137-HEATING LAB REAR DOOR	Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-139-BUILDING CONSTRUCTION DOOR	MCC-139-BUILDING CONSTRUCTION DOOR	Open	Held Open	Locked	in:1	3000-MCC MANCHESTER
MCC-139-BUILDING CONSTRUCTION REAR DOOR	MCC-139-BUILDING CONSTRUCTION REAR DOOR	Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-CAFE EMPLOYEE ENTRANCE DOOR	MCC-CAFE EMPLOYEE ENTRANCE DOOR	Closed	Normal	Unlocked	in:1	3000-MCC MANCHESTER
MCC-GYM GLASS DOORS-DOOR	MCC-GYM GLASS DOORS-DOOR	Closed	Normal	Unlocked	in:1	3000-MCC MANCHESTER
MCC-PRESIDENTS OFFICE DOOR	MCC-PRESIDENTS OFFICE DOOR	Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-VAULT DOOR	MCC-VAULT DOOR	Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC- ENTRANCE 46 1ST FLOOR	MCC-CENTRAL WING ENTRANCE DOOR 1ST FLOOR - near mens bathroom	Closed	Normal	Unlocked	in:1	3000-MCC MANCHESTER
MCC-106 GRAPHIC DESIGN LAB DOOR	MCC-106 GRAPHIC DESIGN LAB DOOR	Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-108 ART AND DESIGN LAB DOOR	MCC-108 ART AND DESIGN LAB DOOR	Closed	Normal	Locked	in:1 / out:1	3000-MCC MANCHESTER
MCC-110 ART AND DESIGN LAB DOOR	MCC-110 ART AND DESIGN LAB DOOR	Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-141 BUILDING CONSTRUCTION REAR DOOR	MCC-141 BUILDING CONSTRUCTION REAR DOOR	Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-STUDENT ENTRANCE DOOR	MCC-STUDENT ENTRANCE DOOR	Closed	Normal	Unlocked	in:1	3000-MCC MANCHESTER
MCC-SERVER ROOM DOOR	MCC-SERVER ROOM DOOR	Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-3rd FL weightroom ENTRANCE DOOR		Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-AUTO LAB 1 REAR ENTRANCE DOOR		Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-AUTO LAB 1 ENTRANCE DOOR		Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-AUTO LAB 2 ENTRANCE DOOR		Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-AUTO 123 CLASSROOM 4 DOOR		Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-AUTO 122 CLASSROOM 3 DOOR		Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-AUTO 121 CLASSROOM 2 DOOR		Closed	Normal	Locked	in:1	3000-MCC MANCHESTER

MCC-AUTO 120 CLASSROOM 1 DOOR		Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-AUTO LAB 2 REAR ENTRANCE DOOR		Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-AUTO MAIN ENTRANCE DOOR		Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-AUTO STUDENT ENTRANCE DOOR		Closed	Normal	Unlocked	in:1	3000-MCC MANCHESTER
MCC-AUTO 121 CLASSROOM 2 REAR DOOR		Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-AUTO 122 CLASSROOM 3 REAR DOOR		Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-102 ROBOTICS CLASS DOOR		Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-102 ROBOTICS LAB DOOR		Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-ADVANCED TECH 101 HVAC MOTORS DOOR		Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-ADVANCED TECH 102 ETECH MOTORS 2 DOOR		Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-ADVANCED TECH 103 ETECH MOTORS 1 DOOR		Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-ADVANCED TECH 113 TELE/DATA DOOR		Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-ADVANCED TECH109 PLC LAB DOOR		Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-ADVANCED TECH CHILLER LAB DOOR		Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-ADVANCED TECH 224 HVAC 101 DOOR		Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-ADVANCED TECH 219 ETEC DOC DOOR		Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-ADVANCED TECH OUTDOOR LAB DOOR		Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-ADVANCED TECH 213 AHU LAB DOOR		Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-ADVANCED TECH 223 RELATED ELECTRICITY DOOR		Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-ADVANCED TECH 218 COMPUTER LAB LEFT DOOR		Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-ADVANCED TECH 218 COMPUTER LAB RIGHT DOOR		Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-ADVANCED TECH 217 HVAC DDC DOOR		Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-ADVANCED TECH MAIN ENTRANCE DOOR		Closed	Normal	Unlocked	in:1	3000-MCC MANCHESTER
MCC-BURSAR FRONT ENTRANCE DOOR		Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-BURSAR REAR ENTRANCE DOOR		Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-240 ADVANCED MANUFACTURING SINGLE DOOR		Closed	Normal	Locked	in:1	3000-MCC MANCHESTER
MCC-ENTRANCE 43 DOOR		Closed	Normal	Unlocked	in:1	3000-MCC MANCHESTER

Name	Description	Open Status	Alarm State status	Mode Status	Clearance Filter Level Status	Partition Name
NCC-H325-2-NURSING LAB STORAGE DOOR		Closed	Normal	Locked	in:1	4500-NCC NASHUA
NCC-H325-3-NURSING LAB LEFT DOOR		Closed	Normal	Locked	in:1	4500-NCC NASHUA
NCC-H321-CONFERENCE ROOM DOOR		Closed	Normal	Locked	in:1	4500-NCC NASHUA
NCC-3RD FLOOR IDF DOOR		Closed	Normal	Locked	in:1	4500-NCC NASHUA
NCC-H325-3-NURSING LAB RIGHT DOOR		Closed	Normal	Locked	in:1	4500-NCC NASHUA
NCC-2ND FLOOR IDF DOOR		Closed	Normal	Locked	in:1	4500-NCC NASHUA
NCC-H285-LAB CLASSROOM DOOR		Closed	Normal	Locked	in:1	4500-NCC NASHUA
NCC-H281-LAB CLASSROOM DOOR		Open	Held Open	Locked	in:1	4500-NCC NASHUA
NCC-H283-LAB CLASSROOM DOOR		Closed	Normal	Locked	in:1	4500-NCC NASHUA
NCC-H278-LABS OFFICE DOOR		Open	Forced	Locked	in:1	4500-NCC NASHUA
NCC-AUTO LAB GENERAL SHOP ENTRANCE DOOR		Closed	Normal	Locked	in:1	4500-NCC NASHUA
NCC-AUTO LAB NORTH ENTRANCE EXTERIOR DOOR		Closed	Normal	Locked	in:1	4500-NCC NASHUA
NCC-AUTO REPAIR LAB 8 DOOR		Closed	Normal	Locked	in:1	4500-NCC NASHUA
NCC AUTO LAB SOUTH ENTRANCE EXTERIOR DOOR		Open	Forced	Locked	in:1	4500-NCC NASHUA
NCC-H BUILDING MAIN ENTRANCE EXTERIOR DOOR		Open	Forced	Locked	in:1	4500-NCC NASHUA
NCC-H BUILDING NORTH SIDE ENTRANCE EXTERIOR DOOR		Closed	Normal	Locked	in:1	4500-NCC NASHUA
NCC-AUTO MAIN LOBBY ENTRANCE EXTERIOR DOOR		Closed	Normal	Locked	in:1	4500-NCC NASHUA
NCC-H BUILDING SOUTH SIDE ENTRANCE EXTERIOR DOOR		Closed	Normal	Locked	in:1	4500-NCC NASHUA
NCC-N101-1-GYM ENTRANCE DOOR		Closed	Normal	Locked	in:1	4500-NCC NASHUA
NCC-201-2-FITNESS CENTER REAR TO TRACK DOOR	FITNESS CENTER REAR	Open	Forced	Locked	in:1	4500-NCC NASHUA
NCC-N110-MENS LOCKER ROOM DOOR	NCC MENS LOCKER ROOM	Closed	Normal	Locked	in:1	4500-NCC NASHUA
NCC-201-1-FITNESS CENTER FRONT DOOR	FITNESS CENTER FRONT	Open	Held Open	Locked	in:1	4500-NCC NASHUA
NCC-203-1-MULTI PURPOSE ROOM DOOR		Closed	Normal	Locked	in:1	4500-NCC NASHUA
NCC-N109-WOMENS LOCKER ROOM DOOR	NCC WOMENS LOCKER ROOM	Closed	Normal	Locked	in:1	4500-NCC NASHUA
NCC-240-1-TRACK ENTRANCE DOOR		Closed	Normal	Locked	in:1	4500-NCC NASHUA

NCC-FUTURE-N113-2 DOOR	Future Card access door in Kitchen recieving. Cable is coiled above the door for future card access add	Closed	Normal	Locked	in:1	4500-NCC NASHUA
NCC-N102-A-IDF DOOR	IDF CLOSET OUTSIDE WOMENS LOCKER ROOM	Closed	Normal	Locked	in:1	4500-NCC NASHUA
NCC-120-CHRISTINE GAGNON OFFICE DOOR		Closed	Normal	Locked	in:1	4500-NCC NASHUA
NCC-144-2-MACHINE SHOP ENTRANCE EXTERIOR DOOR		Closed	Normal	Locked	in:1	4500-NCC NASHUA
NCC-152-3-MAINTENANCE ENTRANCE EXTERIOR DOOR		Closed	Normal	Locked	in:1	4500-NCC NASHUA
NCC-EAST ENTRANCE EXTERIOR DOOR		Closed	Normal	Locked	in:1	4500-NCC NASHUA
NCC-123-1-CAMPUS SAFETY DOOR		Open	Held Open	Locked	in:1	4500-NCC NASHUA
NCC-156-1-ADMISSIONS ENTRANCE DOOR		Closed	Normal	Locked	in:1	4500-NCC NASHUA
NCC-MAIN ENTRANCE EXTERIOR DOOR		Open	Held Open	Locked	in:1	4500-NCC NASHUA
NCC-SOUTH SIDE ENTRANCE EXTERIOR DOOR		Closed	Normal	Locked	in:1	4500-NCC NASHUA
117-1-NCC-DR		Open	Held Open	Locked	in:1	4500-NCC NASHUA
NCC-100-1-ACADEMIC SUCCESS CENTER DOOR		Open	Held Open	Locked	in:1	4500-NCC NASHUA
NCC-93-1-AVAITION TECH DEPARTMENT DOOR		Closed	Normal	Locked	in:1	4500-NCC NASHUA
NCC-89-4-AVAITION EXTERIOR DOOR		Closed	Normal	Locked	in:1	4500-NCC NASHUA
NCC-97-1-FINANCIAL AID DOOR		Closed	Normal	Locked	in:1	4500-NCC NASHUA
NCC-99-1-ACADEMIC ADVISING CENTER DOOR		Closed	Normal	Locked	in:1	4500-NCC NASHUA
NCC-102-COMPUTER CLASSROOM DOOR		Closed	Normal	Locked	in:1	4500-NCC NASHUA
NCC-98-1-MAIL ROOM DOOR		Closed	Normal	Locked	in:1	4500-NCC NASHUA
NCC-SOUTH WEST EXTERIOR DOOR		Closed	Normal	Locked	in:1	4500-NCC NASHUA
NCC-159-3-BUSINESS OFFICE VAULT DOOR		Closed	Normal	Locked	in:1	4500-NCC NASHUA
NCC-159-1-BUSINESS OFFICE DOOR		Closed	Normal	Locked	in:1	4500-NCC NASHUA
NCC-171-1-CAD LAB DOOR		Closed	Normal	Locked	in:1	4500-NCC NASHUA
NCC-104-COMPUTER CLASSROOM DOOR		Closed	Normal	Locked	in:1	4500-NCC NASHUA
NCC-170-1-CAD LAB DOOR		Closed	Normal	Locked	in:1	4500-NCC NASHUA
NCC-218-1-MICROSCOPE LAB DOOR		Closed	Normal	Locked	in:1	4500-NCC NASHUA
NCC-220-1-COMPUTER LAB DOOR		Closed	Normal	Locked	in:1	4500-NCC NASHUA
NCC-232-1-COMPUTER LAB DOOR		Closed	Normal	Locked	in:1	4500-NCC NASHUA

NCC-233-1-CLASSROOM DOOR		Closed	Normal	Locked	in:1	4500-NCC NASHUA
NCC-307-1-COMPUTER NETWORKING DOOR		Closed	Normal	Locked	in:1	4500-NCC NASHUA
NCC-307-COMPUTER NETWORKING DOOR		Closed	Normal	Locked	in:1	4500-NCC NASHUA
NCC-310-1-COMPUTER LAB DOOR		Closed	Normal	Locked	in:1	4500-NCC NASHUA
NCC-310-2-COMPUTER LAB DOOR		Closed	Normal	Locked	in:1	4500-NCC NASHUA
NCC-130-LIBRARY ENTRANCE DOOR		Closed	Normal	Locked	in:1	4500-NCC NASHUA
N113-NCC-DR	CONTACT ONLY AT THIS TIME Kitchen Recieving Door Also as Door 8 on this panel but not prepped at door but composite cable is run to door and wired in panel to Reader 8	Closed	Normal	Locked		4500-NCC NASHUA
NCC-COURTYARD EXIT DOOR	No reader on door. Contacts and mags only	Closed	Normal	Locked		4500-NCC NASHUA
NCC-NORTH EAST ENTRANCE EXTERIOR DOOR	GLASS MAG DOORS ACROSS FROM COURTYARD DOORS	Closed	Normal	Locked		4500-NCC NASHUA
Name	Description	Open Status	Alarm State status	Mode Status	Clearance Filter Level Status	Partition Name
NHTI-GRAPPONE MAIN ENTRANCE 1 DOOR	NHTI-GRAPPONE MAIN ENTRANCE DOOR	Closed	Normal	Unlocked	in:1	6000-NHTI CONCORD
NHTI-GRAPPONE REAR ENTRANCE DOOR	NHTI-GRAPPONE REAR ENTRANCE DOOR	Closed	Normal	Unlocked	in:1	6000-NHTI CONCORD
NHTI-GRAPPONE NURSING LAB AREA DOOR	NHTI-GRAPPONE NURSING LAB AREA DOOR	Closed	Normal	Unlocked	in:1	6000-NHTI CONCORD
NHTI-GRAPPONE 133 CLASSROOM DOOR	NHTI-GRAPPONE 133 CLASSROOM DOOR	Closed	Normal	Locked	in:1	6000-NHTI CONCORD
NHTI-GRAPPONE 136 NURSING SKILLS LAB DOOR	NHTI-GRAPPONE 136 NURSING SKILLS LAB DOOR	Closed	Normal	Locked	in:1	6000-NHTI CONCORD
NHTI-GRAPPONE 218 COMPUTER LAB DOOR	NHTI-GRAPPONE 218 COMPUTER LAB DOOR	Closed	Normal	Locked	in:1	6000-NHTI CONCORD
NHTI-FARNUM F103 NETWORKING DOOR	NHTI-FARNUM F103 NETWORKING DOOR	Closed	Normal	Locked	in:1	6000-NHTI CONCORD
NHTI-FARNUM MAIN ENTRANCE DOOR	NHTI-FARNUM MAIN ENTRANCE DOOR	Closed	Normal	Unlocked	in:1	6000-NHTI CONCORD
NHTI-SWEENEY MAIN ENTRANCE DOOR	NHTI-SWEENEY MAIN ENTRANCE DOOR	Closed	Normal	Unlocked	in:1	6000-NHTI CONCORD
NHTI-SWEENEY BISTRO EMPLOYEE ENTRANCE DOOR	NHTI-SWEENEY BISTRO EMPLOYEE ENTRANCE DOOR	Closed	Normal	Locked	in:1	6000-NHTI CONCORD
NHTI-LIBRARY BOOK STORE ENTRANCE DOOR	NHTI-LIBRARY BOOK STORE ENTRANCE DOOR	Closed	Normal	Locked	in:1	6000-NHTI CONCORD
NHTI-LIBRARY SHIPPING/RECIEVING DOOR	NHTI-LIBRARY SHIPPING/RECIEVING DOOR	Closed	Normal	Locked	in:1	6000-NHTI CONCORD
NHTI-LIBRARY REAR DOOR	NHTI-LIBRARY REAR DOOR	Closed	Normal	Locked	in:1 / out:1	6000-NHTI CONCORD
NHTI-MAINTENANCE ENTRANCE DOOR	NHTI-MAINTENANCE ENTRANCE DOOR	Closed	Normal	Unlocked	in:1	6000-NHTI CONCORD
NHTI-MACRURY 137 DENTAL COMPUTER ROOM DOOR	NHTI-MACRURY DENTAL COMPUTER ROOM DOOR	Closed	Normal	Unlocked	in:1	6000-NHTI CONCORD

NHTI-MACRURY QUAD ENTRANCE DOOR	NHTI-MACRURY QUAD ENTRANCE DOOR DENTAL ANNEX	Closed	Normal	Unlocked	in:1	6000-NHTI CONCORD
NHTI-MACRURY MAIN ENTRANCE DOOR	Faces Farnum Hall	Closed	Normal	Unlocked	in:1	6000-NHTI CONCORD
NHTI-MACRURY REAR ENTRANCE DOOR	NHTI-MACRURY REAR ENTRANCE DOOR	Closed	Normal	Unlocked	in:1	6000-NHTI CONCORD
NHTI-MACRURY M113 LIBRARY DOOR	NHTI-MACRURY M113 LIBRARY DOOR	Closed	Normal	Locked	in:1	6000-NHTI CONCORD
NHTI-MACRURY M208 COMPUTER LAB DOOR	NHTI-MACRURY M208 COMPUTER LAB DOOR	Closed	Normal	Locked	in:1	6000-NHTI CONCORD
NHTI-MACRURY M201 PARAMEDIC SUITE DOOR	NHTI-MACRURY M201 PARAMEDIC SUITE DOOR	Closed	Normal	Locked	in:1	6000-NHTI CONCORD
NHTI-MACRURY M201C PARAMEDIC AMBULANCE DOOR	NHTI-MACRURY M201C PARAMEDIC AMBULANCE DOOR	Closed	Normal	Locked	in:1	6000-NHTI CONCORD
NHTI-MACRURY M201D PARAMEDIC BREAKOUT DOOR	NHTI-MACRURY M201D PARAMEDIC BREAKOUT DOOR	Closed	Normal	Locked	in:1	6000-NHTI CONCORD
NHTI- LANGLEY HALL A WING 1ST FLOOR INTERIOR DOOR	NHTI- LANGLEY HALL A WING 1ST FLOOR INTERIOR DOOR O THE LANGLEY MAIN RESIDENT LOBBY.	Open	Normal	Unlocked	in:1 / out:1	6000-NHTI CONCORD
NHTI- LANGLEY HALL A WING EXTERIOR DOOR	NHTI- LANGLEY HALL A WING EXTERIOR DOOR	Closed	Normal	Locked	in:1	6000-NHTI CONCORD
NHTI- LANGLEY HALL MAIN LOBBY DOOR	NHTI- LANGLEY HALL MAIN LOBBY DOOR	Open	Held Open	Locked	in:1 / out:1	6000-NHTI CONCORD
NHTI- LANGLEY HALL B WING EXTERIOR DOOR	NHTI- LANGLEY HALL B WING EXTERIOR DOOR	Closed	Normal	Locked	in:1	6000-NHTI CONCORD
NHTI- LANGLEY HALL C WING EXTERIOR DOOR	NHTI-LANGLEY HALL C WING EXTERIOR DOOR	Closed	Normal	Locked	in:1	6000-NHTI CONCORD
NHTI- LANGLEY HALL BOILER ROOM EXTERIOR DOOR	NHTI- LANGLEY HALL BOILER ROOM EXTERIOR DOOR	Closed	Normal	Locked	in:1	6000-NHTI CONCORD
NHTI-SOUTH HALL EAST DOOR	NHTI-SOUTH HALL EASTDOOR	Closed	Normal	Locked	in:1	6000-NHTI CONCORD
NHTI-SOUTH HALL WEST DOOR	NHTI-SOUTH HALL WEST DOOR	Closed	Normal	Locked	in:1 / out:1	6000-NHTI CONCORD
NHTI-SOUTH HALL FRONT DOOR	NHTI-SOUTH HALL FRONT DOOR	Closed	Normal	Locked	in:1 / out:1	6000-NHTI CONCORD
NHTI-SOUTH HALL ELECTRICAL DOOR	NHTI-SOUTH HALL ELECTRICAL DOOR	Closed	Normal	Locked	in:1	6000-NHTI CONCORD
NHTI-LITTLE HALL SLIDER TO CAPITAL COMMONS DOOR	NHTI-LITTLE HALL SLIDER TO CAPITAL COMMONS DOOR	Closed	Normal	Unlocked	in:1	6000-NHTI CONCORD
NHTI-LITTLE HALL SLIDER TO STREET DOOR	NHTI-LITTLE HALL SLIDER TO STREET DOOR	Closed	Normal	Unlocked	in:1	6000-NHTI CONCORD
NHTI-LITTLE HALL L112 CLASSROOM DOOR	NHTI-LITTLE HALL L112 CLASSROOM DOOR	Closed	Normal	Locked	in:1	6000-NHTI CONCORD
NHTI-LITTLE HALL L128 CLASSROOM DOOR	NHTI-LITTLE HALL L128 CLASSROOM DOOR	Closed	Normal	Locked	in:1	6000-NHTI CONCORD
NHTI-LITTLE HALL L204 CLASSROOM DOOR	NHTI-LITTLE HALL L204 CLASSROOM DOOR	Closed	Normal	Locked	in:1	6000-NHTI CONCORD
NHTI-LITTLE HALL L231 CLASSROOM DOOR	NHTI-LITTLE HALL L231 CLASSROOM DOOR	Closed	Normal	Locked	in:1	6000-NHTI CONCORD
NHTI-CAPITAL COMMONS DATA CLOSET DOOR	NHTI-CAPITAL COMMONS DATA CLOSET DOOR	Closed	Normal	Locked	in:1	6000-NHTI CONCORD
NHTI-CAPITAL COMMONS MANAGERS OFFICE DOOR	NHTI-CAPITAL COMMONS MANAGERS OFFICE DOOR	Open	Held Open	Locked	in:1	6000-NHTI CONCORD

NHTI-CAPITAL COMMONS RECIEVING DOOR	NHTI-CAPITAL COMMONS RECIEVING DOOR	Open	Held Open	Locked	in:1	6000-NHTI CONCORD
NHTI-WELLNESS CENTER FITNESS ROOM DOOR	NHTI-WELLNESS CENTER FITNESS ROOM DOOR	Closed	Normal	Locked	in:1	6000-NHTI CONCORD
NHTI-STUDENT CENTER ENTRANCE DOOR	NHTI-STUDENT CENTER ENTRANCE DOOR	Closed	Normal	Unlocked	in:1	6000-NHTI CONCORD
NHTI-WELLNESS CENTER ENTRANCE DOOR	NHTI-WELNESS CENTER ENTRANCE DOOR	Closed	Normal	Unlocked	in:1	6000-NHTI CONCORD
NHTI-STUDENT CENTER AFFAIR DOOR	NHTI-STUDENT CENTER AFFAIR DOOR	Closed	Normal	Locked	in:1	6000-NHTI CONCORD
NHTI-WELLNESS CENTER ACTIVITY IN/OUT	NHTI-WELLNESS CENTER ACTIVITY IN/OUT	Closed	Normal	Locked	in:1 / out:1	6000-NHTI CONCORD
NHTI-WELLNESS CENTER OFFICE DOOR	NHTI-WELLNESS CENTER OFFICE DOOR	Closed	Normal	Locked	in:1	6000-NHTI CONCORD
NHTI-GRAPPONE MAIN ENTRANCE 2 DOOR		Closed	Normal	Unlocked		6000-NHTI CONCORD
NHTI-SWEENEY REAR ENTRANCE DOOR		Closed	Normal	Unlocked	in:1	6000-NHTI CONCORD
NHTI-STROUT HALL EAST DOOR	NHTI-STROUT HALL EAST DOOR	Closed	Normal	Locked	in:1 / out:1	6000-NHTI CONCORD
NHTI-STROUT HALL WEST DOOR	NHTI-STROUT HALL WEST DOOR	Closed	Normal	Locked	in:1 / out:1	6000-NHTI CONCORD
NHTI-STROUT HALL FRONT DOOR	NHTI-STROUT HALL FRONT DOOR	Closed	Normal	Locked	in:1 / out:1	6000-NHTI CONCORD
NHTI-CFDC MAIN ENTRANCE DOOR	NHTI-CFDC MAIN ENTRANCE DOOR	Open	Held Open	Locked	in:1	6500-NHTI CFDC
NHTI- LANGLEY HALL A WING 2ND FLOOR HALL DOOR		Closed	Normal	Unlocked	in:1	6000-NHTI CONCORD
NHTI- LANGLEY HALL A WING 1ST FLOOR HALL DOOR		Closed	Normal	Unlocked	in:1	6000-NHTI CONCORD
7000-CO-SERVER ROOM FRONT DOOR		Closed	Normal	Locked	in:1	7000-CO
7000-CO-SERVER ROOM REAR DOOR		Closed	Normal	Locked	in:1	7000-CO
7000-CO-BACK ENTRANCE DOOR		Closed	Normal	Locked	in:1	7000-CO
7000-CO-FRONT ENTRANCE DOOR		Closed	Normal	Locked	in:1	7000-CO
7000-CO-CHECK PRINTER DOOR		Closed	Normal	Locked	in:1	7000-CO
7000-CO-MIDDLE DOOR		Open	Held Open	Locked	in:1	7000-CO
NHTI-LIBRARY EXTERIOR MAIN ENTRANCE DOOR		Closed	Normal	Unlocked	in:1	6000-NHTI CONCORD
NHTI-LIBRARY INTERIOR MAIN ENTRANCE DOOR		Closed	Normal	Unlocked	in:1	6000-NHTI CONCORD
NHTI-FARNUM REAR ENTRANCE DOOR		Closed	Normal	Locked		6000-NHTI CONCORD
NHTI-CFDC -TODDLER EAST EXIT DOOR		Closed	Normal	Locked		6500-NHTI CFDC
NHTI-CFDC -INFANT EAST EXIT DOOR		Closed	Normal	Locked		6500-NHTI CFDC
NHTI-CFDC -WEST CORRIDOR EXIT DOOR		Closed	Normal	Locked		6500-NHTI CFDC
NHTI-CFDC -PRESCHOOL WEST EXIT DOOR		Open	Forced	Locked		6500-NHTI CFDC

NHTI-CFDC -PRESCHOOL SOUTH EXIT DOOR		Closed	Normal	Locked		6500-NHTI CFDC
NHTI-CFDC - KINDERGARTEN EAST EXIT DOOR		Closed	Normal	Locked		6500-NHTI CFDC
NHTI-CAPITAL COMMONS SOUTHEAST DINING DOOR		Closed	Normal	Locked		6000-NHTI CONCORD
NHTI-CAPITAL COMMONS SOUTHWEST DINING DOOR		Closed	Normal	Locked		6000-NHTI CONCORD
NHTI-CAPITAL COMMONS CAFE TO PATIO DOOR		Closed	Normal	Locked		6000-NHTI CONCORD
NHTI-CAPITAL COMMONS SERVERY EXTERIOR DOOR		Closed	Normal	Locked		6000-NHTI CONCORD
NHTI-SWEENEY-BISTRO LOADING ENTRANCE		Closed	Normal	Locked		6000-NHTI CONCORD
NHTI-SWEENEY-BISTRO EXTERIOR ENTRANCE		Closed	Normal	Locked		6000-NHTI CONCORD
NHTI-SWEENEY-BISTRO FOYER ENTRANCE		Closed	Normal	Locked		6000-NHTI CONCORD
NHTI-MACRURY-LOBBY ENTRANCE	DENTAL PATIENT LOBBY	Closed	Normal	Unlocked	in:1	6000-NHTI CONCORD
NHTI-SWEENEY S301 OFFICE DOOR		Closed	Normal	Locked	in:1	6000-NHTI CONCORD
NHTI-SWEENEY S318 IT CLASSROOM DOOR		Closed	Normal	Locked	in:1	6000-NHTI CONCORD
NHTI-SWEENEY S308 CISCO LAB DOOR		Closed	Normal	Locked	in:1	6000-NHTI CONCORD
NHTI-SWEENEY S309 CISCO LAB CLASSROOM DOOR		Closed	Normal	Locked	in:1	6000-NHTI CONCORD
NHTI-SWEENEY S306 DH OFFICE DOOR		Closed	Normal	Locked	in:1	6000-NHTI CONCORD
NHTI-SWEENEY S307 FACULTY OFFICE DOOR		Closed	Normal	Locked	in:1	6000-NHTI CONCORD
NHTI-FARNUM F104 FACULTY ADJUNCT DOOR		Closed	Normal	Locked	in:1	6000-NHTI CONCORD
NHTI-CAMPUS SAFTY ENTRANCE DOOR		Closed	Normal	Unlocked	in:1	6000-NHTI CONCORD
NHTI-SWEENEY S131 FIRE ALARM ROOM DOOR		Closed	Normal	Locked	in:1	6000-NHTI CONCORD
NHTI-SWEENEY S220A IT ROOM DOOR		Closed	Normal	Locked	in:1	6000-NHTI CONCORD
NHTI-SWEENEY PLANETARIUM DOUBLE DOOR		Closed	Normal	Locked		6000-NHTI CONCORD
NHTI-LITTLE HALL REAR DOUBLE DOOR		Closed	Normal	Locked		6000-NHTI CONCORD
NHTI-CAPITAL COMMONS DINING SLIDER DOOR		Closed	Normal	Unlocked		6000-NHTI CONCORD
NHTI-MACRURY SIDE ENTRANCE DOOR		Closed	Normal	Unlocked		6000-NHTI CONCORD
NHTI- LANGLEY HALL A WING 2ND FLOOR INTERIOR DOOR	NHTI- LANGLEY HALL A WING 2ND FLOOR INTERIOR DOOR	Closed	Normal	Unlocked	in:1 / out:1	6000-NHTI CONCORD

Name	Description	Open Status	Alarm State status	Mode Status	Clearance Filter Level Status	Partition Name
RVCC CLAREMONT-1ST FLOOR HANDICAP RESTROOM TO MAIN HALL DOOR	RVCC CLAREMONT-1ST FLOOR HANDICAP RESTROOM TO MAIN HALL DOOR	Open	Held Open	Locked	in:1	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC CLAREMONT-1ST FLOOR LIBRARY TO LEARNING CENTER DOOR	RVCC CLAREMONT-1ST FLOOR LIBRARY TO LEARNING CENTER DOOR	Closed	Normal	Unlocked	in:1	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC CLAREMONT-1ST FLOOR 100J LEARNING CENTER DOOR	RVCC CLAREMONT-1ST FLOOR 100J LEARNING CENTER DOOR	Closed	Normal	Unlocked	in:1	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC CLAREMONT-1ST FLOOR EXT FALCON DOOR	RVCC CLAREMONT-1ST FLOOR EXT FALCON DOOR	Closed	Normal	Locked	in:1	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC KEENE-1ST FLOOR FRONT ENTRANCE DOOR	RVCC KEENE-1ST FLOOR FRONT ENTRANCE DOOR	Closed	Normal	Locked	in:1	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC KEENE-1ST FLOOR REAR ENTRANCE DOOR	RVCC KEENE-1ST FLOOR REAR ENTRANCE DOOR	Closed	Normal	Locked	in:1	2000-RVCC CLAREMONT/KEENE/LEBANON
2006-RVCC-CFO OFFICE		Closed	Normal	Locked	in:1	2000-RVCC CLAREMONT/KEENE/LEBANON
2007-RVCC-TEL-DATA CLOSET		Closed	Normal	Locked	in:1	2000-RVCC CLAREMONT/KEENE/LEBANON
2014-RVCC-ROOM 238		Closed	Normal	Locked	in:1	2000-RVCC CLAREMONT/KEENE/LEBANON
2015-RVCC-PRESIDENTS OFFICE (RM 242)		Closed	Normal	Locked	in:1	2000-RVCC CLAREMONT/KEENE/LEBANON
2009--RVCC-CLASSROOM 145		Closed	Normal	Locked	in:1	2000-RVCC CLAREMONT/KEENE/LEBANON
2010--RVCC-CLASSROOM 146		Closed	Normal	Locked	in:1	2000-RVCC CLAREMONT/KEENE/LEBANON
2011--RVCC-CLASSROOM 147		Closed	Normal	Locked	in:1	2000-RVCC CLAREMONT/KEENE/LEBANON
2012--RVCC-CLASSROOM 151		Closed	Normal	Locked	in:1	2000-RVCC CLAREMONT/KEENE/LEBANON
2013--RVCC-CLASSROOM 153		Closed	Normal	Locked	in:1	2000-RVCC CLAREMONT/KEENE/LEBANON

RVCC CLAREMONT-1ST FLOOR EMPLOYEE/STUDENT ENTRANCE DOOR		Closed	Normal	Locked	in:1	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC LEBANON 1ST FL EMPLOYEE ENTRANCE DOOR	RVCC LEBANON 1ST FL EMPLOYEE ENTRANCE DOOR	Closed	Normal	Locked	in:1	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC LEBANON 121 MAIL ROOM DOOR	RVCC LEBANON 121 MAIL ROOM DOOR	Closed	Normal	Locked	in:1	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC LEBANON 114 IT OFFICE DOOR	RVCC LEBANON 114 IT OFFICE DOOR	Closed	Normal	Locked	in:1	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC LEBANON 112 CLASSROOM DOOR	RVCC LEBANON 112 CLASSROOM DOOR	Closed	Normal	Locked	in:1	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC LEBANON 110 CLASSROOM DOOR	RVCC LEBANON 110 CLASSROOM DOOR	Closed	Normal	Locked	in:1	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC LEBANON 109 CLASSROOM DOOR	RVCC LEBANON 109 CLASSROOM DOOR	Closed	Normal	Locked	in:1	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC LEBANON 2ND FL REAR ENTRANCE DOOR	RVCC LEBANON 2ND FL REAR ENTRANCE DOOR	Closed	Normal	Locked	in:1	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC LEBANON 2ND FL FRONT ENTRANCE DOOR	RVCC LEBANON 2ND FL FRONT ENTRANCE DOOR	Closed	Normal	Locked	in:1	2000-RVCC CLAREMONT/KEENE/LEBANON
2016--RVCC-CLASSROOM 130		Closed	Normal	Locked	in:1	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC CLAREMONT-1ST FLOOR MAIN ENTRANCE DOOR		Closed	Normal	Locked	in:1	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC CLAREMONT-KITCHEN EXTERIOR		Closed	Normal	Locked	in:1	2000-RVCC CLAREMONT/KEENE/LEBANON
Name	Description	Open Status	Alarm State status	Mode Status	Clearance Filter Level Status	Partition Name
WMCC-MAIN DOOR		Closed	Normal	Unlocked	in:1	5000-WMCC BERLIN
WMCC-SIDE STAIRWELL DOOR		Closed	Normal	Unlocked	in:1	5000-WMCC BERLIN
WMCC-BACK STAIRWELL DOOR		Closed	Normal	Unlocked	in:1	5000-WMCC BERLIN
WMCC-WELLNESS CENTER DOOR		Closed	Normal	Unlocked	in:1	5000-WMCC BERLIN

I Star Panel summary					
Name	Description	Controller Name	Online Status	Certificate signing	Partition Name
CO-SERVER ROOM-ISTAR		iSTAR Classic/Pro	Online	Unknown	7000-CO
Name	Description	Controller Name	Online Status	Certificate signing status	Partition Name
GBCC-STUDENT CENTER ISTAR	8 DOOR ISTAR LOCATED IN GYM IDF	iSTAR Classic/Pro	Online	Unknown	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-DATA CENTER ISTAR		iSTAR Classic/Pro	Online	Unknown	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC ROCHESTER DATA CLOSET ISTAR EDGE 1		iSTAR Edge	Online	Unknown	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-1ST FL IDF NE151 ISTAR		iSTAR Ultra Encrypted	Online	Unknown	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC ROCHESTER DATA CLOSET ISTAR EDGE 2		iSTAR Edge	Online	Unknown	4000-GBCC PORTSMOUTH/ROCHESTER
Name	Description	Controller Name	Online Status	Certificate signing status	Partition Name
LRCC-iSTAR01-CAT BUILDING		iSTAR Classic/Pro	Online		1000-LRCC LACONIA
LRCC-iSTAR02-CAT BUILDING		iSTAR Classic/Pro	Online		1000-LRCC LACONIA
LRCC-iSTAR03-CAT BUILDING		iSTAR Classic/Pro	Online		1000-LRCC LACONIA
LRCC-iSTAR04-CAT BUILDING		iSTAR Classic/Pro	Online		1000-LRCC LACONIA
LRCC-iSTAR01-TURNER BUILDING		iSTAR Classic/Pro	Online		1000-LRCC LACONIA
LRCC- AUTOMOTIVE ISTAR		iSTAR Classic/Pro	Online		1000-LRCC LACONIA
Name	Description	Controller Name	Online Status	Certificate signing status	Partition Name
MCC-2 CENTRAL WING IDF-ISTAR	IDF AND PANEL LOCATED IN 238 CLASSROOM	iSTAR Classic/Pro	Online	Unknown	3000-MCC MANCHESTER
MCC-HSCI 3RD FL-ISTAR		iSTAR Classic/Pro	Online	Unknown	3000-MCC MANCHESTER
MCC-HSCI 2ND FL-ISTAR	MCC-HSCI 2ND FL-ISTAR LOCATED IN HSCI HALL IN 2ND FLOOR IN IDF CLOSET	iSTAR Classic/Pro	Online	Unknown	3000-MCC MANCHESTER
MCC-STUDENT CENTER ONE STOP-ISTAR EDGE	MCC-STUDENT CENTER ONE STOP-ISTAR EDGE	iSTAR Edge	Online	Unknown	3000-MCC MANCHESTER
MCC-NORTH WING 1ST FL IDF-ISTAR 1	MCC-B BUILDING 1ST FL IDF-ISTAR 1	iSTAR Classic/Pro	Online	Unknown	3000-MCC MANCHESTER
MCC-NORTH WING 1ST FL IDF-ISTAR 2	MCC-B BUILDING 1ST FL IDF-ISTAR 2	iSTAR Classic/Pro	Online	Unknown	3000-MCC MANCHESTER
MCC-STUDENT CENTER GYM IDF-ISTAR EDGE	MCC-STUDENT CENTER GYM IDF-ISTAR EDGE	iSTAR Edge	Online	Unknown	3000-MCC MANCHESTER
MCC-CENTRAL WING 1ST FL TELEDATA-ISTAR	MCC-KNOX 1ST FL TELEDATA-ISTAR	iSTAR Classic/Pro	Online	Unknown	3000-MCC MANCHESTER
MCC-SERVER ROOM EDGE		iSTAR Edge	Online	Unknown	3000-MCC MANCHESTER
MCC-STUDENT CENTER GYM IDF-ISTAR EDGE 2		iSTAR Edge	Online	Unknown	3000-MCC MANCHESTER
MCC-AUTO TECH BUILDING-ISTAR		iSTAR Classic/Pro	Online	Unknown	3000-MCC MANCHESTER
MCC-ADVANCED TECH BUILDING-ISTAR 1	LOCATED IN THE HVAC BUILDING IN THE IDF ROOM ON THE LOWER LEVEL	iSTAR Classic/Pro	Online	Unknown	3000-MCC MANCHESTER
MCC-STUDENT CENTER ONE STOP-ISTAR EDGE 2		iSTAR Edge	Online	Unknown	3000-MCC MANCHESTER
Name	Description	Controller Name	Online Status	Certificate signing status	Partition Name
NCC-NASHUA 3RD FLOOR HSH EDGE 1	PANEL LOCATED IN IDF CLOSET BUILDING H ON 3RD FLOOR	iSTAR Edge	Online	Unknown	4500-NCC NASHUA
NCC-NASHUA 3RD FLOOR HSH EDGE 2	PANEL LOCATED IN IDF CLOSET BUILDING H ON 3RD FLOOR	iSTAR Edge	Online	Unknown	4500-NCC NASHUA
NCC-NASHUA 2ND FLOOR HSH	PANEL LOCATED IN IDF BULDING H	iSTAR Classic/Pro	Online	Unknown	4500-NCC NASHUA
NCC-NASHUA 1ST FLOOR AUTO EXT	PANEL LOCATED IN IDF CLOSET NEXT TO AUTOMOTIVE	iSTAR Classic/Pro	Online	Unknown	4500-NCC NASHUA
NCC-NASHUA 1ST FLOOR MAIN IDF	PANEL LOCATED IN IMAIN IDF ROOM 101	iSTAR Classic/Pro	Online	Unknown	4500-NCC NASHUA
NCC-NASHUA 1ST FLOOR LIBRARY 132A	PANEL LOCATED IN IDF CLOSET IN LIBRARY COMPUTER LAB	iSTAR Classic/Pro	Online	Unknown	4500-NCC NASHUA
NCC-NASHUA 1ST FLOOR WOMENS LOCKER RM	PANEL LOCATED IN IDF CLOSET NEXT TO WOMENS LOCKER ROOM BY BASKETBALL COURTS	iSTAR Classic/Pro	Online	Unknown	4500-NCC NASHUA
NCC-NASHUA 2ND FLOOR LAB STORAGE	LOCATED IN LAB STORAGE ROOM ON 2NF FLOOR IN STORAGE ROOM BETWEEN RM 218 AND RM 220	iSTAR Classic/Pro	Online	Unknown	4500-NCC NASHUA

Name	Description	Controller Name		Certificate signing status	Partition Name
NHTI-GRAPPONE 113 MDF TELE/DATA ISTAR		iSTAR Classic/Pro			6000-NHTI CONCORD
NHTI-FARNUM 108 ISTAR EDGE		iSTAR Edge			6000-NHTI CONCORD
NHTI-STUDENT CENTER-ISTAR		iSTAR Classic/Pro			6000-NHTI CONCORD
NHTI-SWEENEY-2ND FL ISTAR EDGE	IN ROOM S220A	iSTAR Edge			6000-NHTI CONCORD
NHTI-LIBRARY-ISTAR		iSTAR Classic/Pro			6000-NHTI CONCORD
NHTI-MAINTENANCE-ISTAR EDGE		iSTAR Edge			6000-NHTI CONCORD
NHTI-MACRURY DATA ROOM 141-ISTAR EDGE #1		iSTAR Edge			6000-NHTI CONCORD
NHTI-MACRURY 2ND FLOOR-ISTAR		iSTAR Classic/Pro			6000-NHTI CONCORD
NHTI-LANGLEY HALL-ISTAR		iSTAR Classic/Pro			6000-NHTI CONCORD
NHTI-SOUTH HALL-ISTAR		iSTAR Classic/Pro			6000-NHTI CONCORD
NHTI-LITTLE HALL 1ST FLOOR-ISTAR EDGE		iSTAR Edge			6000-NHTI CONCORD
NHTI-LITTLE HALL 2ND FLOOR-ISTAR EDGE		iSTAR Edge			6000-NHTI CONCORD
NHTI-CHILDHOOD-ISTAR EDGE		iSTAR Edge			6000-NHTI CONCORD
NHTI-CAPITAL COMMONS-ISTAR EDGE		iSTAR Edge			6000-NHTI CONCORD
NHTI-STROUT HALL ISTAR		iSTAR Classic/Pro			6000-NHTI CONCORD
NHTI-CFDC ISTAR EDGE	NHTI-CFDC ISTAR EDGE	iSTAR Edge			6500-NHTI CFDC
CO-SERVER ROOM-ISTAR		iSTAR Classic/Pro			7000-CO
NHTI-MACRURY DATA ROOM 141-ISTAR EDGE #2		iSTAR Edge			6000-NHTI CONCORD
NHTI-SWEENEY 3RD FLOOR-ISTAR		iSTAR Ultra Encrypted			6000-NHTI CONCORD
NHTI-CAMPUS SAFTY-ISTAR EDGE		iSTAR Edge			6000-NHTI CONCORD
NHTI-SWEENEY 1ST FL ISTAR EDGE		iSTAR Edge			6000-NHTI CONCORD
NHTI-SWEENEY-2ND FL ISTAR EDGE 2		iSTAR Edge			6000-NHTI CONCORD
Name	Description	Controller Name	Online Status	Certificate signing status	Partition Name
RVCC CLAREMONT ISTAR01-1ST FLOOR SERVER ROOM	RVCC CLAREMONT ISTAR01-1ST FLOOR SERVER ROOM	iSTAR Classic/Pro	Online	Unknown	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC KEENE ISTAR EDGE01-1ST FLOOR SERVER ROOM		iSTAR Edge	Online	Unknown	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC LEBANON ISTAR		iSTAR Classic/Pro	Online	Unknown	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC CLAREMONT ISTAR 2	1 DOOR ISTAR	iSTAR Edge	Online	Unknown	2000-RVCC CLAREMONT/KEENE/LEBANON
Name	Description	Controller Name	Online Status	Certificate signing status	Partition Name
WMCC-iSTAR EDGE		iSTAR Edge	Online	Unknown	5000-WMCC BERLIN

Input Report Summary				
Name	Description	Armed status	Active Status	Partition Name
7000-CO-SERVER ROOM FRONT-DSM		Armed	Inactive	7000-CO
7000-CO-SERVER ROOM FRONT-REX		Armed	Update Disabled	7000-CO
7000-CO-SERVER ROOM REAR-DSM		Armed	Inactive	7000-CO
7000-CO-SERVER ROOM REAR-REX		Armed	Update Disabled	7000-CO
7000-CO-BACK ENTRANCE-DSM		Armed	Inactive	7000-CO
7000-CO-BACK ENTRANCE-REX		Armed	Update Disabled	7000-CO
7000-CO-FRONT ENTRANCE-DSM		Armed	Inactive	7000-CO
7000-CO-FRONT ENTRANCE-REX		Armed	Update Disabled	7000-CO
7000-CO-CHECK PRINTER-DSM		Armed	Inactive	7000-CO
7000-CO-CHECK PRINTER-REX		Armed	Update Disabled	7000-CO
7000-CO-MIDDLE-DSM		Armed	Inactive	7000-CO
7000-CO-MIDDLE-REX		Armed	Update Disabled	7000-CO
Name	Description	Armed status	Active Status	Partition Name
GBCC-STUDENT CENTER REAR ENT-DSM		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-STUDENT CENTER REAR ENT-REX		Armed	Update Disabled	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-STUDENT CENTER GYM ENT-DSM		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-STUDENT CENTER GYM ENT-REX		Armed	Update Disabled	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-STUDENT CENTER HALLWALL EXIT--DSM		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-STUDENT CENTER HALLWALL ENT--DSM		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-STUDENT CENTER GREEN BEAN REAR ENT-DSM		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-STUDENT CENTER GREEN BEAN REAR ENT-REX		Armed	Update Disabled	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-STUDENT CENTER MAIN ENT-DSM		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-STUDENT CENTER MAIN ENT-REX		Armed	Update Disabled	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-STUDENT CENTER FITNESS CENTER ENT-DSM		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-STUDENT CENTER FITNESS CENTER ENT-REX		Armed	Update Disabled	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-DATA CENTER-DSM		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-LOADING DOCK-DSM		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-LOADING DOCK-REX		Armed	Update Disabled	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-NORTH ENTRANCE-DSM		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-NORTH ENTRANCE-REX		Armed	Update Disabled	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-MAIN ENT-DSM		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-MAIN ENT-REX		Armed	Update Disabled	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-BUSINESS ENT-DSM		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-BUSINESS ENT-REX		Armed	Update Disabled	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-VET TECH ENT-DSM		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-VET TECH ENT-REX		Armed	Update Disabled	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-STUDENT CENTER GYM RIGHT-DSM		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-STUDENT CENTER GYM RIGHT-REX		Armed	Update Disabled	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-STUDENT CENTER ROOM 95-DSM		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-STUDENT CENTER ROOM 95-REX		Armed	Update Disabled	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-STUDENT CENTER ROOM 96-DSM		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-STUDENT CENTER ROOM 96-REX		Armed	Update Disabled	4000-GBCC PORTSMOUTH/ROCHESTER
iSTAR Input7-4000-GBCC ROCHESTER Administration Lock Down		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
iSTAR Input8-4000-GBCC ROCHESTER Front Desk Lock down		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
Power Failure-GBCC-DATA CENTER ISTAR		Armed	Active	4000-GBCC PORTSMOUTH/ROCHESTER
External Battery Low-GBCC-DATA CENTER ISTAR		Armed	Active	4000-GBCC PORTSMOUTH/ROCHESTER
Power Failure-GBCC-STUDENT CENTER ISTAR		Armed	Active	4000-GBCC PORTSMOUTH/ROCHESTER
External Battery Low-GBCC-STUDENT CENTER ISTAR		Armed	Active	4000-GBCC PORTSMOUTH/ROCHESTER
Power Failure-4000-GBCC ROCHESTER DATA CLOSET ISTAR EDGE		Armed	Active	4000-GBCC PORTSMOUTH/ROCHESTER
External Battery Low-4000-GBCC ROCHESTER DATA CLOSET ISTAR EDGE		Armed	Active	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-STUDENT LIFE ASSISTANT OFFICE 85 LOCKDOWN-BTN		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
Communication Fail-GBCC-DATA CENTER ISTAR-INPUT BOARD 1		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-SECURITY DESK LOCKDOWN-BTN		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-ONE STOP OFFICE AREA LOCKDOWN-BTN		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-PRESIDENTS OFFICE AREA LOCKDOWN-BTN		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-BUSINESS AND TRAINING CENTER LOCKDOWN-BTN		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-HELP DESK/IT DEPT LOCKDOWN-BTN		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-ONE STOP-DSM		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER

GBCC-ONE STOP-REX		Armed	Update Disabled	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-CHEMESTRY LAB NE140-DSM		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-CHEMESTRY LAB NE140-REX		Armed	Update Disabled	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-LIFE SCIENCE NE141-DSM		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-LIFE SCIENCE NE141-REX		Armed	Update Disabled	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-LIFE SCIENCE NE142-DSM		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-LIFE SCIENCE NE142-REX		Armed	Update Disabled	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-LIFE SCIENCE NE143-DSM		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-LIFE SCIENCE NE143-REX		Armed	Update Disabled	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-BIO PREP NE149-DSM		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-BIO PREP NE149-REX		Armed	Update Disabled	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-BIO LAB NE149A-DSM		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-BIO LAB NE149A-REX		Armed	Update Disabled	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-BIO LAB 149C-DSM		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-BIO LAB 149C-REX		Armed	Update Disabled	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-LOADING DOCK 2-DSM		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-VET TECH NE154-DSM		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-BIOTECH EMERGENCY DOOR-CONT		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-1ST FL IDF NE151 ISTAR INPUT BOARD 1 COMM FAIL		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-NE148 MAINTENANCE-DSM		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-NE148 MAINTENANCE-REX		Armed	Update Disabled	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-LOADING DOCK 2-REX		Armed	Update Disabled	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-VET TECH NE154-REX		Armed	Update Disabled	4000-GBCC PORTSMOUTH/ROCHESTER
Power Failure-GBCC-1ST FL IDF NE151 ISTAR		Armed	Active	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-FITNESS CENTER OFFICE-DSM		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-FITNESS CENTER OFFICE-REX		Armed	Update Disabled	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-STUDENT CENTER DOOR OVER RIDE-BTN		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-DATA CENTER DOOR OVER RIDE-BTN		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-1ST FL IDF NE151 DOOR OVER RIDE-BTN		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
Power Failure-GBCC ROCHESTER DATA CLOSET ISTAR EDGE 2		Armed	Active	4000-GBCC PORTSMOUTH/ROCHESTER
External Battery Low-GBCC ROCHESTER DATA CLOSET ISTAR EDGE 2		Armed	Active	4000-GBCC PORTSMOUTH/ROCHESTER
4000-GBCC ROCHESTER WELDING LAB TO CNC LAB-DSM		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
4000-GBCC ROCHESTER WELDING LAB TO CNC LAB-REX		Armed	Update Disabled	4000-GBCC PORTSMOUTH/ROCHESTER
4000-GBCC ROCHESTER VESTIBULE 140 TO WELDING LAB-DSM		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
4000-GBCC ROCHESTER VESTIBULE 140 TO WELDING LAB-REX		Armed	Update Disabled	4000-GBCC PORTSMOUTH/ROCHESTER
4000-GBCC ROCHESTER VESTIBULE 140 TO CNC LAB-DSM		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
4000-GBCC ROCHESTER VESTIBULE 140 TO CNC LAB-REX		Armed	Update Disabled	4000-GBCC PORTSMOUTH/ROCHESTER
iSTAR Input3-4000-GBCC ROCHESTER Main Entrance Intercom Release		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
Name	Description	Armed status	Active Status	Partition Name
1001-iSTAR01/ACM1/I01/LRCC-TURNER-DOOR1-DMS		Armed	Inactive	1000-LRCC LACONIA
1002-iSTAR01/ACM1/I02/LRCC-TURNER-DOOR2-DSM		Armed	Inactive	1000-LRCC LACONIA
1003-iSTAR01/ACM1/I03/LRCC-TURNER-DOOR3-DSM		Armed	Inactive	1000-LRCC LACONIA
1004-iSTAR01/ACM1/I04/LRCC-TURNER-DOOR4-DSM		Armed	Inactive	1000-LRCC LACONIA
1005-iSTAR01/ACM1/I05/LRCC-TURNER-DOOR5-DSM		Armed	Inactive	1000-LRCC LACONIA
1001-iSTAR01/ACM1/I09/LRCC-TURNER-DOOR1-REX		Armed	Update Disabled	1000-LRCC LACONIA
1002-iSTAR01/ACM1/I10/LRCC-TURNER-DOOR2-REX		Armed	Update Disabled	1000-LRCC LACONIA
1003-iSTAR01/ACM1/I11/LRCC-TURNER-DOOR3-REX		Armed	Update Disabled	1000-LRCC LACONIA
1004-iSTAR01/ACM1/I12/LRCC-TURNER-DOOR4-REX		Armed	Update Disabled	1000-LRCC LACONIA
1005-iSTAR01/ACM1/I13/LRCC-TURNER-DOOR5-REX		Armed	Update Disabled	1000-LRCC LACONIA
1008-iSTAR01/ACM1/R08I1/LRCC-CAT-DOOR8-DSM		Armed	Inactive	1000-LRCC LACONIA
1008-iSTAR01/ACM1/R08I2/LRCC-CAT-DOOR8-REX		Armed	Update Disabled	1000-LRCC LACONIA
1007-iSTAR01/ACM1/R07I1/LRCC-CAT-DOOR7-DSM		Armed	Inactive	1000-LRCC LACONIA
1007-iSTAR01/ACM1/R07I2/LRCC-CAT-DOOR7-REX		Armed	Update Disabled	1000-LRCC LACONIA
1130-iSTAR01/1I01-LR CAT-G-IT CLOSET-DSM		Armed	Inactive	1000-LRCC LACONIA
1135-iSTAR01/1I02-LR CAT-G-CLASSROOM-DSM		Armed	Inactive	1000-LRCC LACONIA
1136-iSTAR01/1I03-LR CAT-G-NURSE FAC-DSM		Armed	Inactive	1000-LRCC LACONIA
1137-iSTAR01/1I04-LR CAT-G-NURSE FAC-DSM		Armed	Inactive	1000-LRCC LACONIA
1138-iSTAR01/1I05-LR CAT-G-NURSE FAC-DSM		Armed	Inactive	1000-LRCC LACONIA
1140-iSTAR01/1I06-LRCC-CAT-G-ANTE/COPY-DSM		Armed	Inactive	1000-LRCC LACONIA

1130-iSTAR01/1I09-LR CAT-G-IT CLOSET-REX		Armed	Update Disabled	1000-LRCC LACONIA
1135-iSTAR01/1I10-LR CAT-G-CLASSROOM-REX		Armed	Update Disabled	1000-LRCC LACONIA
1136-iSTAR01/1I11-LR CAT-G-NURSE FAC-REX		Armed	Update Disabled	1000-LRCC LACONIA
1138-iSTAR01/1I13-LR CAT-G-NURSE FAC-REX		Armed	Update Disabled	1000-LRCC LACONIA
1137-iSTAR01/1I12-LR CAT-G-NURSE FAC-REX		Armed	Update Disabled	1000-LRCC LACONIA
1140-iSTAR01/1I14-LRCC-CAT-G-ANTE/COPY-REX		Armed	Update Disabled	1000-LRCC LACONIA
1142-iSTAR01/2I01-LRCC-CAT-G-CLASSROOM-DSM		Armed	Inactive	1000-LRCC LACONIA
1147-iSTAR01/2I02-LRCC-CAT-G-SIDE ENT-DSM		Armed	Inactive	1000-LRCC LACONIA
1148-iSTAR01/2I03-LRCC-CAT-G-FACULTY-DSM		Armed	Inactive	1000-LRCC LACONIA
1149-iSTAR01/2I04-LRCC-CAT-G-FACULTY-DSM		Armed	Inactive	1000-LRCC LACONIA
1151-iSTAR01/2I05-LRCC-CAT-G-STORAGE-DSM		Armed	Inactive	1000-LRCC LACONIA
1152A-iSTAR01/2I06-LRCC-CAT-G-CLASSROOM-DSM		Armed	Inactive	1000-LRCC LACONIA
1152B-iSTAR01/2I07-LRCC-CAT-G-CLASSROOM EXT-DSM		Armed	Inactive	1000-LRCC LACONIA
1153A-iSTAR01/2I08-LRCC-CAT-G-CLASSROOM-DSM		Armed	Inactive	1000-LRCC LACONIA
1142-iSTAR01/2I09-LRCC-CAT-G-CLASSROOM-REX		Armed	Update Disabled	1000-LRCC LACONIA
1147-iSTAR01/2I10-LRCC-CAT-G-SIDE ENT-REX		Armed	Inactive	1000-LRCC LACONIA
1148-iSTAR01/2I11-LRCC-CAT-G-FACULTY-REX		Armed	Update Disabled	1000-LRCC LACONIA
1149-iSTAR01/2I12-LRCC-CAT-G-FACULTY-REX		Armed	Update Disabled	1000-LRCC LACONIA
1151-iSTAR01/2I13-LRCC-CAT-G-STORAGE-REX		Armed	Update Disabled	1000-LRCC LACONIA
1152A-iSTAR01/2I14-LRCC-CAT-G-CLASSROOM-REX		Armed	Update Disabled	1000-LRCC LACONIA
1152B-iSTAR01/2I15-LRCC-CAT-G-CLASSROOM EXT-REX		Armed	Update Disabled	1000-LRCC LACONIA
1153A-iSTAR01/2I16-LRCC-CAT-G-CLASSROOM-REX		Armed	Update Disabled	1000-LRCC LACONIA
1153B-iSTAR02/1I01-LRCC-CAT-G-BETWEEN CLASSROOMS-DSM		Armed	Inactive	1000-LRCC LACONIA
1154-iSTAR02/1I02-LRCC-CAT-G-STORAGE-DSM		Armed	Inactive	1000-LRCC LACONIA
1155-iSTAR02/1I03-LRCC-CAT-G-CONFERENCE RM-DSM		Armed	Inactive	1000-LRCC LACONIA
1156-iSTAR02/1I04-LRCC-CAT-G-NURSE STORAGE-DSM		Armed	Inactive	1000-LRCC LACONIA
1157-iSTAR02/1I05-LRCC-CAT-G-NURSE SIM-DSM		Armed	Inactive	1000-LRCC LACONIA
1158-iSTAR02/1I06-LRCC-CAT-G-CONTROL RM-DSM		Armed	Inactive	1000-LRCC LACONIA
1159-iSTAR02/1I07-LRCC-CAT-G-NURSE SIM-DSM		Armed	Inactive	1000-LRCC LACONIA
1160-iSTAR02/1I08-LRCC-CAT-G-NURSE CLASSROOM-DSM		Armed	Inactive	1000-LRCC LACONIA
1153B-iSTAR02/1I09-LRCC-CAT-G-BETWEEN CLASSROOMS-REX		Armed	Update Disabled	1000-LRCC LACONIA
1154-iSTAR02/1I10-LRCC-CAT-G-STORAGE-REX		Armed	Update Disabled	1000-LRCC LACONIA
1155-iSTAR02/1I11-LRCC-CAT-G-CONFERENCE RM-REX		Armed	Update Disabled	1000-LRCC LACONIA
1156-iSTAR02/1I12-LRCC-CAT-G-NURSE STORAGE-REX		Armed	Update Disabled	1000-LRCC LACONIA
1157-iSTAR02/1I13-LRCC-CAT-G-NURSE SIM-REX		Armed	Update Disabled	1000-LRCC LACONIA
1158-iSTAR02/1I14-LRCC-CAT-G-CONTROL RM-REX		Armed	Update Disabled	1000-LRCC LACONIA
1159-iSTAR02/1I15-LRCC-CAT-G-NURSE SIM-REX		Armed	Update Disabled	1000-LRCC LACONIA
1160-iSTAR02/1I16-LRCC-CAT-G-NURSE CLASSROOM-REX		Armed	Update Disabled	1000-LRCC LACONIA
1162-iSTAR02/2I01-LRCC-CAT-G-NURSE STORAGE-DSM		Armed	Inactive	1000-LRCC LACONIA
1163-iSTAR02/2I02-LRCC-CAT-G-MED STORAGE-DSM		Armed	Inactive	1000-LRCC LACONIA
1163A-iSTAR02/2I03-LRCC-CAT-G-NURSE STORAGE-DSM		Armed	Inactive	1000-LRCC LACONIA
1164-iSTAR02/2I04-LRCC-CAT-G-NURSE CLASSROOM-DSM		Armed	Inactive	1000-LRCC LACONIA
1162-iSTAR02/2I09-LRCC-CAT-G-NURSE STORAGE-REX		Armed	Update Disabled	1000-LRCC LACONIA
1163-iSTAR02/2I10-LRCC-CAT-G-MED STORAGE-REX		Armed	Update Disabled	1000-LRCC LACONIA
1163A-iSTAR02/2I11-LRCC-CAT-G-NURSE STORAGE-REX		Armed	Update Disabled	1000-LRCC LACONIA
1164-iSTAR02/2I12-LRCC-CAT-G-NURSE CLASSROOM-REX		Armed	Update Disabled	1000-LRCC LACONIA
1236-iSTAR03/1I01-LRCC-CAT-1ST-ACADEMIC COMMONS-DSM		Armed	Inactive	1000-LRCC LACONIA
1236A-iSTAR03/1I02-LRCC-CAT-1ST-ACADEMIC COMMONS REAR-DSM		Armed	Inactive	1000-LRCC LACONIA
1238-iSTAR03/1I03-LRCC-CAT-1ST-STORAGE-DSM		Armed	Inactive	1000-LRCC LACONIA
1239-iSTAR03/1I04-LRCC-CAT-1ST-KITCHEN-DSM		Armed	Inactive	1000-LRCC LACONIA
1243-iSTAR03/1I05-LRCC-CAT-1ST-CLASSROOM-DSM		Armed	Inactive	1000-LRCC LACONIA
1244-iSTAR03/1I06-LRCC-CAT-1ST-ANTE/COPY-DSM		Armed	Inactive	1000-LRCC LACONIA
1246-iSTAR03/1I07-LRCC-CAT-1ST-BIO/MICRO FAC-DSM		Armed	Inactive	1000-LRCC LACONIA
1247-iSTAR03/1I08-LRCC-CAT-1ST-PHYSICS STORAGE-DSM		Armed	Inactive	1000-LRCC LACONIA
1236-iSTAR03/1I09-LRCC-CAT-1ST-ACADEMIC COMMONS-REX		Armed	Update Disabled	1000-LRCC LACONIA
1236A-iSTAR03/1I10-LRCC-CAT-1ST-ACADEMIC COMMONS REAR-REX		Armed	Update Disabled	1000-LRCC LACONIA
1238-iSTAR03/1I11-LRCC-CAT-1ST-STORAGE-REX		Armed	Update Disabled	1000-LRCC LACONIA

1239-iSTAR03/1I12-LRCC-CAT-1ST-KITCHEN-REX		Armed	Update Disabled	1000-LRCC LACONIA
1243-iSTAR03/1I13-LRCC-CAT-1ST-CLASSROOM-REX		Armed	Update Disabled	1000-LRCC LACONIA
1244-iSTAR03/1I14-LRCC-CAT-1ST-ANTE/COPY-REX		Armed	Update Disabled	1000-LRCC LACONIA
1246-iSTAR03/1I15-LRCC-CAT-1ST-BIO/MICRO FAC-REX		Armed	Update Disabled	1000-LRCC LACONIA
1247-iSTAR03/1I16-LRCC-CAT-1ST-PHYSICS STORAGE-REX		Armed	Update Disabled	1000-LRCC LACONIA
1248-iSTAR03/2I01-LRCC-CAT-1ST-PHYSICS FAC-DSM		Armed	Inactive	1000-LRCC LACONIA
1249-iSTAR03/2I02-LRCC-CAT-1ST-PHYSICS LAB-DSM		Armed	Inactive	1000-LRCC LACONIA
1255-iSTAR03/2I03-LRCC-CAT-1ST-CONF RM-DSM		Armed	Inactive	1000-LRCC LACONIA
1256-iSTAR03/2I04-LRCC-CAT-1ST-CHEM STORAGE-DSM		Armed	Inactive	1000-LRCC LACONIA
1257-iSTAR03/2I05-LRCC-CAT-1ST-CHEM PREP-DSM		Armed	Inactive	1000-LRCC LACONIA
1258-iSTAR03/2I06-LRCC-CAT-1ST-CHEM LAB-DSM		Armed	Inactive	1000-LRCC LACONIA
1260A-iSTAR03/2I07-LRCC-CAT-1ST-PREP STORAGE-DSM		Armed	Inactive	1000-LRCC LACONIA
1260B-iSTAR03/2I08-LRCC-CAT-1ST-PREP STORAGE-DSM		Armed	Inactive	1000-LRCC LACONIA
1248-iSTAR03/2I09-LRCC-CAT-1ST-PHYSICS FAC-REX		Armed	Update Disabled	1000-LRCC LACONIA
1249-iSTAR03/2I10-LRCC-CAT-1ST-PHYSICS LAB-REX		Armed	Update Disabled	1000-LRCC LACONIA
1255-iSTAR03/2I11-LRCC-CAT-1ST-CONF RM-REX		Armed	Update Disabled	1000-LRCC LACONIA
1256-iSTAR03/2I12-LRCC-CAT-1ST-CHEM STORAGE-REX		Armed	Update Disabled	1000-LRCC LACONIA
1257-iSTAR03/2I13-LRCC-CAT-1ST-CHEM PREP-REX		Armed	Update Disabled	1000-LRCC LACONIA
1258-iSTAR03/2I14-LRCC-CAT-1ST-CHEM LAB-REX		Armed	Update Disabled	1000-LRCC LACONIA
1260A-iSTAR03/2I15-LRCC-CAT-1ST-PREP STORAGE-REX		Armed	Update Disabled	1000-LRCC LACONIA
1260B-iSTAR03/2I16-LRCC-CAT-1ST-PREP STORAGE-REX		Armed	Update Disabled	1000-LRCC LACONIA
1261A-iSTAR04/1I01-LRCC-CAT-1ST-261 TO 158 CLASSROOM-DSM		Armed	Inactive	1000-LRCC LACONIA
1261B-iSTAR04/1I02-LRCC-CAT-1ST-MICRO/BIO LAB-DSM		Armed	Inactive	1000-LRCC LACONIA
1261C-iSTAR04/1I03-LRCC-CAT-1ST-MICRO/BIO LAB-DSM		Armed	Inactive	1000-LRCC LACONIA
1262A-iSTAR04/1I04-LRCC-CAT-1ST-MICRO/BIO PREP-DSM		Armed	Inactive	1000-LRCC LACONIA
1262B-iSTAR04/1I05-LRCC-CAT-1ST-MICRO/BIO PREP-DSM		Armed	Inactive	1000-LRCC LACONIA
1263A-iSTAR04/1I06-LRCC-CAT-1ST-BIO LAB-DSM		Armed	Inactive	1000-LRCC LACONIA
1263B-iSTAR04/1I07-LRCC-CAT-1ST-BIO LAB-DSM		Armed	Inactive	1000-LRCC LACONIA
1264A-iSTAR04/1I08-LRCC-CAT-1ST-PREP STORAGE-DSM		Armed	Inactive	1000-LRCC LACONIA
1261A-iSTAR04/1I09-LRCC-CAT-1ST-261 TO 158 CLASSROOM-REX		Armed	Update Disabled	1000-LRCC LACONIA
1261B-iSTAR04/1I10-LRCC-CAT-1ST-MICRO/BIO LAB-REX		Armed	Update Disabled	1000-LRCC LACONIA
1261C-iSTAR04/1I11-LRCC-CAT-1ST-MICRO/BIO LAB-REX		Armed	Update Disabled	1000-LRCC LACONIA
1262A-iSTAR04/1I12-LRCC-CAT-1ST-MICRO/BIO PREP-REX		Armed	Update Disabled	1000-LRCC LACONIA
1262B-iSTAR04/1I13-LRCC-CAT-1ST-MICRO/BIO PREP-REX		Armed	Update Disabled	1000-LRCC LACONIA
1263A-iSTAR04/1I14-LRCC-CAT-1ST-BIO LAB-REX		Armed	Update Disabled	1000-LRCC LACONIA
1263B-iSTAR04/1I15-LRCC-CAT-1ST-BIO LAB-REX		Armed	Update Disabled	1000-LRCC LACONIA
1264A-iSTAR04/1I16-LRCC-CAT-1ST-PREP STORAGE-REX		Armed	Update Disabled	1000-LRCC LACONIA
1264B-iSTAR04/2I01-LRCC-CAT-1ST-PREP STORAGE-DSM		Armed	Inactive	1000-LRCC LACONIA
1265-iSTAR04/2I02-LRCC-CAT-1ST-STORAGE-DSM		Armed	Inactive	1000-LRCC LACONIA
1234-iSTAR04/2I03-LRCC-CAT-1ST-MAIN ENT-DSM		Armed	Inactive	1000-LRCC LACONIA
1264B-iSTAR04/2I09-LRCC-CAT-1ST-PREP STORAGE-REX		Armed	Update Disabled	1000-LRCC LACONIA
1265-iSTAR04/2I10-LRCC-CAT-1ST-STORAGE-REX		Armed	Update Disabled	1000-LRCC LACONIA
1234-iSTAR04/2I11-LRCC-CAT-1ST-MAIN ENT-REX		Armed	Update Disabled	1000-LRCC LACONIA
1008-iSTAR01/ACM1/I06-LRCC-TURNER-MAINT SHOP-DSM		Armed	Inactive	1000-LRCC LACONIA
1008-iSTAR01/ACM1/I06-LRCC-TURNER-MAINT SHOP-REX		Armed	Update Disabled	1000-LRCC LACONIA
LRCC OLD BUILDING ISTAR 1 LOCK DOORS-BTN	LRCC OLD BUILDING ISTAR 1 LOCK DOORS-BTN BUTTON IS ON THE ISTAR DOOR TO LOCK ALL DOORS ON THE PANEL INCASE OF NETWORK FAILURE	Armed	Inactive	1000-LRCC LACONIA
LRCC-CAT BUILDING ISTAR 1 AND 2 DOOR LOCK-BTN	LRCC-CAT BUILDING ISTAR 1 AND 2 DOOR LOCK-BTN BUTTON IS ON THE ISTAR DOOR TO LOCK ALL DOORS ON THE PANEL INCASE OF NETWORK FAILURE	Armed	Inactive	1000-LRCC LACONIA
LRCC-CAT BUILDING ISTAR 4 AND 4 DOOR LOCK-BTN	LRCC-CAT BUILDING ISTAR 4 AND 4 DOOR LOCK-BTN BUTTON LOCATED ON ISTAR 3 IN CAT BUILDING TO LOCK DOORS INCASE OF NETWORK LOSS	Armed	Inactive	1000-LRCC LACONIA
LRCC-AUTOMOTIVE REAR MAN DOOR-DSM	LRCC-AUTOMOTIVE REAR MAN DOOR-DSM	Armed	Inactive	1000-LRCC LACONIA
LRCC-AUTOMOTIVE REAR MAN DOOR-REX	LRCC-AUTOMOTIVE REAR MAN DOOR-REX	Armed	Update Disabled	1000-LRCC LACONIA

LRCC-AUTOMOTIVE MAIN LOBBY HC BUTTON-TRIP	LRCC-AUTOMOTIVE MAIN LOBBY HC BUTTON-TRIP	Armed	Inactive	1000-LRCC LACONIA
LRCC-AUTOMOTIVE MAIN ENTRANCE-DSM	LRCC-AUTOMOTIVE MAIN ENTRANCE-DSM	Armed	Inactive	1000-LRCC LACONIA
LRCC-AUTOMOTIVE MAIN ENTRANCE-REX	LRCC-AUTOMOTIVE MAIN ENTRANCE-REX	Armed	Update Disabled	1000-LRCC LACONIA
LRCC-AUTOMOTIVE MAIN LOBBY-DSM	LRCC-AUTOMOTIVE MAIN LOBBY-DSM	Armed	Inactive	1000-LRCC LACONIA
LRCC-AUTOMOTIVE MAIN LOBBY-REX	LRCC-AUTOMOTIVE MAIN LOBBY-REX	Armed	Update Disabled	1000-LRCC LACONIA
LRCC-AUTOMOTIVE CLASSROOM/LAB 115-DSM	LRCC-AUTOMOTIVE CLASSROOM/LAB 115-DSM	Armed	Inactive	1000-LRCC LACONIA
LRCC-AUTOMOTIVE CLASSROOM/LAB 115-REX	LRCC-AUTOMOTIVE CLASSROOM/LAB 115-REX	Armed	Update Disabled	1000-LRCC LACONIA
LRCC-AUTOMOTIVE CLASSROOM/LAB 114-DSM	LRCC-AUTOMOTIVE CLASSROOM/LAB 114-DSM	Armed	Inactive	1000-LRCC LACONIA
LRCC-AUTOMOTIVE CLASSROOM/LAB 114-REX	LRCC-AUTOMOTIVE CLASSROOM/LAB 114-REX	Armed	Update Disabled	1000-LRCC LACONIA
Communication Fail-iSTAR Output Board1-ACM1-LRCC-AUTOMOTIVE ISTAR		Armed	Inactive	1000-LRCC LACONIA
Communication Fail-iSTAR Input Board1-ACM1-LRCC-AUTOMOTIVE ISTAR		Armed	Inactive	1000-LRCC LACONIA
LRCC-AUTOMOTIVE REAR OVERHEAD-CONT	LRCC-AUTOMOTIVE REAR OVERHEAD-CONT	Armed	Inactive	1000-LRCC LACONIA
LRCC-AUTOMOTIVE CLASSROOM/LAB 115 OVERHEAD-CONT	LRCC-AUTOMOTIVE CLASSROOM/LAB 115 OVERHEAD-CONT	Armed	Inactive	1000-LRCC LACONIA
LRCC-AUTOMOTIVE CLASSROOM/LAB 114 OVERHEAD-CONT	LRCC-AUTOMOTIVE CLASSROOM/LAB 114 OVERHEAD-CONT	Armed	Inactive	1000-LRCC LACONIA
LRCC-EXT DOOR NEAR ROOM 113-DSM	LRCC-EXT DOOR NEAR ROOM 113-DSM	Armed	Active	1000-LRCC LACONIA
LRCC-EXT DOOR NEAR ROOM 113-REX	LRCC-EXT DOOR NEAR ROOM 113-REX	Armed	Update Disabled	1000-LRCC LACONIA
LRCC-AUTOMOTIVE BOILER-ALARM	LRCC-AUTOMOTIVE BOILER-ALARM	Armed	Inactive	1000-LRCC LACONIA
LRCC-EXT DOOR NEAR ROOM 124-DSM	LRCC-EXT DOOR NEAR ROOM 124-DSM	Armed	Inactive	1000-LRCC LACONIA
LRCC-EXT DOOR NEAR ROOM 124-REX	LRCC-EXT DOOR NEAR ROOM 124-REX	Armed	Update Disabled	1000-LRCC LACONIA
LRCC-CAT-1ST FLOOR EXT NEAR ROOM 124-DSM	LRCC-CAT-1ST FLOOR EXT NEAR ROOM 124-DSM	Armed	Inactive	1000-LRCC LACONIA
LRCC-CAT-1ST FLOOR EXT NEAR ROOM 124-REX	LRCC-CAT-1ST FLOOR EXT NEAR ROOM 124-REX	Armed	Update Disabled	1000-LRCC LACONIA
LRCC-AUTOMOTIVE IT CLOSET-DSM	LRCC-AUTOMOTIVE IT CLOSET-DSM	Armed	Inactive	1000-LRCC LACONIA
LRCC-AUTOMOTIVE IT CLOSET-REX	LRCC-AUTOMOTIVE IT CLOSET-REX	Armed	Update Disabled	1000-LRCC LACONIA
Wireless Reader Tamper - LRCC-AUTOMOTIVE IT CLOSET		Armed	Inactive	1000-LRCC LACONIA
Low Battery - LRCC-AUTOMOTIVE IT CLOSET		Armed	Inactive	1000-LRCC LACONIA
Manual Lock Override - LRCC-AUTOMOTIVE IT CLOSET		Armed	Inactive	1000-LRCC LACONIA
Push Button - LRCC-AUTOMOTIVE IT CLOSET		Unknown	Unknown	1000-LRCC LACONIA
LRCC-AUTOMOTIVE BOILER ROOM-DSM	LRCC-AUTOMOTIVE BOILER ROOM-DSM	Armed	Inactive	1000-LRCC LACONIA
LRCC-AUTOMOTIVE BOILER ROOM-REX	LRCC-AUTOMOTIVE BOILER ROOM-REX	Armed	Update Disabled	1000-LRCC LACONIA
Wireless Reader Tamper - LRCC-AUTOMOTIVE BOILER ROOM		Armed	Inactive	1000-LRCC LACONIA
Low Battery - LRCC-AUTOMOTIVE BOILER ROOM		Armed	Inactive	1000-LRCC LACONIA
Manual Lock Override - LRCC-AUTOMOTIVE BOILER ROOM		Armed	Inactive	1000-LRCC LACONIA
Push Button - LRCC-AUTOMOTIVE BOILER ROOM		Unknown	Unknown	1000-LRCC LACONIA
LRCC-AUTOMOTIVE STORAGE ROOM 103-DSM		Armed	Inactive	1000-LRCC LACONIA
LRCC-AUTOMOTIVE STORAGE ROOM 103-REX	LRCC-AUTOMOTIVE STORAGE ROOM 103-REX	Armed	Update Disabled	1000-LRCC LACONIA
Wireless Reader Tamper - LRCC-AUTOMOTIVE STORAGE ROOM		Armed	Inactive	1000-LRCC LACONIA
Low Battery - LRCC-AUTOMOTIVE STORAGE ROOM		Armed	Inactive	1000-LRCC LACONIA
Manual Lock Override - LRCC-AUTOMOTIVE STORAGE ROOM		Armed	Inactive	1000-LRCC LACONIA
Push Button - LRCC-AUTOMOTIVE STORAGE ROOM		Unknown	Unknown	1000-LRCC LACONIA
LRCC-AUTOMOTIVE ADMIN OFFICE-DSM	LRCC-AUTOMOTIVE ADMIN OFFICE-DSM	Armed	Inactive	1000-LRCC LACONIA
LRCC-AUTOMOTIVE ADMIN OFFICE-REX	LRCC-AUTOMOTIVE ADMIN OFFICE-REX	Armed	Update Disabled	1000-LRCC LACONIA
Wireless Reader Tamper - LRCC-AUTOMOTIVE ADMIN OFFICE		Armed	Inactive	1000-LRCC LACONIA
Low Battery - LRCC-AUTOMOTIVE ADMIN OFFICE		Armed	Inactive	1000-LRCC LACONIA
Manual Lock Override - LRCC-AUTOMOTIVE ADMIN OFFICE		Armed	Inactive	1000-LRCC LACONIA
Push Button - LRCC-AUTOMOTIVE ADMIN OFFICE		Unknown	Unknown	1000-LRCC LACONIA
LRCC-AUTOMOTIVE CLASSROOM 113-DSM	LRCC-AUTOMOTIVE CLASSROOM 113-DSM	Armed	Inactive	1000-LRCC LACONIA
LRCC-AUTOMOTIVE CLASSROOM 113-REX	LRCC-AUTOMOTIVE CLASSROOM 113-REX	Armed	Update Disabled	1000-LRCC LACONIA
Low Battery - LRCC DOOR 2-RDR		Armed	Inactive	1000-LRCC LACONIA
Manual Lock Override - LRCC DOOR 2-RDR		Armed	Inactive	1000-LRCC LACONIA
Push Button - LRCC DOOR 2-RDR		Unknown	Unknown	1000-LRCC LACONIA
LRCC-AUTOMOTIVE STORAGE ROOM 110-DSM	LRCC-AUTOMOTIVE STORAGE ROOM 110-DSM	Armed	Inactive	1000-LRCC LACONIA
LRCC-AUTOMOTIVE STORAGE ROOM 110-REX	LRCC-AUTOMOTIVE STORAGE ROOM 110-REX	Armed	Update Disabled	1000-LRCC LACONIA
Wireless Reader Tamper - LRCC DOOR 3-RDR		Armed	Inactive	1000-LRCC LACONIA
Low Battery - LRCC DOOR 3-RDR		Armed	Inactive	1000-LRCC LACONIA
Manual Lock Override - LRCC DOOR 3-RDR		Armed	Inactive	1000-LRCC LACONIA
Push Button - LRCC DOOR 3-RDR		Unknown	Unknown	1000-LRCC LACONIA
LRCC-AUTOMOTIVE CLASSROOM 115-DSM	LRCC-AUTOMOTIVE CLASSROOM 115-DSM	Armed	Inactive	1000-LRCC LACONIA
LRCC-AUTOMOTIVE CLASSROOM 115-REX	LRCC-AUTOMOTIVE CLASSROOM 115-REX	Armed	Update Disabled	1000-LRCC LACONIA
Wireless Reader Tamper - LRCC DOOR 4-RDR		Armed	Inactive	1000-LRCC LACONIA
Low Battery - LRCC DOOR 4-RDR		Armed	Inactive	1000-LRCC LACONIA
Manual Lock Override - LRCC DOOR 4-RDR		Armed	Inactive	1000-LRCC LACONIA

Push Button - LRCC DOOR 4-RDR		Armed	Inactive	1000-LRCC LACONIA
LRCC-AUTOMOTIVE CLASSROOM 114-DSM	LRCC-AUTOMOTIVE CLASSROOM 114-DSM	Armed	Active	1000-LRCC LACONIA
LRCC-AUTOMOTIVE CLASSROOM 114-REX	LRCC-AUTOMOTIVE CLASSROOM 114-REX	Armed	Update Disabled	1000-LRCC LACONIA
Low Battery - LRCC DOOR 1-RDR		Armed	Inactive	1000-LRCC LACONIA
Manual Lock Override - LRCC DOOR 1-RDR		Armed	Inactive	1000-LRCC LACONIA
Push Button - LRCC DOOR 1-RDR		Unknown	Unknown	1000-LRCC LACONIA
Wireless Reader Tamper - LRCC-AUTOMOTIVE CLASSROOM 113-RDR		Armed	Inactive	1000-LRCC LACONIA
Wireless Reader Tamper - LRCC DOOR 1-RDR		Armed	Inactive	1000-LRCC LACONIA
LRCC-AUTOMOTIVE LOCKDOWN-BTN		Armed	Inactive	1000-LRCC LACONIA
LRCC ISTAR 03 OUTPUT BOARD COMM FAIL		Armed	Active	1000-LRCC LACONIA
000000TEST		Armed	Inactive	1000-LRCC LACONIA
iSTAR04/2I04-LRCC-CAT BUILDING-LOCKDOWN BUTTON		Armed	Inactive	1000-LRCC LACONIA
Name	Description	Armed status	Active Status	Partition Name
MCC-A KNOX BLDG 2ND FLOOR ENTRANCE-DSM	MCC-A KNOX BLDG 2ND FLOOR ENTRANCE-DSM	Armed	Inactive	3000-MCC MANCHESTER
MCC-A KNOX BLDG 2ND FLOOR ENTRANCE-REX	MCC-A KNOX BLDG 2ND FLOOR ENTRANCE-REX	Armed	Update Disabled	3000-MCC MANCHESTER
MCC-231 AMT LAB-DSM	MCC-231 AMT LAB-DSM	Armed	Inactive	3000-MCC MANCHESTER
MCC-231 AMT LAB-REX	MCC-231 AMT LAB-REX	Armed	Update Disabled	3000-MCC MANCHESTER
MCC-235 COMPUTER SCIENCE CLASSROOM-DSM	MCC-235 COMPUTER SCIENCE CLASSROOM-DSM	Armed	Inactive	3000-MCC MANCHESTER
MCC-235 COMPUTER SCIENCE CLASSROOM-REX	MCC-235 COMPUTER SCIENCE CLASSROOM-REX	Armed	Update Disabled	3000-MCC MANCHESTER
MCC-243 EXERCISE CLASSROOM-DSM	MCC-243 EXERCISE CLASSROOM-DSM	Armed	Inactive	3000-MCC MANCHESTER
MCC-243 EXERCISE CLASSROOM-REX	MCC-243 EXERCISE CLASSROOM-REX	Armed	Update Disabled	3000-MCC MANCHESTER
MCC-241 EXERCISE SCIENCE LAB LEFT-DSM	MCC-241 EXERCISE SCIENCE LAB LEFT-DSM	Armed	Inactive	3000-MCC MANCHESTER
MCC-241 EXERCISE SCIENCE LAB LEFT-REX	MCC-241 EXERCISE SCIENCE LAB LEFT-REX	Armed	Update Disabled	3000-MCC MANCHESTER
MCC-241 EXERCISE SCIENCE LAB RIGHT-DSM	MCC-241 EXERCISE SCIENCE LAB RIGHT-DSM	Armed	Inactive	3000-MCC MANCHESTER
MCC-241 EXERCISE SCIENCE LAB RIGHT-REX	MCC-241 EXERCISE SCIENCE LAB RIGHT-REX	Armed	Update Disabled	3000-MCC MANCHESTER
MCC-237 COMPUTER CLASSROOM-DSM	MCC-237 COMPUTER CLASSROOM-DSM	Armed	Inactive	3000-MCC MANCHESTER
MCC-237 COMPUTER CLASSROOM-REX	MCC-237 COMPUTER CLASSROOM-REX	Armed	Update Disabled	3000-MCC MANCHESTER
MCC-CHILD DEVELOPMENT CENTER REAR ENTRANCE-DSM	MCC-CHILD DEVELOPMENT CENTER REAR ENTRANCE-DSM	Armed	Inactive	3000-MCC MANCHESTER
MCC-CHILD DEVELOPMENT CENTER REAR ENTRANCE-REX	MCC-CHILD DEVELOPMENT CENTER REAR ENTRANCE-REX	Armed	Update Disabled	3000-MCC MANCHESTER
MCC-CHILD DEVELOPMENT CENTER MAIN ENTRANCE-DSM	MCC-CHILD DEVELOPMENT CENTER MAIN ENTRANCE-DSM	Armed	Inactive	3000-MCC MANCHESTER
MCC-CHILD DEVELOPMENT CENTER MAIN ENTRANCE-REX	MCC-CHILD DEVELOPMENT CENTER MAIN ENTRANCE-REX	Armed	Update Disabled	3000-MCC MANCHESTER
MCC-253 COMPUTER LAB-DSM	MCC-253 COMPUTER LAB-DSM	Armed	Inactive	3000-MCC MANCHESTER
MCC-253 COMPUTER LAB-REX	MCC-253 COMPUTER LAB-REX	Armed	Update Disabled	3000-MCC MANCHESTER
MCC-231 AMT LAB EMERGENCY EXIT-CONT	MCC-231 AMT LAB EMERGENCY EXIT-CONT	Armed	Inactive	3000-MCC MANCHESTER
MCC-249 MARKETING EMERGENCY EXIT-CONT	MCC-249 MARKETING EMERGENCY EXIT-CONT	Armed	Inactive	3000-MCC MANCHESTER
MCC-259-1 CHILD DEVELOPMENT CENTER EMERGENCY EXIT-CONT	MCC-259-1 CHILD DEVELOPMENT CENTER EMERGENCY EXIT-CONT	Armed	Inactive	3000-MCC MANCHESTER
MCC-CHILD DEVELOPMENT CENTER MAIN ENT-CONT	MCC-CHILD DEVELOPMENT CENTER MAIN ENT-CONT	Armed	Inactive	3000-MCC MANCHESTER
MCC-259-3 CHILD DEVELOPMENT CENTER EMERGENCY EXIT-CONT	MCC-259-3 CHILD DEVELOPMENT CENTER EMERGENCY EXIT-CONT	Armed	Inactive	3000-MCC MANCHESTER
MCC-259-4 CHILD DEVELOPMENT CENTER EMERGENCY EXIT-CONT		Armed	Inactive	3000-MCC MANCHESTER
MCC-CHILD DEVELOPMENT CENTER-PANIC	MCC-CHILD DEVELOPMENT CENTER-PANIC	Armed	Inactive	3000-MCC MANCHESTER
MCC-247 WATER CLOSET-CONT	MCC-247 WATER CLOSET-CONT	Armed	Inactive	3000-MCC MANCHESTER
MCC-2 KNOX HALL DOOR 1-CONT	MCC-2 KNOX HALL DOOR 1-CONT	Armed	Inactive	3000-MCC MANCHESTER
MCC-2 KNOX HALL DOOR 2-CONT	MCC-2 KNOX HALL DOOR 2-CONT	Armed	Inactive	3000-MCC MANCHESTER
Communication Fail-iSTAR Input Board1-ACM1-MCC-2 KNOX HALL IDF-ISTAR		Armed	Inactive	3000-MCC MANCHESTER
Communication Fail-iSTAR Input Board2-ACM1-MCC-2 KNOX HALL IDF-ISTAR		Armed	Inactive	3000-MCC MANCHESTER
Communication Fail-iSTAR Output Board1-ACM1-MCC-2 KNOX HALL IDF-ISTAR		Armed	Inactive	3000-MCC MANCHESTER
MCC-321 NURSING LAB RIGHT-DSM	MCC-321 NURSING LAB RIGHT-DSM	Armed	Inactive	3000-MCC MANCHESTER
MCC-321 NURSING LAB RIGHT-REX	MCC-321 NURSING LAB RIGHT-REX	Armed	Update Disabled	3000-MCC MANCHESTER
MCC-321 NURSING LAB LEFT-DSM	MCC-321 NURSING LAB LEFT-DSM	Armed	Inactive	3000-MCC MANCHESTER
MCC-321 NURSING LAB LEFT-REX	MCC-321 NURSING LAB LEFT-REX	Armed	Update Disabled	3000-MCC MANCHESTER
MCC-325 COMPUTER LAB-DSM	MCC-325 COMPUTER LAB-DSM	Armed	Inactive	3000-MCC MANCHESTER
MCC-325 COMPUTER LAB-REX	MCC-325 COMPUTER LAB-REX	Armed	Update Disabled	3000-MCC MANCHESTER
MCC-327 MEDICAL ASSISTING LAB RIGHT-DSM	MCC-327 MEDICAL ASSISTING LAB RIGHT-DSM	Armed	Inactive	3000-MCC MANCHESTER
MCC-327 MEDICAL ASSISTING LAB RIGHT-REX	MCC-327 MEDICAL ASSISTING LAB RIGHT-REX	Armed	Update Disabled	3000-MCC MANCHESTER
MCC-327 MEDICAL ASSISTING LAB LEFT-DSM	MCC-327 MEDICAL ASSISTING LAB LEFT-DSM	Armed	Inactive	3000-MCC MANCHESTER
MCC-327 MEDICAL ASSISTING LAB LEFT-REX	MCC-327 MEDICAL ASSISTING LAB LEFT-REX	Armed	Update Disabled	3000-MCC MANCHESTER
Communication Fail-iSTAR Input Board1-ACM1-MCC-HSCI 3RD FL-ISTAR		Armed	Inactive	3000-MCC MANCHESTER

MCC-HSCI TO UPPER CAFE-CONT	MCC-HSCI TO UPPER CAFE-CONT	Armed	Inactive	3000-MCC MANCHESTER
Communication Fail-iSTAR Output Board1-ACM1-MCC-HSCI 3RD FL-ISTAR		Armed	Inactive	3000-MCC MANCHESTER
MCC-318 NURSING AND ALLIED HEALTH SIDE ENT-CONT	MCC-318 NURSING AND ALLIED HEALTH SIDE ENT-CONT	Armed	Inactive	3000-MCC MANCHESTER
MCC-318 NURSING AND ALLIED HEALTH MAIN ENT-CONT	MCC-318 NURSING AND ALLIED HEALTH MAIN ENT-CONT	Armed	Inactive	3000-MCC MANCHESTER
MCC-258 HUMAN RESOURCES-DSM	MCC-258 HUMAN RESOURCES-DSM	Armed	Inactive	3000-MCC MANCHESTER
MCC-258 HUMAN RESOURCES-REX	MCC-258 HUMAN RESOURCES-REX	Armed	Update Disabled	3000-MCC MANCHESTER
MCC-MAIN LOBBY-DSM	MCC-MAIN LOBBY-DSM	Armed	Inactive	3000-MCC MANCHESTER
MCC-MAIN LOBBY-REX	MCC-MAIN LOBBY-REX	Armed	Update Disabled	3000-MCC MANCHESTER
MCC-285 MICROBIOLOGY LAB-DSM	MCC-285 MICROBIOLOGY LAB-DSM	Armed	Inactive	3000-MCC MANCHESTER
MCC-285 MICROBIOLOGY LAB-REX	MCC-285 MICROBIOLOGY LAB-REX	Armed	Update Disabled	3000-MCC MANCHESTER
MCC-289 SCIENCE LAB-DSM	MCC-289 SCIENCE LAB-DSM	Armed	Inactive	3000-MCC MANCHESTER
MCC-289 SCIENCE LAB-REX	MCC-289 SCIENCE LAB-REX	Armed	Update Disabled	3000-MCC MANCHESTER
MCC-295 SCIENCE LAB-DSM	MCC-295 SCIENCE LAB-DSM	Armed	Inactive	3000-MCC MANCHESTER
MCC-295 SCIENCE LAB-REX	MCC-295 SCIENCE LAB-REX	Armed	Update Disabled	3000-MCC MANCHESTER
MCC-297 PHYSICS/EARTH SCIENCE LAB-DSM	MCC-297 PHYSICS/EARTH SCIENCE LAB-DSM	Armed	Inactive	3000-MCC MANCHESTER
MCC-297 PHYSICS/EARTH SCIENCE LAB-REX	MCC-297 PHYSICS/EARTH SCIENCE LAB-REX	Armed	Update Disabled	3000-MCC MANCHESTER
MCC-HSCI SIDE ENTRANCE-DSM	MCC-HSCI SIDE ENTRANCE-DSM	Armed	Inactive	3000-MCC MANCHESTER
MCC-HSCI SIDE ENTRANCE-REX	MCC-HSCI SIDE ENTRANCE-REX	Armed	Update Disabled	3000-MCC MANCHESTER
MCC-276 COMPUTER LAB-DSM	MCC-276 COMPUTER LAB-DSM	Armed	Inactive	3000-MCC MANCHESTER
MCC-276 COMPUTER LAB-REX	MCC-276 COMPUTER LAB-REX	Armed	Update Disabled	3000-MCC MANCHESTER
MCC-279 CHEMISTRY LAB LEFT-DSM	MCC-279 CHEMISTRY LAB LEFT-DSM	Armed	Inactive	3000-MCC MANCHESTER
MCC-279 CHEMISTRY LAB LEFT-REX	MCC-279 CHEMISTRY LAB LEFT-REX	Armed	Update Disabled	3000-MCC MANCHESTER
MCC-279 CHEMISTRY LAB RIGHT-DSM	MCC-279 CHEMISTRY LAB RIGHT-DSM	Armed	Inactive	3000-MCC MANCHESTER
MCC-279 CHEMISTRY LAB RIGHT-REX	MCC-279 CHEMISTRY LAB RIGHT-REX	Armed	Update Disabled	3000-MCC MANCHESTER
MCC-268 LIBRARY-DSM	MCC-268 LIBRARY-DSM	Armed	Inactive	3000-MCC MANCHESTER
MCC-268 LIBRARY-REX	MCC-268 LIBRARY-REX	Armed	Update Disabled	3000-MCC MANCHESTER
MCC-287 BOILER ROOM EMERGENCY EXIT-CONT	MCC-287 BOILER ROOM EMERGENCY EXIT-CONT	Armed	Inactive	3000-MCC MANCHESTER
Communication Fail-iSTAR Input Board1-ACM1-MCC-HSCI 2ND FL-ISTAR		Armed	Inactive	3000-MCC MANCHESTER
Communication Fail-iSTAR Output Board1-ACM1-MCC-HSCI 2ND FL-ISTAR		Armed	Inactive	3000-MCC MANCHESTER
MCC-297 PHYSICS/EARTH SCIENCE LAB EMERGENCY EXIT-CONT	MCC-297 PHYSICS/EARTH SCIENCE LAB EMERGENCY EXIT-CONT	Armed	Inactive	3000-MCC MANCHESTER
MCC-268 LIBRARY EMERGENCY EXIT LEFT-CONT	MCC-268 LIBRARY EMERGENCY EXIT LEFT-CONT	Armed	Inactive	3000-MCC MANCHESTER
MCC-268 LIBRARY EMERGENCY EXIT RIGHT-CONT	MCC-268 LIBRARY EMERGENCY EXIT RIGHT-CONT	Armed	Inactive	3000-MCC MANCHESTER
MCC-MAIN LOBBY MIDDLE DOOR-CONT	MCC-MAIN LOBBY MIDDLE DOOR-CONT	Armed	Inactive	3000-MCC MANCHESTER
MCC-MAIN LOBBY RIGHT DOOR-CONT	MCC-MAIN LOBBY RIGHT DOOR-CONT	Armed	Inactive	3000-MCC MANCHESTER
MCC-2ND FL HSCI HALL DOOR-CONT	MCC-2ND FL HSCI HALL DOOR-CONT	Armed	Inactive	3000-MCC MANCHESTER
MCC-225-1 METALLURGY LAB LEFT-DSM	MCC-225-1 METALLURGY LAB LEFT-DSM	Armed	Inactive	3000-MCC MANCHESTER
MCC-225-1 METALLURGY LAB LEFT-REX	MCC-225-1 METALLURGY LAB LEFT-REX	Armed	Update Disabled	3000-MCC MANCHESTER
MCC-225-METALLURGY LAB RIGHT-DSM	MCC-225-METALLURGY LAB RIGHT-DSM	Armed	Inactive	3000-MCC MANCHESTER
MCC-225-METALLURGY LAB RIGHT-REX	MCC-225-METALLURGY LAB RIGHT-REX	Armed	Update Disabled	3000-MCC MANCHESTER
MCC-219 COMPUTER LAB-DSM	MCC-219 COMPUTER LAB-DSM	Armed	Inactive	3000-MCC MANCHESTER
MCC-219 COMPUTER LAB-REX	MCC-219 COMPUTER LAB-REX	Armed	Update Disabled	3000-MCC MANCHESTER
MCC-222-COMPUTER LAB RIGHT-DSM	MCC-222-COMPUTER LAB RIGHT-DSM	Armed	Inactive	3000-MCC MANCHESTER
MCC-222-COMPUTER LAB RIGHT-REX	MCC-222-COMPUTER LAB RIGHT-REX	Armed	Update Disabled	3000-MCC MANCHESTER
MCC-222-COMPUTER LAB LEFT-DSM	MCC-222-COMPUTER LAB LEFT-DSM	Armed	Inactive	3000-MCC MANCHESTER
MCC-222-COMPUTER LAB LEFT-REX	MCC-222-COMPUTER LAB LEFT-REX	Armed	Update Disabled	3000-MCC MANCHESTER
MCC-217 ELECTRICAL TECH LAB-DSM	MCC-217 ELECTRICAL TECH LAB-DSM	Armed	Inactive	3000-MCC MANCHESTER
MCC-217 ELECTRICAL TECH LAB-REX	MCC-217 ELECTRICAL TECH LAB-REX	Armed	Update Disabled	3000-MCC MANCHESTER
MCC-215-ELECTRICAL TECH LAB LEFT-DSM	MCC-215-ELECTRICAL TECH LAB LEFT-DSM	Armed	Inactive	3000-MCC MANCHESTER
MCC-215-ELECTRICAL TECH LAB LEFT-REX	MCC-215-ELECTRICAL TECH LAB LEFT-REX	Armed	Update Disabled	3000-MCC MANCHESTER
MCC-215-ELECTRICAL TECH LAB RIGHT-DSM	MCC-215-ELECTRICAL TECH LAB RIGHT-DSM	Armed	Inactive	3000-MCC MANCHESTER
MCC-215-ELECTRICAL TECH LAB RIGHT-REX	MCC-215-ELECTRICAL TECH LAB RIGHT-REX	Armed	Update Disabled	3000-MCC MANCHESTER
MCC-216 COMPUTER LAB-DSM	MCC-216 COMPUTER LAB-DSM	Armed	Inactive	3000-MCC MANCHESTER
MCC-216 COMPUTER LAB-REX	MCC-216 COMPUTER LAB-REX	Armed	Update Disabled	3000-MCC MANCHESTER
MCC-211 WELDING LAB-DSM	MCC-211 WELDING LAB-DSM	Armed	Inactive	3000-MCC MANCHESTER
MCC-211 WELDING LAB-REX	MCC-211 WELDING LAB-REX	Armed	Update Disabled	3000-MCC MANCHESTER
MCC-209 HVAC-DSM	MCC-209 HVAC-DSM	Armed	Inactive	3000-MCC MANCHESTER

MCC-209 HVAC-REX	MCC-209 HVAC-REX	Armed	Update Disabled	3000-MCC MANCHESTER
MCC-207 HVAC CLASSROOM-DSM	MCC-207 HVAC CLASSROOM-DSM	Armed	Inactive	3000-MCC MANCHESTER
MCC-207 HVAC CLASSROOM-REX	MCC-207 HVAC CLASSROOM-REX	Armed	Update Disabled	3000-MCC MANCHESTER
MCC-203 CAD LAB-DSM	MCC-203 CAD LAB-DSM	Armed	Inactive	3000-MCC MANCHESTER
MCC-203 CAD LAB-REX	MCC-203 CAD LAB-REX	Armed	Update Disabled	3000-MCC MANCHESTER
MCC-133-WELDING LAB-DSM	MCC-133-WELDING LAB-DSM	Armed	Inactive	3000-MCC MANCHESTER
MCC-133-WELDING LAB-REX	MCC-133-WELDING LAB-REX	Armed	Update Disabled	3000-MCC MANCHESTER
MCC-133-WELDING LAB REAR-REX	MCC-133-WELDING LAB REAR-REX	Armed	Update Disabled	3000-MCC MANCHESTER
MCC-133-WELDING LAB REAR-DSM	MCC-133-WELDING LAB REAR-DSM	Armed	Inactive	3000-MCC MANCHESTER
MCC-135-AIR CON LAB-DSM	MCC-135-AIR CON LAB-DSM	Armed	Inactive	3000-MCC MANCHESTER
MCC-135-AIR CON LAB-REX	MCC-135-AIR CON LAB-REX	Armed	Update Disabled	3000-MCC MANCHESTER
MCC-135-AIR CON LAB REAR-DSM	MCC-135-AIR CON LAB REAR-DSM	Armed	Inactive	3000-MCC MANCHESTER
MCC-135-AIR CON LAB REAR-REX	MCC-135-AIR CON LAB REAR-REX	Armed	Update Disabled	3000-MCC MANCHESTER
MCC-137-HEATING LAB-DSM	MCC-137-HEATING LAB-DSM	Armed	Inactive	3000-MCC MANCHESTER
MCC-137-HEATING LAB-REX	MCC-137-HEATING LAB-REX	Armed	Update Disabled	3000-MCC MANCHESTER
MCC-137-HEATING LAB REAR-DSM	MCC-137-HEATING LAB REAR-DSM	Armed	Inactive	3000-MCC MANCHESTER
MCC-137-HEATING LAB REAR-REX	MCC-137-HEATING LAB REAR-REX	Armed	Update Disabled	3000-MCC MANCHESTER
MCC-139-BUILDING CONSTRUCTION-DSM	MCC-139-BUILDING CONSTRUCTION-DSM	Armed	Active	3000-MCC MANCHESTER
MCC-139-BUILDING CONSTRUCTION-REX	MCC-139-BUILDING CONSTRUCTION-REX	Armed	Update Disabled	3000-MCC MANCHESTER
MCC-139-BUILDING CONSTRUCTION REAR-DSM	MCC-139-BUILDING CONSTRUCTION REAR-DSM	Armed	Inactive	3000-MCC MANCHESTER
MCC-139-BUILDING CONSTRUCTION REAR-REX	MCC-139-BUILDING CONSTRUCTION REAR-REX	Armed	Update Disabled	3000-MCC MANCHESTER
MCC-268 LIBRARY PANIC-BTN	MCC-268 LIBRARY PANIC-BTN	Armed	Inactive	3000-MCC MANCHESTER
MCC- MAIN ENTRANCE PANIC-BTN	MCC- MAIN ENTRANCE PANIC-BTN	Armed	Inactive	3000-MCC MANCHESTER
Communication Fail-iSTAR Input Board2-ACM1-MCC-HSCI 2ND FL-ISTAR		Armed	Inactive	3000-MCC MANCHESTER
MCC-GYM EMERGENCY EXIT LEFT-CONT	MCC-GYM EMERGENCY EXIT LEFT-CONT	Armed	Inactive	3000-MCC MANCHESTER
Communication Fail-COM1iSTAR Output Board1-MCC-STUDENT CENTER GYM IDF-ISTAR EDGE		Armed	Inactive	3000-MCC MANCHESTER
MCC-CAFE SERVING AREA EMERGENCY EXIT-CONT	MCC-CAFE SERVING AREA EMERGENCY EXIT-CONT	Armed	Inactive	3000-MCC MANCHESTER
MCC-CAFE SITTING AREA EXIT-CONT	MCC-CAFE SITTING AREA EXIT-CONT	Armed	Inactive	3000-MCC MANCHESTER
MCC-PRESIDENTS OFFICE-DSM	MCC-PRESIDENTS OFFICE-DSM	Armed	Inactive	3000-MCC MANCHESTER
MCC-PRESIDENTS OFFICE-REX	MCC-PRESIDENTS OFFICE-REX	Armed	Update Disabled	3000-MCC MANCHESTER
MCC-VAULT-DSM	MCC-VAULT-DSM	Armed	Inactive	3000-MCC MANCHESTER
MCC-STUDENT CENTER DOOR LOCK OVER RIDE-BTN	MCC-STUDENT CENTER DOOR LOCK OVER RIDE-BTN	Armed	Inactive	3000-MCC MANCHESTER
MCC-GYM EMERGENCY EXIT RIGHT-CONT	MCC-GYM EMERGENCY EXIT RIGHT-CONT	Armed	Inactive	3000-MCC MANCHESTER
Communication Fail-COM1iSTAR Output Board1-MCC-STUDENT CENTER ONE STOP-ISTAR EDGE		Armed	Inactive	3000-MCC MANCHESTER
MCC-STUDENT SERVICES EMERGENCY EXIT-CONT	MCC-STUDENT SERVICES EMERGENCY EXIT-CONT	Armed	Inactive	3000-MCC MANCHESTER
MCC-KH2-3 HALL DOOR-CONT	MCC-KH2-3 HALL DOOR-CONT	Armed	Inactive	3000-MCC MANCHESTER
MCC-STUDENT SERVICES PANIC-BTN	MCC-STUDENT SERVICES PANIC-BTN	Armed	Inactive	3000-MCC MANCHESTER
MCC-Room 126 LECTURE HALL EMERGENCY EXIT-CONT	MCC-Room 126 LECTURE HALL EMERGENCY EXIT-CONT	Armed	Inactive	3000-MCC MANCHESTER
Communication Fail-iSTAR Input Board1-ACM1-MCC-B BUILDING 1ST FL IDF-ISTAR 2		Armed	Inactive	3000-MCC MANCHESTER
MCC-C BUILDING STAIR 1 EMERGENCY EXIT-CONT	MCC-C BUILDING STAIR 1 EMERGENCY EXIT-CONT	Armed	Inactive	3000-MCC MANCHESTER
MCC-C BUILDING STAIR 2 EMERGENCY EXIT-CONT	MCC-C BUILDING STAIR 2 EMERGENCY EXIT-CONT	Armed	Inactive	3000-MCC MANCHESTER
MCC-ACADEMIC AFFAIRS MAIN ENTRANCE LEFT-CONT Door 43 A & B	MCC-ACADEMIC AFFAIRS MAIN ENTRANCE LEFT-CONT Door 43 A & B	Armed	Inactive	3000-MCC MANCHESTER
MCC-2B-4 HALL DOORS-CONT	MCC-2B-4 HALL DOORS-CONT	Armed	Inactive	3000-MCC MANCHESTER
MCC-2B-2 HALL DOORS-CONT	MCC-2B-2 HALL DOORS-CONT	Armed	Inactive	3000-MCC MANCHESTER
MCC-2B-1 HALL DOORS-CONT	MCC-2B-1 HALL DOORS-CONT	Armed	Inactive	3000-MCC MANCHESTER
MCC-2C-N STAIR 1-CONT	MCC-2C-N STAIR 1-CONT	Armed	Active	3000-MCC MANCHESTER
Communication Fail-iSTAR Input Board2-ACM1-MCC-B BUILDING 1ST FL IDF-ISTAR 2		Armed	Inactive	3000-MCC MANCHESTER
MCC-KNOX 1 HALL DOOR-CONT	MCC-KNOX 1 HALL DOOR-CONT	Armed	Inactive	3000-MCC MANCHESTER
MCC-1B-7 HALL DOORS-CONT	MCC-1B-7 HALL DOORS-CONT	Armed	Inactive	3000-MCC MANCHESTER
MCC-1B-2 HALL DOORS-CONT	MCC-1B-2 HALL DOORS-CONT	Armed	Inactive	3000-MCC MANCHESTER
MCC-1B-1 HALL DOORS-CONT	MCC-1B-1 HALL DOORS-CONT	Armed	Inactive	3000-MCC MANCHESTER
MCC-133-9 WELDING LAB MAN DOOR-CONT	MCC-133-9 WELDING LAB MAN DOOR-CONT	Armed	Inactive	3000-MCC MANCHESTER
MCC-133-10 WELDING LAB OVERHEAD DOOR-CONT	MCC-133-10 WELDING LAB OVERHEAD DOOR-CONT	Armed	Inactive	3000-MCC MANCHESTER
Communication Fail-iSTAR Input Board3-ACM1-MCC-B BUILDING 1ST FL IDF-ISTAR 2		Armed	Inactive	3000-MCC MANCHESTER
MCC-133-7 WELDING LAB MAN DOOR-CONT	MCC-133-7 WELDING LAB MAN DOOR-CONT	Armed	Inactive	3000-MCC MANCHESTER
MCC-133-6 WELDING LAB SLIDING DOOR-CONT	MCC-133-6 WELDING LAB SLIDING DOOR-CONT	Armed	Inactive	3000-MCC MANCHESTER
MCC-133-5 WELDING LAB MAN DOOR-CONT	MCC-133-5 WELDING LAB MAN DOOR-CONT	Armed	Inactive	3000-MCC MANCHESTER

MCC-135 -7 AIR CON LAB STORAGE DOORS-CONT	MCC-135 -7 AIR CON LAB STORAGE DOORS--CONT	Armed	Inactive	3000-MCC MANCHESTER
MCC-135 -9 AIR CON LAB OVERHEAD DOOR-CONT	MCC-135 -9 AIR CON LAB OVERHEAD DOOR-CONT	Armed	Inactive	3000-MCC MANCHESTER
MCC-137-3 HEATING LAB OVERHEAD DOOR-CONT	MCC-137-3 HEATING LAB OVERHEAD DOOR-CONT	Armed	Inactive	3000-MCC MANCHESTER
MCC 141-1 BUILDING CONSTRUCTION OVERHEAD DOOR-CONT	MCC 141-1 BUILDING CONSTRUCTION OVERHEAD DOOR-CONT	Armed	Inactive	3000-MCC MANCHESTER
MCC 141-2 BUILDING CONSTRUCTION OVERHEAD DOOR-CONT	MCC 141-2 BUILDING CONSTRUCTION OVERHEAD DOOR-CONT	Armed	Inactive	3000-MCC MANCHESTER
Communication Fail-iSTAR Input Board1-ACM1-MCC-B BUILDING 1ST FL IDF 1-ISTAR		Armed	Inactive	3000-MCC MANCHESTER
MCC 141-3 BUILDING CONSTRUCTION OVERHEAD DOOR-CONT	MCC 141-3 BUILDING CONSTRUCTION OVERHEAD DOOR-CONT	Armed	Inactive	3000-MCC MANCHESTER
MCC 141-14BUILDING CONSTRUCTION MAN DOOR-CONT	MCC 141-14BUILDING CONSTRUCTION MAN DOOR-CONT	Armed	Inactive	3000-MCC MANCHESTER
MCC-CENTRAL WING ENTRANCE DOOR 1ST FLOOR-DSM	MCC-CENTRAL WING ENTRANCE DOOR 1ST FLOOR-DSM	Armed	Inactive	3000-MCC MANCHESTER
MCC-KNOX 6 MAIN ENTRANCE-REX	MCC-KNOX 6 MAIN ENTRANCE-REX	Armed	Update Disabled	3000-MCC MANCHESTER
MCC-106 GRAPHIC DESIGN LAB-DSM	MCC-106 GRAPHIC DESIGN LAB-DSM	Armed	Inactive	3000-MCC MANCHESTER
MCC-106 GRAPHIC DESIGN LAB-REX	MCC-106 GRAPHIC DESIGN LAB-REX	Armed	Update Disabled	3000-MCC MANCHESTER
MCC-108 ART AND DESIGN LAB-DSM	MCC-108 ART AND DESIGN LAB-DSM	Armed	Active	3000-MCC MANCHESTER
MCC-108 ART AND DESIGN LAB-REX	MCC-108 ART AND DESIGN LAB-REX	Armed	Update Disabled	3000-MCC MANCHESTER
MCC-110 ART AND DESIGN LAB-DSM	MCC-110 ART AND DESIGN LAB-DSM	Armed	Active	3000-MCC MANCHESTER
MCC-110 ART AND DESIGN LAB-REX	MCC-110 ART AND DESIGN LAB-REX	Armed	Update Disabled	3000-MCC MANCHESTER
MCC-100 LECTURE HALL EMERGENCY EXIT-CONT	MCC-100 LECTURE HALL EMERGENCY EXIT-CONT	Armed	Inactive	3000-MCC MANCHESTER
Communication Fail-iSTAR Input Board1-ACM1-MCC-KNOX 1ST FL TELEDATA-ISTAR		Armed	Inactive	3000-MCC MANCHESTER
Communication Fail-iSTAR Output Board1-ACM1-MCC-KNOX 1ST FL TELEDATA-ISTAR		Armed	Inactive	3000-MCC MANCHESTER
MCC-102 GRAPHIC DESIGN EMERGENCY EXIT-CONT	MCC-102 GRAPHIC DESIGN EMERGENCY EXIT-CONT	Armed	Inactive	3000-MCC MANCHESTER
MCC-HSCI 3RD FL DOOR LOCK OVER RIDE-BTN	MCC-HSCI 3RD FL DOOR LOCK OVER RIDE-BTN	Armed	Inactive	3000-MCC MANCHESTER
MCC-2ND FL KNOX DOOR LOCK OVER RIDE-BTN	MCC-2ND FL KNOX DOOR LOCK OVER RIDE-BTN	Armed	Inactive	3000-MCC MANCHESTER
MCC-B BUILDING DOOR LOCK OVER RIDE-BTN	MCC-B BUILDING DOOR LOCK OVER RIDE-BTN	Armed	Inactive	3000-MCC MANCHESTER
Communication Fail-iSTAR Output Board1-ACM1-MCC-B BUILDING 1ST FL IDF-ISTAR 2		Armed	Inactive	3000-MCC MANCHESTER
MCC-141 BUILDING CONSTRUCTION REAR-DSM	MCC-141 BUILDING CONSTRUCTION REAR-DSM	Armed	Inactive	3000-MCC MANCHESTER
MCC-141 BUILDING CONSTRUCTION REAR-REX	MCC-141 BUILDING CONSTRUCTION REAR-REX	Armed	Update Disabled	3000-MCC MANCHESTER
MCC-GYM GLASS DOORS-DSM	MCC-GYM GLASS DOORS-DSM	Armed	Active	3000-MCC MANCHESTER
MCC-GYM GLASS DOORS-REX	MCC-GYM GLASS DOORS-REX	Armed	Update Disabled	3000-MCC MANCHESTER
MCC-CAFE EMPLOYEE ENTRANCE-REX	MCC-CAFE EMPLOYEE ENTRANCE-REX	Armed	Update Disabled	3000-MCC MANCHESTER
MCC-CAFE EMPLOYEE ENTRANCE-DSM	MCC-CAFE EMPLOYEE ENTRANCE-DSM	Armed	Inactive	3000-MCC MANCHESTER
MCC-GYM IDF DOOR LOCK OVER RIDE-BTN	MCC-GYM IDF DOOR LOCK OVER RIDE-BTN	Armed	Inactive	3000-MCC MANCHESTER
Communication Fail-iSTAR Output Board2-ACM1-MCC-B BUILDING 1ST FL IDF-ISTAR 2		Armed	Inactive	3000-MCC MANCHESTER
MCC-CHILD DEVELOPMENT CENTER MAIN ENT AIPHONE-DREL	MCC-CHILD DEVELOPMENT CENTER MAIN ENT AIPHONE--DREL	Armed	Inactive	3000-MCC MANCHESTER
MCC-CHILD DEVELOPMENT CENTER REAR ENTRANCE AIPHONE-DREL	MCC-CHILD DEVELOPMENT CENTER REAR ENTRANCE AIPHONE-DREL	Armed	Inactive	3000-MCC MANCHESTER
MCC- 1 KNOX 2 HALLWAY DOORS 1-CONT	MCC-1 KNOX 2 HALLWAY DOORS 1-CONT	Armed	Inactive	3000-MCC MANCHESTER
Communication Fail-iSTAR Output Board1-ACM2-MCC-HSCI 2ND FL-ISTAR		Armed	Inactive	3000-MCC MANCHESTER
MCC-ENTRANCE 43 doors c&d -DSM	aka academic affiars MCC-NORTH WING 1ST FL ENTRANCE-DSM	Armed	Inactive	3000-MCC MANCHESTER
MCC- ENTRANCE 43 doors c & d -REX	AKA MCC-ACADEMIC AFFAIRS MAIN ENTRANCE-REX	Armed	Update Disabled	3000-MCC MANCHESTER
MCC-STUDENT ENTRANCE-DSM	MCC-STUDENT ENTRANCE-DSM	Armed	Inactive	3000-MCC MANCHESTER
MCC-STUDENT ENTRANCE-REX	MCC-STUDENT ENTRANCE-REX	Armed	Update Disabled	3000-MCC MANCHESTER
Communication Fail-iSTAR Output Board2-ACM2-MCC-HSCI 2ND FL-ISTAR		Armed	Inactive	3000-MCC MANCHESTER
MCC-252C-2 CAD STAIRS DOOR-CONT	MCC-252C-2 CAD STAIRS DOOR-CONT	Armed	Active	3000-MCC MANCHESTER
MCC-1 KNOX 2 HALLWAY DOORS 2-CONT	MCC-1 KNOX 2 HALLWAY DOORS 2-CONT	Armed	Inactive	3000-MCC MANCHESTER
MCC-LOBBY TO CAFE DOORS-CONT	MCC-LOBBY TO CAFE DOORS-CONT	Armed	Inactive	3000-MCC MANCHESTER
Communication Fail-iSTAR Output Board3-ACM2-MCC-HSCI 2ND FL-ISTAR		Armed	Inactive	3000-MCC MANCHESTER
Communication Fail-iSTAR Output Board4-ACM2-MCC-HSCI 2ND FL-ISTAR		Armed	Inactive	3000-MCC MANCHESTER
Communication Fail-iSTAR Output Board5-ACM2-MCC-HSCI 2ND FL-ISTAR		Armed	Inactive	3000-MCC MANCHESTER
MCC-KNOX 1ST FL TELEDATA ISTAR OVER RIDE-BTN	MCC-KNOX 1ST FL TELEDATA ISTAR OVER RIDE-BTN	Armed	Inactive	3000-MCC MANCHESTER
MCC-HSCI 2ND FL STAR DOOR OVER RIDE-BTN		Armed	Inactive	3000-MCC MANCHESTER
MCC-COMPUTER/EXERCISE HALL ENTRANCE-DSM		Armed	Inactive	3000-MCC MANCHESTER
MCC-COMPUTER/EXERCISE HALL ENTRANCE-REX		Armed	Update Disabled	3000-MCC MANCHESTER
Internal Battery Fault-MCC-SERVER ROOM EDGE		Armed	Inactive	3000-MCC MANCHESTER
MCC-SERVER ROOM-DSM	MCC-SERVER ROOM-DSM	Armed	Inactive	3000-MCC MANCHESTER
MCC-SERVER ROOM-REX	MCC-SERVER ROOM-REX	Armed	Update Disabled	3000-MCC MANCHESTER

MCC-MAINTENANCE SHOP LOCKOUT-BTN		Armed	Inactive	3000-MCC MANCHESTER
MCC-MAIN LOBBY DESK LOCKOUT-BTN		Armed	Inactive	3000-MCC MANCHESTER
MCC-LIBRARY LOCKOUT-BTN		Armed	Inactive	3000-MCC MANCHESTER
MCC-SECURITY OFFICE LOCKDOWN-BTN		Armed	Inactive	3000-MCC MANCHESTER
MCC-ACADEMIC AFFAIRS LOCKOUT-BTN		Armed	Inactive	3000-MCC MANCHESTER
MCC-SERVER ROOM TEMP SENSOR		Armed	Inactive	3000-MCC MANCHESTER
Communication Fail-iSTAR Output Board6-ACM2-MCC-HSCI 2ND FL-ISTAR		Armed	Inactive	3000-MCC MANCHESTER
MCC-3rd FL weightroom ENTRANCE DOOR-DSM		Armed	Inactive	3000-MCC MANCHESTER
MCC-2ND FL GYM ENTRANCE-REX		Armed	Update Disabled	3000-MCC MANCHESTER
MCC-AUTO LAB 1 REAR ENTRANCE-DSM		Armed	Inactive	3000-MCC MANCHESTER
MCC-AUTO LAB 1 REAR ENTRANCE-REX		Armed	Update Disabled	3000-MCC MANCHESTER
MCC-AUTO LAB 1 ENTRANCE-DSM		Armed	Inactive	3000-MCC MANCHESTER
MCC-AUTO LAB 1 ENTRANCE-REX		Armed	Update Disabled	3000-MCC MANCHESTER
MCC-AUTO LAB 2 ENTRANCE-DSM		Armed	Inactive	3000-MCC MANCHESTER
MCC-AUTO LAB 2 ENTRANCE-REX		Armed	Update Disabled	3000-MCC MANCHESTER
MCC-AUTO 123 CLASSROOM 4-DSM		Armed	Inactive	3000-MCC MANCHESTER
MCC-AUTO 123 CLASSROOM 4-REX		Armed	Update Disabled	3000-MCC MANCHESTER
MCC-AUTO 122 CLASSROOM 3-DSM		Armed	Inactive	3000-MCC MANCHESTER
MCC-AUTO 122 CLASSROOM 3-REX		Armed	Update Disabled	3000-MCC MANCHESTER
MCC-AUTO 121 CLASSROOM 2-DSM		Armed	Inactive	3000-MCC MANCHESTER
MCC-AUTO 121 CLASSROOM 2-REX		Armed	Update Disabled	3000-MCC MANCHESTER
MCC-AUTO 120 CLASSROOM 1-DSM		Armed	Inactive	3000-MCC MANCHESTER
MCC-AUTO 120 CLASSROOM 1-REX		Armed	Update Disabled	3000-MCC MANCHESTER
MCC-AUTO LAB 2 REAR ENTRANCE-DSM		Armed	Inactive	3000-MCC MANCHESTER
MCC-AUTO LAB 2 REAR ENTRANCE-REX		Armed	Update Disabled	3000-MCC MANCHESTER
MCC-AUTO MAIN ENTRANCE-DSM		Armed	Inactive	3000-MCC MANCHESTER
MCC-AUTO MAIN ENTRANCE-REX		Armed	Update Disabled	3000-MCC MANCHESTER
MCC-AUTO STUDENT ENTRANCE-DSM		Armed	Inactive	3000-MCC MANCHESTER
MCC-AUTO STUDENT ENTRANCE-REX		Armed	Update Disabled	3000-MCC MANCHESTER
MCC-AUTO 121 CLASSROOM 2 REAR-DSM		Armed	Inactive	3000-MCC MANCHESTER
MCC-AUTO 121 CLASSROOM 2 REAR-REX		Armed	Update Disabled	3000-MCC MANCHESTER
MCC-AUTO 122 CLASSROOM 3 REAR-DSM		Armed	Inactive	3000-MCC MANCHESTER
MCC-AUTO 122 CLASSROOM 3 REAR-REX		Armed	Update Disabled	3000-MCC MANCHESTER
MCC-102 ROBOTICS CLASS-DSM		Armed	Inactive	3000-MCC MANCHESTER
MCC-102 ROBOTICS CLASS-REX		Armed	Update Disabled	3000-MCC MANCHESTER
MCC-102 ROBOTICS LAB-DSM		Armed	Inactive	3000-MCC MANCHESTER
MCC-102 ROBOTICS LAB-REX		Armed	Update Disabled	3000-MCC MANCHESTER
MCC-GENERATOR-MTP	CONNECTED TO GENERATOR CONTROLLER IN SERVER ROOM ELECTRIC ROOM	Armed	Inactive	3000-MCC MANCHESTER
MCC-ADVANCED TECH 101 HVAC MOTORS-DSM		Armed	Inactive	3000-MCC MANCHESTER
MCC-ADVANCED TECH HVAC MOTORS-REX		Armed	Update Disabled	3000-MCC MANCHESTER
MCC-ADVANCED TECH 102 ETECH MOTORS 2-DSM		Armed	Inactive	3000-MCC MANCHESTER
MCC-ADVANCED TECH102 ETECH MOTORS 2-REX		Armed	Update Disabled	3000-MCC MANCHESTER
MCC-ADVANCED TECH103 ETECH MOTORS 1-DSM		Armed	Inactive	3000-MCC MANCHESTER
MCC-ADVANCED TECH103 ETECH MOTORS 1-REX		Armed	Update Disabled	3000-MCC MANCHESTER
MCC-ADVANCED TECH 113 TELE/DATA-DSM		Armed	Inactive	3000-MCC MANCHESTER
MCC-ADVANCED TECH 113 TELE/DATA-REX		Armed	Update Disabled	3000-MCC MANCHESTER
MCC-ADVANCED TECH109 PLC LAB-DSM		Armed	Inactive	3000-MCC MANCHESTER
MCC-ADVANCED TECH 109 PLC LAB-REX		Armed	Update Disabled	3000-MCC MANCHESTER
MCC-ADVANCED TECH CHILLER LAB-DSM		Armed	Inactive	3000-MCC MANCHESTER
MCC-ADVANCED TECH CHILLER LAB-REX		Armed	Update Disabled	3000-MCC MANCHESTER
MCC-ADVANCED TECH 224 HVAC 101-DSM		Armed	Inactive	3000-MCC MANCHESTER
MCC-ADVANCED TECH 224 HVAC 101-REX		Armed	Update Disabled	3000-MCC MANCHESTER
MCC-ADVANCED TECH 219 ETEC DOC-DSM		Armed	Inactive	3000-MCC MANCHESTER
MCC-ADVANCED TECH 219 ETEC DOC-REX		Armed	Update Disabled	3000-MCC MANCHESTER
MCC-ADVANCED TECH OUTDOOR LAB-DSM		Armed	Inactive	3000-MCC MANCHESTER
MCC-ADVANCED TECH OUTDOOR LAB-REX		Armed	Update Disabled	3000-MCC MANCHESTER
MCC-ADVANCED TECH 213 AHU LAB-DSM		Armed	Inactive	3000-MCC MANCHESTER
MCC-ADVANCED TECH 213 AHU LAB-REX		Armed	Update Disabled	3000-MCC MANCHESTER

MCC-ADVANCED TECH 223 RELATED ELECTRICITY-DSM		Armed	Inactive	3000-MCC MANCHESTER
MCC-ADVANCED TECH 223 RELATED ELECTRICITY-REX		Armed	Update Disabled	3000-MCC MANCHESTER
MCC-ADVANCED TECH 218 COMPUTER LAB LEFT-DSM		Armed	Inactive	3000-MCC MANCHESTER
MCC-ADVANCED TECH 218 COMPUTER LAB LEFT-REX		Armed	Update Disabled	3000-MCC MANCHESTER
MCC-ADVANCED TECH 218 COMPUTER LAB RIGHT-DSM		Armed	Inactive	3000-MCC MANCHESTER
MCC-ADVANCED TECH 218 COMPUTER LAB RIGHT-REX		Armed	Update Disabled	3000-MCC MANCHESTER
MCC-ADVANCED TECH 217 HVAC DDC-DSM		Armed	Inactive	3000-MCC MANCHESTER
MCC-ADVANCED TECH 217 HVAC DDC-REX		Armed	Update Disabled	3000-MCC MANCHESTER
MCC-ADVANCED TECH MAIN ENTRANCE-DSM		Armed	Inactive	3000-MCC MANCHESTER
MCC-ADVANCED TECH MAIN ENTRANCE-REX		Armed	Update Disabled	3000-MCC MANCHESTER
MCC-BURSAR FRONT ENTRANCE-DSM		Armed	Inactive	3000-MCC MANCHESTER
MCC-BURSAR FRONT ENTRANCE-REX		Armed	Update Disabled	3000-MCC MANCHESTER
MCC-BURSAR REAR ENTRANCE-DSM		Armed	Inactive	3000-MCC MANCHESTER
MCC-BURSAR REAR ENTRANCE-REX		Armed	Update Disabled	3000-MCC MANCHESTER
MCC-240 ADVANCED MANUFACTURING SINGLE-DSM		Armed	Inactive	3000-MCC MANCHESTER
MCC-240 ADVANCED MANUFACTURING SINGLE-REX		Armed	Update Disabled	3000-MCC MANCHESTER
MCC-240 ADVANCED MANUFACTURING DOUBLE-DSM		Armed	Inactive	3000-MCC MANCHESTER
MCC-240 ADVANCED MANUFACTURING DOUBLE-REX		Armed	Inactive	3000-MCC MANCHESTER
Name	Description	Armed status	Active Status	Partition Name
NCC-H325-3-NURSING LAB LEFT-DSM		Armed	Inactive	4500-NCC NASHUA
NCC-H325-3-NURSING LAB LEFT-REX		Armed	Update Disabled	4500-NCC NASHUA
NCC-H321-CONFERENCE ROOM-DSM		Armed	Inactive	4500-NCC NASHUA
NCC-H321-CONFERENCE ROOM-REX		Armed	Update Disabled	4500-NCC NASHUA
NCC-H325-2-NURSING LAB STORAGE-DSM		Armed	Inactive	4500-NCC NASHUA
NCC-H325-2-NURSING LAB STORAGE-REX		Armed	Update Disabled	4500-NCC NASHUA
NCC-3RD FLOOR IDF-DSM		Armed	Inactive	4500-NCC NASHUA
NCC-3RD FLOOR IDF-REX		Armed	Update Disabled	4500-NCC NASHUA
NCC-H325-3-NURSING LAB RIGHT-DSM		Armed	Inactive	4500-NCC NASHUA
NCC-H325-3-NURSING LAB RIGHT-REX		Armed	Update Disabled	4500-NCC NASHUA
NCC-2ND FLOOR IDF-DSM		Armed	Inactive	4500-NCC NASHUA
NCC-2ND FLOOR IDF-REX		Armed	Update Disabled	4500-NCC NASHUA
NCC-H285-LAB CLASSROOM-DSM		Armed	Inactive	4500-NCC NASHUA
NCC-H285-LAB CLASSROOM-REX		Armed	Update Disabled	4500-NCC NASHUA
NCC-H281-LAB CLASSROOM-DSM		Armed	Inactive	4500-NCC NASHUA
NCC-H281-LAB CLASSROOM-REX		Armed	Update Disabled	4500-NCC NASHUA
NCC-H283-LAB CLASSROOM-DSM		Armed	Inactive	4500-NCC NASHUA
NCC-H283-LAB CLASSROOM-REX		Armed	Update Disabled	4500-NCC NASHUA
NCC-H278-LABS OFFICE-DSM		Armed	Active	4500-NCC NASHUA
NCC-H278-LABS OFFICE-REX		Armed	Update Disabled	4500-NCC NASHUA
NCC-AUTO LAB GENERAL SHOP ENTRANCE-DSM		Armed	Inactive	4500-NCC NASHUA
NCC-AUTO LAB GENERAL SHOP ENTRANCE-REX		Armed	Update Disabled	4500-NCC NASHUA
NCC-AUTO LAB NORTH ENTRANCE EXTERIOR-DSM		Armed	Inactive	4500-NCC NASHUA
NCC-AUTO LAB NORTH ENTRANCE EXTERIOR-REX		Armed	Update Disabled	4500-NCC NASHUA
NCC-AUTO REPAIR LAB 8-DSM		Armed	Inactive	4500-NCC NASHUA
NCC-AUTO REPAIR LAB 8-REX		Armed	Update Disabled	4500-NCC NASHUA
NCC AUTO LAB SOUTH ENTRANCE EXTERIOR-DSM		Armed	Active	4500-NCC NASHUA
NCC AUTO LAB SOUTH ENTRANCE EXTERIOR-REX		Armed	Update Disabled	4500-NCC NASHUA
NCC-H BUILDING MAIN ENTRANCE EXTERIOR-DSM		Armed	Inactive	4500-NCC NASHUA
NCC-H BUILDING MAIN ENTRANCE EXTERIOR-REX		Armed	Update Disabled	4500-NCC NASHUA
NCC-H BUILDING NORTH SIDE ENTRANCE EXTERIOR-DSM		Armed	Inactive	4500-NCC NASHUA
NCC-H BUILDING NORTH SIDE ENTRANCE EXTERIOR-REX		Armed	Update Disabled	4500-NCC NASHUA
NCC-AUTO MAIN LOBBY ENTRANCE EXTERIOR-REX		Armed	Update Disabled	4500-NCC NASHUA
NCC-AUTO MAIN LOBBY ENTRANCE EXTERIOR-DSM		Armed	Inactive	4500-NCC NASHUA
NCC-H BUILDING SOUTH SIDE ENTRANCE EXTERIOR-DSM		Armed	Inactive	4500-NCC NASHUA
NCC-H BUILDING SOUTH SIDE ENTRANCE EXTERIOR-REX		Armed	Update Disabled	4500-NCC NASHUA
NCC-N101-1-GYM ENTRANCE-DSM		Armed	Inactive	4500-NCC NASHUA
NCC-N101-1-GYM ENTRANCE-REX		Armed	Update Disabled	4500-NCC NASHUA
NCC-201-2-FITNESS CENTER REAR TO TRACK-DSM		Armed	Inactive	4500-NCC NASHUA

NCC-201-2-FITNESS CENTER REAR TO TRACK-REX		Armed	Update Disabled	4500-NCC NASHUA
NCC-N110-MENS LOCKER ROOM-DSM		Armed	Inactive	4500-NCC NASHUA
NCC-N110-MENS LOCKER ROOM-REX		Armed	Update Disabled	4500-NCC NASHUA
NCC-201-1-FITNESS CENTER FRONT-DSM		Armed	Inactive	4500-NCC NASHUA
NCC-201-1-FITNESS CENTER FRONT-REX		Armed	Update Disabled	4500-NCC NASHUA
NCC-203-1-MULTI PURPOSE ROOM-DSM		Armed	Inactive	4500-NCC NASHUA
NCC-203-1-MULTI PURPOSE ROOM-REX		Armed	Update Disabled	4500-NCC NASHUA
NCC-N109-WOMENS LOCKER ROOM-DSM		Armed	Inactive	4500-NCC NASHUA
NCC-N109-WOMENS LOCKER ROOM-REX		Armed	Update Disabled	4500-NCC NASHUA
NCC-240-1-TRACK ENTRANCE-DSM		Armed	Inactive	4500-NCC NASHUA
NCC-240-1-TRACK ENTRANCE-REX		Armed	Update Disabled	4500-NCC NASHUA
NCC-N102-A-IDF-DSM		Armed	Inactive	4500-NCC NASHUA
NCC-N102-A-IDF-REX		Armed	Update Disabled	4500-NCC NASHUA
NCC-120-CHRISTINE GAGNON OFFICE-DSM		Armed	Inactive	4500-NCC NASHUA
NCC-120-CHRISTINE GAGNON OFFICE-REX		Armed	Update Disabled	4500-NCC NASHUA
NCC-144-2-MACHINE SHOP ENTRANCE EXTERIOR-DSM		Armed	Inactive	4500-NCC NASHUA
NCC-144-2-MACHINE SHOP ENTRANCE EXTERIOR-REX		Armed	Update Disabled	4500-NCC NASHUA
NCC-152-3-MAINTENANCE ENTRANCE EXTERIOR-DSM		Armed	Inactive	4500-NCC NASHUA
NCC-152-3-MAINTENANCE ENTRANCE EXTERIOR-REX		Armed	Update Disabled	4500-NCC NASHUA
NCC-EAST ENTRANCE EXTERIOR-DSM		Armed	Inactive	4500-NCC NASHUA
NCC-EAST ENTRANCE EXTERIOR-REX		Armed	Update Disabled	4500-NCC NASHUA
NCC-123-1-CAMPUS SAFETY-DSM		Armed	Inactive	4500-NCC NASHUA
NCC-123-1-CAMPUS SAFETY-REX		Armed	Update Disabled	4500-NCC NASHUA
NCC-156-1-ADMISSIONS ENTRANCE-DSM		Armed	Inactive	4500-NCC NASHUA
NCC-156-1-ADMISSIONS ENTRANCE-REX		Armed	Update Disabled	4500-NCC NASHUA
NCC-MAIN ENTRANCE EXTERIOR-DSM		Armed	Inactive	4500-NCC NASHUA
NCC-MAIN ENTRANCE EXTERIOR-REX		Armed	Update Disabled	4500-NCC NASHUA
NCC-SOUTH SIDE ENTRANCE EXTERIOR-DSM		Armed	Inactive	4500-NCC NASHUA
NCC-SOUTH SIDE ENTRANCE EXTERIOR-REX		Armed	Update Disabled	4500-NCC NASHUA
117-1-NCC-DSM		Armed	Inactive	4500-NCC NASHUA
117-1-NCC-REX		Armed	Update Disabled	4500-NCC NASHUA
NCC-100-1-ACADEMIC SUCCESS CENTER-DSM		Armed	Inactive	4500-NCC NASHUA
NCC-100-1-ACADEMIC SUCCESS CENTER-REX		Armed	Update Disabled	4500-NCC NASHUA
NCC-93-1-AVAITION TECH DEPARTMENT-DSM		Armed	Inactive	4500-NCC NASHUA
NCC-93-1-AVAITION TECH DEPARTMENT-REX		Armed	Update Disabled	4500-NCC NASHUA
NCC-89-4-AVAITION EXTERIOR-DSM		Armed	Inactive	4500-NCC NASHUA
NCC-89-4-AVAITION EXTERIOR-REX		Armed	Update Disabled	4500-NCC NASHUA
NCC-97-1-FINANCIAL AID-DSM		Armed	Inactive	4500-NCC NASHUA
NCC-97-1-FINANCIAL AID-REX		Armed	Update Disabled	4500-NCC NASHUA
NCC-99-1-ACADEMIC ADVISING CENTER-DSM		Armed	Inactive	4500-NCC NASHUA
NCC-99-1-ACADEMIC ADVISING CENTER-REX		Armed	Update Disabled	4500-NCC NASHUA
NCC-102-COMPUTER CLASSROOM-DSM		Armed	Inactive	4500-NCC NASHUA
NCC-98-1-MAIL ROOM-DSM		Armed	Inactive	4500-NCC NASHUA
NCC-SOUTH WEST EXTERIOR-DSM		Armed	Inactive	4500-NCC NASHUA
NCC-159-3-BUSINESS OFFICE VAULT-DSM		Armed	Inactive	4500-NCC NASHUA
NCC-159-1-BUSINESS OFFICE-DSM		Armed	Inactive	4500-NCC NASHUA
NCC-171-1-CAD LAB-DSM		Armed	Inactive	4500-NCC NASHUA
NCC-104-COMPUTER CLASSROOM-DSM		Armed	Inactive	4500-NCC NASHUA
NCC-170-1-CAD LAB-DSM		Armed	Inactive	4500-NCC NASHUA
NCC-102-COMPUTER CLASSROOM-REX		Armed	Update Disabled	4500-NCC NASHUA
NCC-98-1-MAIL ROOM-REX		Armed	Update Disabled	4500-NCC NASHUA
NCC-SOUTH WEST EXTERIOR-REX		Armed	Update Disabled	4500-NCC NASHUA
NCC-159-3-BUSINESS OFFICE VAULT-REX		Armed	Update Disabled	4500-NCC NASHUA
NCC-159-1-BUSINESS OFFICE-REX		Armed	Update Disabled	4500-NCC NASHUA
NCC-171-1-CAD LAB-REX		Armed	Update Disabled	4500-NCC NASHUA
NCC-104-COMPUTER CLASSROOM-REX		Armed	Update Disabled	4500-NCC NASHUA
NCC-170-1-CAD LAB-REX		Armed	Update Disabled	4500-NCC NASHUA

NCC-218-1-MICROSCOPE LAB-DSM		Armed	Inactive	4500-NCC NASHUA
NCC-220-1-COMPUTER LAB-DSM		Armed	Inactive	4500-NCC NASHUA
NCC-232-1-COMPUTER LAB-DSM		Armed	Active	4500-NCC NASHUA
NCC-233-1-CLASSROOM-DSM		Armed	Inactive	4500-NCC NASHUA
NCC-307-1-COMPUTER NETWORKING-DSM		Armed	Inactive	4500-NCC NASHUA
NCC-307-COMPUTER NETWORKING-DSM		Armed	Inactive	4500-NCC NASHUA
NCC-310-1-COMPUTER LAB-DSM		Armed	Inactive	4500-NCC NASHUA
NCC-310-2-COMPUTER LAB-DSM		Armed	Inactive	4500-NCC NASHUA
NCC-218-1-MICROSCOPE LAB-REX		Armed	Update Disabled	4500-NCC NASHUA
NCC-220-1-COMPUTER LAB-REX		Armed	Update Disabled	4500-NCC NASHUA
NCC-233-1-CLASSROOM-REX		Armed	Update Disabled	4500-NCC NASHUA
NCC-307-1-COMPUTER NETWORKING-REX		Armed	Update Disabled	4500-NCC NASHUA
NCC-307-COMPUTER NETWORKING-REX		Armed	Update Disabled	4500-NCC NASHUA
NCC-232-1-COMPUTER LAB-REX		Armed	Update Disabled	4500-NCC NASHUA
NCC-310-1-COMPUTER LAB-REX		Armed	Update Disabled	4500-NCC NASHUA
NCC-310-2-COMPUTER LAB-REX		Armed	Update Disabled	4500-NCC NASHUA
NCC-130-LIBRARY ENTRANCE-REX		Armed	Update Disabled	4500-NCC NASHUA
117-3-NCC PANIC		Armed	Inactive	4500-NCC NASHUA
89-3-NCC-DSM		Armed	Inactive	4500-NCC NASHUA
94-2-NCC-DSM		Armed	Inactive	4500-NCC NASHUA
93-2-NCC-DSM		Armed	Inactive	4500-NCC NASHUA
95-4-NCC-DSM		Armed	Inactive	4500-NCC NASHUA
FINANCIAL AID-NCC-DSM		Armed	Inactive	4500-NCC NASHUA
890-3-NCC-DSM		Armed	Inactive	4500-NCC NASHUA
89-2-NCC-DSM		Armed	Inactive	4500-NCC NASHUA
ME-12		Armed	Inactive	4500-NCC NASHUA
OVERHEAD-MC-1		Armed	Inactive	4500-NCC NASHUA
OVERHEAD-152		Armed	Inactive	4500-NCC NASHUA
RM-121-NCC-PANIC		Armed	Active	4500-NCC NASHUA
OVERHEAD-144-2		Armed	Inactive	4500-NCC NASHUA
N113-NCC-DSM	Kitchen Recieving door	Armed	Inactive	4500-NCC NASHUA
NCC-NORTH EAST ENTRANCE EXTERIOR-CONT		Armed	Inactive	4500-NCC NASHUA
NCC-COURTYARD EXIT-DSM		Armed	Inactive	4500-NCC NASHUA
NCC-MAINTENANCE RED UNLOCK SCHEDULE OVERRIDE-BTN	DEACTIVATES THE EXTERIOR DOORS UNLOCK SCHEDULE	Armed	Active	4500-NCC NASHUA
Name	Description	Armed status	Active Status	Partition Name
NHTI-GRAPPONE MAIN ENTRANCE-DSM	NHTI-GRAPPONE MAIN ENTRANCE-DSM			6000-NHTI CONCORD
NHTI-GRAPPONE MAIN ENTRANCE-REX	NHTI-GRAPPONE MAIN ENTRANCE-REX			6000-NHTI CONCORD
NHTI-GRAPPONE REAR ENTRANCE-DSM	NHTI-GRAPPONE REAR ENTRANCE-DSM			6000-NHTI CONCORD
NHTI-GRAPPONE REAR ENTRANCE-REX	NHTI-GRAPPONE REAR ENTRANCE-REX			6000-NHTI CONCORD
NHTI-GRAPPONE NURSING LAB AREA-DSM	NHTI-GRAPPONE NURSING LAB AREA-DSM			6000-NHTI CONCORD
NHTI-GRAPPONE NURSING LAB AREA-REX	NHTI-GRAPPONE NURSING LAB AREA-REX			6000-NHTI CONCORD
NHTI-GRAPPONE 133 CLASSROOM-DSM	NHTI-GRAPPONE 133 CLASSROOM-DSM			6000-NHTI CONCORD
NHTI-GRAPPONE 133 CLASSROOM-REX	NHTI-GRAPPONE 133 CLASSROOM-REX			6000-NHTI CONCORD
NHTI-GRAPPONE 136 NURSING SKILLS LAB-DSM	NHTI-GRAPPONE 136 NURSING SKILLS LAB-DSM			6000-NHTI CONCORD
NHTI-GRAPPONE 136 NURSING SKILLS LAB-REX	NHTI-GRAPPONE 136 NURSING SKILLS LAB-REX			6000-NHTI CONCORD
NHTI-GRAPPONE 218 COMPUTER LAB-DSM	NHTI-GRAPPONE 218 COMPUTER LAB-DSM			6000-NHTI CONCORD
NHTI-GRAPPONE 218 COMPUTER LAB-REX	NHTI-GRAPPONE 218 COMPUTER LAB-REX			6000-NHTI CONCORD
NHTI-GRAPPONE 218 COMPUTER LAB-CONT	NHTI-GRAPPONE 218 COMPUTER LAB-CONT			6000-NHTI CONCORD
Internal Battery Fault-NHTI-FARNUM 108 ISTAR EDGE				6000-NHTI CONCORD
NHTI-FARNUM F103 NETWORKING-DSM	NHTI-FARNUM F103 NETWORKING-DSM			6000-NHTI CONCORD
NHTI-FARNUM F103 NETWORKING-REX	NHTI-FARNUM F103 NETWORKING-REX			6000-NHTI CONCORD
NHTI-SWEENEY MAIN ENTRANCE-DSM	NHTI-SWEENEY MAIN ENTRANCE-DSM			6000-NHTI CONCORD
NHTI-SWEENEY MAIN ENTRANCE-REX	NHTI-SWEENEY MAIN ENTRANCE-REX			6000-NHTI CONCORD
NHTI-SWEENEY BISTRO EMPLOYEE ENTRANCE-DSM	NHTI-SWEENEY BISTRO EMPLOYEE ENTRANCE-DSM			6000-NHTI CONCORD
NHTI-SWEENEY BISTRO EMPLOYEE ENTRANCE-REX	NHTI-SWEENEY BISTRO EMPLOYEE ENTRANCE-REX			6000-NHTI CONCORD
NHTI-SWEENEY BURSAR MAIN DESK 1 PANIC-ALARM	NHTI-SWEENEY BURSAR MAIN DESK 1 PANIC-ALARM			6000-NHTI CONCORD
NHTI-SWEENEY BURSAR REAR OFFICE PANIC-ALARM	NHTI-SWEENEY BURSAR REAR OFFICE PANIC-ALARM			6000-NHTI CONCORD
NHTI-SWEENEY RECEPTION DESK PANIC-ALARM	NHTI-SWEENEY RECEPTION DESK PANIC-ALARM			6000-NHTI CONCORD
NHTI-SWEENEY BURSAR MAIN DESK 2 PANIC-ALARM	NHTI-SWEENEY BURSAR MAIN DESK 2 PANIC-ALARM			6000-NHTI CONCORD
NHTI-LIBRARY BOOK STORE ENTRANCE-DSM	NHTI-LIBRARY BOOK STORE ENTRANCE-DSM			6000-NHTI CONCORD
NHTI-LIBRARY BOOK STORE ENTRANCE-REX	NHTI-LIBRARY BOOK STORE ENTRANCE-REX			6000-NHTI CONCORD
NHTI-LIBRARY SHIPPING/RECIEVING-DSM	NHTI-LIBRARY SHIPPING/RECIEVING-DSM			6000-NHTI CONCORD

NHTI-LIBRARY SHIPPING/RECIEVING-REX	NHTI-LIBRARY SHIPPING/RECIEVING-REX			6000-NHTI CONCORD
NHTI-LIBRARY REAR DOOR-DSM	NHTI-LIBRARY REAR DOOR-DSM			6000-NHTI CONCORD
Internal Battery Fault-NHTI-MAINTENANCE-ISTAR EDGE				6000-NHTI CONCORD
NHTI-MAINTENANCE ENTRANCE-DSM	NHTI-MAINTENANCE ENTRANCE-DSM			6000-NHTI CONCORD
NHTI-MAINTENANCE ENTRANCE-REX	NHTI-MAINTENANCE ENTRANCE-REX			6000-NHTI CONCORD
NHTI-MACRURY DENTAL COMPUTER ROOM-DSM	NHTI-MACRURY DENTAL COMPUTER ROOM--DSM			6000-NHTI CONCORD
NHTI-MACRURY DENTAL COMPUTER ROOM-REX	NHTI-MACRURY DENTAL COMPUTER ROOM-REX			6000-NHTI CONCORD
NHTI-MACRURY MAIN ENTRANCE-DSM	NHTI-MACRURY MAIN ENTRANCE-DSM			6000-NHTI CONCORD
NHTI-MACRURY MAIN ENTRANCE-REX	NHTI-MACRURY MAIN ENTRANCE-REX			6000-NHTI CONCORD
NHTI-MACRURY REAR ENTRANCE-DSM	NHTI-MACRURY REAR ENTRANCE-DSM			6000-NHTI CONCORD
NHTI-MACRURY REAR ENTRANCE-REX	NHTI-MACRURY REAR ENTRANCE-REX			6000-NHTI CONCORD
NHTI-MACRURY M113 LIBRARY-DSM	NHTI-MACRURY M113 LIBRARY-DSM			6000-NHTI CONCORD
NHTI-MACRURY M113 LIBRARY-REX	NHTI-MACRURY M113 LIBRARY-REX			6000-NHTI CONCORD
NHTI-MACRURY M208 COMPUTER LAB-DSM	NHTI-MACRURY M208 COMPUTER LAB-DSM			6000-NHTI CONCORD
NHTI-MACRURY M208 COMPUTER LAB-REX	NHTI-MACRURY M208 COMPUTER LAB-REX			6000-NHTI CONCORD
NHTI-MACRURY M201 PARAMEDIC SUITE-DSM	NHTI-MACRURY M201 PARAMEDIC SUITE-DSM			6000-NHTI CONCORD
NHTI-MACRURY M201 PARAMEDIC SUITE-REX	NHTI-MACRURY M201 PARAMEDIC SUITE-REX			6000-NHTI CONCORD
NHTI-MACRURY M201C PARAMEDIC AMBULANCE-DSM	NHTI-MACRURY M201C PARAMEDIC AMBULANCE-DSM			6000-NHTI CONCORD
NHTI-MACRURY M201C PARAMEDIC AMBULANCE-REX	NHTI-MACRURY M201C PARAMEDIC AMBULANCE-REX			6000-NHTI CONCORD
NHTI-MACRURY M201D PARAMEDIC BREAKOUT-DSM	NHTI-MACRURY M201D PARAMEDIC BREAKOUT-DSM			6000-NHTI CONCORD
NHTI-MACRURY M201D PARAMEDIC BREAKOUT-REX	NHTI-MACRURY M201D PARAMEDIC BREAKOUT-REX			6000-NHTI CONCORD
NHTI-LANGLEY HALL A WING 1ST FLOOR INTERIOR-DSM	NHTI-LANGLEY HALL A WING 1ST FLOOR INTERIOR-DSM			6000-NHTI CONCORD
NHTI-LANGLEY HALL A WING 2ND FLOOR HALL-DSM	NHTI-LANGLEY HALL A WING 2ND FLOOR HALL-DSM			6000-NHTI CONCORD
NHTI-LANGLEY HALL A WING EXTERIOR-DSM	NHTI-LANGLEY HALL A WING EXTERIOR-DSM			6000-NHTI CONCORD
NHTI-LANGLEY HALL A WING EXTERIOR-REX	NHTI-LANGLEY HALL A WING EXTERIOR-REX			6000-NHTI CONCORD
NHTI-LANGLEY HALL MAIN LOBBY-DSM	NHTI-LANGLEY HALL MAIN LOBBY-DSM			6000-NHTI CONCORD
NHTI-LANGLEY HALL MAIN LOBBY-REX	NHTI-LANGLEY HALL MAIN LOBBY-REX			6000-NHTI CONCORD
NHTI-LANGLEY HALL BOILER ROOM EXTERIOR-DSM	NHTI-LANGLEY HALL BOILER ROOM EXTERIOR-DSM			6000-NHTI CONCORD
NHTI-LANGLEY HALL BOILER ROOM EXTERIOR-REX	NHTI-LANGLEYHALL BOILER ROOM EXTERIOR-REX			6000-NHTI CONCORD
NHTI-LANGLEY HALL A WING PHOTO-ALARM	NHTI-LANGLEY HALL A WING PHOTO-ALARM			6000-NHTI CONCORD
Communication Fail-iSTAR Input Board1-ACM1-NHTI-LAGNLEY HALL-ISTAR				6000-NHTI CONCORD
NHTI-NORTH HALL BOILER ROOM EXTERIOR-CONT	NHTI-NORTH HALL BOILER ROOM EXTERIOR-CONT			6000-NHTI CONCORD
NHTI-LANGLEY HALL PANIC BUTTONS-ALARM	NHTI-LANGLEY HALL PANIC BUTTONS-ALARM			6000-NHTI CONCORD
NHTI-NORTH HALL GLASS-ALARM				6000-NHTI CONCORD
NHTI-LANGLEY HALL B WING PHOTO-ALARM	NHTI-LANGLEY HALL B WING PHOTO-ALARM			6000-NHTI CONCORD
NHTI-NORTH HALL BALCONY DOOR-CONT	NHTI-NORTH HALL BALCONY DOOR-CONT			6000-NHTI CONCORD
NHTI-LANGLEY HALL C WING EAST PHOTO-ALARM	NHTI-LANGLEY HALL C WING EAST PHOTO-ALARM			6000-NHTI CONCORD
NHTI-LANGLEY HALL C WING WEST PHOTO-ALARM	NHTI-LANGLEY HALL C WING WEST PHOTO-ALARM			6000-NHTI CONCORD
Communication Fail-iSTAR Input Board2-ACM1-NHTI-LANGLEY HALL-ISTAR				6000-NHTI CONCORD
NHTI-NORTH HALL BOILER FAIL-ALARM				6000-NHTI CONCORD
NHTI-NORTH HALL FIRE-ALARM				6000-NHTI CONCORD
Communication Fail-iSTAR Output Board1-ACM1-NHTI-LANGLEY HALL-ISTAR				6000-NHTI CONCORD
NHTI-SOUTH HALL EAST-DSM	NHTI-SOUTH HALL EAST-DSM			6000-NHTI CONCORD
NHTI-SOUTH HALL EAST-REX	NHTI-SOUTH HALL EAST-REX			6000-NHTI CONCORD
NHTI-SOUTH HALL WEST-DSM	NHTI-SOUTH HALL WEST-DSM			6000-NHTI CONCORD
NHTI-SOUTH HALL WEST-REX	NHTI-SOUTH HALL WEST-REX			6000-NHTI CONCORD
NHTI-SOUTH HALL FRONT-DSM	NHTI-SOUTH HALL FRONT-DSM			6000-NHTI CONCORD
NHTI-SOUTH HALL FRONT-REX	NHTI-SOUTH HALL FRONT-REX			6000-NHTI CONCORD
NHTI-SOUTH HALL ELECTRICAL-DSM	NHTI-SOUTH HALL ELECTRICAL-DSM			6000-NHTI CONCORD
NHTI-SOUTH HALL ELECTRICAL-REX	NHTI-SOUTH HALL ELECTRICAL-REX			6000-NHTI CONCORD
NHTI-SOUTH HALL 1ST FLOOR PANIC-ALARM	NHTI-SOUTH HALL 1ST FLOOR PANIC-ALARM			6000-NHTI CONCORD
NHTI-SOUTH HALL 2ND FLOOR PANIC-ALARM	NHTI-SOUTH HALL 2ND FLOOR PANIC-ALARM			6000-NHTI CONCORD
NHTI-SOUTH HALL 3RD FLOOR PANIC-ALARM	NHTI-SOUTH HALL 3RD FLOOR PANIC-ALARM			6000-NHTI CONCORD
NHTI-SOUTH HALL REAR PHOTO-ALARM	NHTI-SOUTH HALL REAR PHOTO-ALARM			6000-NHTI CONCORD
NHTI-SOUTH HALL FRONT PHOTO-ALARM	NHTI-SOUTH HALL FRONT PHOTO-ALARM			6000-NHTI CONCORD
NHTI-SOUTH HALL BOILER FAIL-ALARM	NHTI-SOUTH HALL BOILER FAIL-ALARM			6000-NHTI CONCORD
NHTI-SOUTH HALL FIRE-ALARM				6000-NHTI CONCORD
NHTI-SOUTH HALL EXTERIOR STORAGE-CONT	NHTI-SOUTH HALL EXTERIOR STORAGE-CONT			6000-NHTI CONCORD
NHTI-SOUTH HALL BOILER ROOM-CONT				6000-NHTI CONCORD
Communication Fail-iSTAR Input Board1-ACM1-NHTI-SOUTH HALL-ISTAR				6000-NHTI CONCORD
Communication Fail-iSTAR Output Board1-ACM1-NHTI-SOUTH HALL-ISTAR				6000-NHTI CONCORD
Internal Battery Fault-NHTI-LITTLE HALL 1ST FLOOR-ISTAR EDGE				6000-NHTI CONCORD

Internal Battery Fault-NHTI-LITTLE HALL 2ND FLOOR-ISTAR EDGE				6000-NHTI CONCORD
NHTI-LITTLE HALL L204 CLASSROOM-DSM	NHTI-LITTLE HALL L204 CLASSROOM-DSM			6000-NHTI CONCORD
NHTI-LITTLE HALL L204 CLASSROOM-REX	NHTI-LITTLE HALL L204 CLASSROOM-REX			6000-NHTI CONCORD
NHTI-LITTLE HALL L231 CLASSROOM-DSM	NHTI-LITTLE HALL L231 CLASSROOM-DSM			6000-NHTI CONCORD
NHTI-LITTLE HALL L231 CLASSROOM-REX	NHTI-LITTLE HALL L231 CLASSROOM-REX			6000-NHTI CONCORD
NHTI-LITTLE HALL L128 CLASSROOM-DSM	NHTI-LITTLE HALL L128 CLASSROOM-DSM			6000-NHTI CONCORD
NHTI-LITTLE HALL L128 CLASSROOM-REX	NHTI-LITTLE HALL L128 CLASSROOM-REX			6000-NHTI CONCORD
NHTI-LITTLE HALL SLIDER TO STREET-DSM	NHTI-LITTLE HALL SLIDER TO STREET-DSM			6000-NHTI CONCORD
NHTI-LITTLE HALL SLIDER TO STREET-REX	NHTI-LITTLE HALL SLIDER TO STREET-REX			6000-NHTI CONCORD
Internal Battery Fault-NHTI-CHILDHOOD-ISTAR EDGE				6000-NHTI CONCORD
NHTI-CHILDHOOD MAIN ENTRANCE-DSM	NHTI-CHILDHOOD MAIN ENTRANCE-DSM			6000-NHTI CONCORD
NHTI-CHILDHOOD MAIN ENTRANCE-REX	NHTI-CHILDHOOD MAIN ENTRANCE-REX			6000-NHTI CONCORD
Internal Battery Fault-NHTI-CAPITAL COMMONS-ISTAR EDGE				6000-NHTI CONCORD
NHTI-CAPITAL COMMONS DATA CLOSET-DSM	NHTI-CAPITAL COMMONS DATA CLOSET-DSM			6000-NHTI CONCORD
NHTI-CAPITAL COMMONS-DATA CLOSET-REX	NHTI-CAPITAL COMMONS-DATA CLOSET-REX			6000-NHTI CONCORD
NHTI-CAPITAL COMMONS RECIEVING-DSM	NHTI-CAPITAL COMMONS RECIEVING-DSM			6000-NHTI CONCORD
NHTI-CAPITAL COMMONS RECIEVING-REX	NHTI-CAPITAL COMMONS RECIEVING-REX			6000-NHTI CONCORD
NHTI-WELLNESS CENTER FITNESS ROOM-DSM	NHTI-WELLNESS CENTER FITNESS ROOM-DSM			6000-NHTI CONCORD
NHTI-WELLNESS CENTER FITNESS ROOM-REX	NHTI-WELLNESS CENTER FITNESS ROOM-REX			6000-NHTI CONCORD
NHTI-STUDENT CENTER ENTRANCE-DSM	NHTI-STUDENT CENTER ENTRANCE-DSM			6000-NHTI CONCORD
NHTI-STUDENT CENTER ENTRANCE-REX	NHTI-STUDENT CENTER ENTRANCE-REX			6000-NHTI CONCORD
NHTI-WELLNESS CENTER ENTRANCE-DSM	NHTI-WELLNESS CENTER ENTRANCE-DSM			6000-NHTI CONCORD
NHTI-WELLNESS CENTER ENTRANCE-REX	NHTI-WELLNESS CENTER ENTRANCE-REX			6000-NHTI CONCORD
NHTI-STUDENT CENTER AFFAIR-DSM	NHTI-STUDENT CENTER AFFAIR-DSM			6000-NHTI CONCORD
NHTI-STUDENT CENTER AFFAIR-REX	NHTI-STUDENT CENTER AFFAIR-REX			6000-NHTI CONCORD
Communication Fail - NHTI-SWEENEY BISTRO EMPLOYEE ENTRANCE-RDR				6000-NHTI CONCORD
NHTI-CAPITAL COMMONS MANAGERS OFFICE-DSM	NHTI-CAPITAL COMMONS MANAGERS OFFICE-DSM			6000-NHTI CONCORD
NHTI-CAPITAL COMMONS MANAGERS OFFICE-REX	NHTI-CAPITAL COMMONS MANAGERS OFFICE-REX			6000-NHTI CONCORD
Communication Fail - NHTI-FARNUM MAIN ENTRANCE-RDR				6000-NHTI CONCORD
NHTI-WELLNESS CENTER OFFICE-DSM	NHTI-WELLNESS CENTER OFFICE-DSM			6000-NHTI CONCORD
NHTI-WELLNESS CENTER OFFICE-REX	NHTI-WELLNESS CENTER OFFICE-REX			6000-NHTI CONCORD
NHTI-GRAPPONE REAR ENTRANCE HANDICAP-BTN				6000-NHTI CONCORD
NHTI-GRAPPONE FRONT ENTRANCE HANDICAP-BTN				6000-NHTI CONCORD
Communication Fail-iSTAR Output Board1-ACM1-NHTI-STROUT HALL ISTAR				6000-NHTI CONCORD
NHTI-STROUT HALL EAST-DSM	NHTI-STROUT HALL EAST-DSM			6000-NHTI CONCORD
NHTI-STROUT HALL EAST-REX	NHTI-STROUT HALL EAST-REX			6000-NHTI CONCORD
NHTI-STROUT HALL WEST-DSM	NHTI-STROUT HALL WEST-DSM			6000-NHTI CONCORD
NHTI-STROUT HALL WEST-REX	NHTI-STROUT HALL WEST-REX			6000-NHTI CONCORD
NHTI-STROUT HALL FRONT-DSM	NHTI-STROUT HALL FRONT-DSM			6000-NHTI CONCORD
NHTI-STROUT HALL FRONT-REX	NHTI-STROUT HALL FRONT-REX			6000-NHTI CONCORD
Communication Fail-iSTAR Input Board1-ACM1-NHTI-STROUT HALL ISTAR				6000-NHTI CONCORD
NHTI-STROUT HALL FRONT PHOTO-ALARM	NHTI-STROUT HALL FRONT PHOTO-ALARM			6000-NHTI CONCORD
NHTI-STROUT HALL REAR PHOTO-ALARM	NHTI-STROUT HALL REAR PHOTO-ALARM			6000-NHTI CONCORD
NHTI-STROUT HALL 1ST FLOOR PANIC-ALARM	NHTI-STROUT HALL 1ST FLOOR PANIC-ALARM			6000-NHTI CONCORD
NHTI-STROUT HALL 2ND FLOOR PANIC-ALARM	NHTI-STROUT HALL 2ND FLOOR PANIC-ALARM			6000-NHTI CONCORD
NHTI-STROUT HALL 3RD FLOOR PANIC-ALARM	NHTI-STROUT HALL 3RD FLOOR PANIC-ALARM			6000-NHTI CONCORD
NHTI-STROUT HALL BOILER ROOM-CONT	NHTI-STROUT HALL BOILER ROOM-CONT			6000-NHTI CONCORD
NHTI-STROUT HALL ELECTRICAL ROOM EXTERIOR-CONT	NHTI-STROUT HALL ELECTRICAL ROOM EXTERIOR-CONT			6000-NHTI CONCORD
Communication Fail-COM3iSTAR Input Board1-NHTI-SWEENEY-ISTAR EDGE				6000-NHTI CONCORD
NHTI-SWEENEY-I81-I01-MAIN ENTRANCE HANDICAP-BTN	NHTI-SWEENEY MAIN ENTRANCE HANDICAP-BTN			6000-NHTI CONCORD
NHTI-SWEENEY-I81-I02-REAR ENTRANCE HANDICAP-BTN	NHTI-SWEENEY REAR ENTRANCE HANDICAP-BTN			6000-NHTI CONCORD
NHTI-FARNUM MAIN ENTRANCE HANDICAP-BTN	NHTI-FARNUM MAIN ENTRANCE HANDICAP-BTN			6000-NHTI CONCORD
NHTI-FARNUM MAIN ENTRANCE-DSM	NHTI-FARNUM MAIN ENTRANCE-DSM			6000-NHTI CONCORD
NHTI-FARNUM MAIN ENTRANCE-REX	NHTI-FARNUM MAIN ENTRANCE-REX			6000-NHTI CONCORD
Communication Fail-iSTAR Input Board1-ACM1-NHTI-LIBRARY-ISTAR				6000-NHTI CONCORD
NHTI-LIBRARY REAR EMERGENCY DOOR-CONT				6000-NHTI CONCORD
Communication Fail-iSTAR Output Board1-ACM1-NHTI-LIBRARY-ISTAR				6000-NHTI CONCORD
NHTI-LIBRARY SOUTH EMERGENCY DOOR-CONT	NHTI-LIBRARY SOUTH EMERGENCY DOOR-CONT			6000-NHTI CONCORD
NHTI-LIBRARY NORTH EMERGENCY DOOR-CONT				6000-NHTI CONCORD
NHTI-LIBRARY BOILER ROOM DOOR-CONT				6000-NHTI CONCORD
NHTI-LIBRARY PANIC-BUTTON				6000-NHTI CONCORD
Communication Fail-iSTAR Input Board1-ACM1-NHTI-MACRURY 2ND FLOOR-ISTAR				6000-NHTI CONCORD
NHTI-MACRURY MAIN ENTRANCE HANDICAP-BTN				6000-NHTI CONCORD
NHTI-MACRURY SIDE ENTRANCE-DSM	NHTI-MACRURY SIDE ENTRANCE-DSM			6000-NHTI CONCORD

NHTI-MACRURY SIDE ENTRANCE-REX	NHTI-MACRURY SIDE ENTRANCE-REX			6000-NHTI CONCORD
NHTI-MACRURY SIDE ENTRANCE HANDICAP-BTN				6000-NHTI CONCORD
NHTI-MACRURY REAR ENTRANCE-CONT	NHTI-MACRURY REAR ENTRANCE-CONT			6000-NHTI CONCORD
NHTI-MACRURY MICROBIOLOGY FRIDGE TEMP ALARM				6000-NHTI CONCORD
Communication Fail - NHTI-LANGLEY HALL B WING EXTERIOR-RDR				6000-NHTI CONCORD
NHTI-LANGLEY HALL B WING EXTERIOR-DSM	NHTI-LANGLEY HALL B WING EXTERIOR-DSM			6000-NHTI CONCORD
NHTI-LANGLEY HALL B WING EXTERIOR-REX	NHTI-LANGLEY HALL B WING EXTERIOR-REX			6000-NHTI CONCORD
NHTI-LANGLEY HALL C WING EXTERIOR-DSM	NHTI-LANGLEY HALL C WING EXTERIOR-DSM			6000-NHTI CONCORD
NHTI-LANGLEY HALL C WING EXTERIOR-REX	NHTI-LANGLEY HALL C WING EXTERIOR-REX			6000-NHTI CONCORD
Communication Fail - NHTI-LANGLEY HALL C WING EXTERIOR-RDR				6000-NHTI CONCORD
NHTI-LITTLE HALL L112 CLASSROOM-DSM	NHTI-LITTLE HALL L112 CLASSROOM-DSM			6000-NHTI CONCORD
NHTI-LITTLE HALL L112 CLASSROOM-REX	NHTI-LITTLE HALL L112 CLASSROOM-REX			6000-NHTI CONCORD
Internal Battery Fault-NHTI-CFDC ISTAR EDGE				6500-NHTI CFDC
NHTI-CFDC MAIN ENTRANCE-DSM	NHTI-CFDC MAIN ENTRANCE-DSM			6500-NHTI CFDC
NHTI-CFDC MAIN ENTRANCE-REX	NHTI-CFDC MAIN ENTRANCE-REX			6500-NHTI CFDC
NHTI-MACRURY QUAD ENTRANCE-DSM	NHTI-MACRURY QUAD ENTRANCE-DSM			6000-NHTI CONCORD
NHTI-MACRURY QUAD ENTRANCE-REX	NHTI-MACRURY QUAD ENTRANCE-REX			6000-NHTI CONCORD
NHTI-MACRURY LOBBY DESK PANIC				6000-NHTI CONCORD
NHTI-MACRURY LOBBY OFFICE PANIC				6000-NHTI CONCORD
Communication Fail-iSTAR Output Board1-ACM1-NHTI-STUDENT CENTER-ISTAR				6000-NHTI CONCORD
NHTI-CFDC MAIN ENTRANCE AIPHONE-DREL				6500-NHTI CFDC
NHTI-LITTLE HALL OFFICE PANIC-ALARM				6000-NHTI CONCORD
NHTI-LANGLEY HALL A WING 2ND FLOOR HALL-REX				6000-NHTI CONCORD
NHTI-LANGLEY HALL A WING 1ST FLOOR HALL-DSM				6000-NHTI CONCORD
NHTI-LANGLEY HALL A WING 1ST FLOOR HALL-REX				6000-NHTI CONCORD
Power Failure-NHTI-CFDC ISTAR EDGE				6500-NHTI CFDC
7000-CO-SERVER ROOM FRONT-DSM				7000-CO
7000-CO-SERVER ROOM FRONT-REX				7000-CO
7000-CO-SERVER ROOM REAR-DSM				7000-CO
7000-CO-SERVER ROOM REAR-REX				7000-CO
7000-CO-BACK ENTRANCE-DSM				7000-CO
7000-CO-BACK ENTRANCE-REX				7000-CO
7000-CO-FRONT ENTRANCE-DSM				7000-CO
7000-CO-FRONT ENTRANCE-REX				7000-CO
7000-CO-CHECK PRINTER-DSM				7000-CO
7000-CO-CHECK PRINTER-REX				7000-CO
7000-CO-MIDDLE-DSM				7000-CO
7000-CO-MIDDLE-REX				7000-CO
NHTI-CFDC ISTAR EDGE-I81-I01-WEST CORRIDOR EXIT DOOR-DSM				6500-NHTI CFDC
NHTI-CFDC ISTAR EDGE-I81-I02-WEST CORRIDOR EXIT DOOR-REX				6500-NHTI CFDC
NHTI-CFDC ISTAR EDGE-I81-I03-PRESCHOOL WEST EXIT DOOR-DSM				6500-NHTI CFDC
NHTI-CFDC ISTAR EDGE-I81-I04-PRESCHOOL WEST EXIT DOOR-REX				6500-NHTI CFDC
NHTI-CFDC ISTAR EDGE-I81-I05-PRESCHOOL SOUTH EXIT DOOR-DSM				6500-NHTI CFDC
NHTI-CFDC ISTAR EDGE-I81-I06-PRESCHOOL SOUTH EXIT DOOR-REX				6500-NHTI CFDC
NHTI-CFDC ISTAR EDGE-I81-I07-KINDERGARTEN EAST EXIT DOOR-DSM				6500-NHTI CFDC
NHTI-CFDC ISTAR EDGE-I81-I08-KINDERGARTEN EAST EXIT DOOR-REX				6500-NHTI CFDC
NHTI-CFDC-I05-TODDLER EAST EXIT DOOR-DSM				6500-NHTI CFDC
NHTI-CFDC-I06-TODDLER EAST EXIT DOOR-REX				6500-NHTI CFDC
NHTI-CFDC-I07-INFANT EAST EXIT DOOR-DSM				6500-NHTI CFDC
NHTI-CFDC-I08-INFANT EAST EXIT DOOR-REX				6500-NHTI CFDC
NHTI-LIBRARY EXTERIOR MAIN ENTRANCE-DSM				6000-NHTI CONCORD
NHTI-LIBRARY EXTERIOR MAIN ENTRANCE-REX				6000-NHTI CONCORD
NHTI-LIBRARY INTERIOR MAIN ENTRANCE-DSM				6000-NHTI CONCORD
NHTI-LIBRARY INTERIOR MAIN ENTRANCE-REX				6000-NHTI CONCORD
NHTI-GRAPPONE-I81-I01-G106 VESTIBULE EXIT DOOR				6000-NHTI CONCORD
NHTI-GRAPPONE-I81-I02-NORTHWEST STAIR EXIT DOOR				6000-NHTI CONCORD
NHTI-GRAPPONE-I81-I03-MECHANICAL ROOM EXIT DOOR				6000-NHTI CONCORD
NHTI-GRAPPONE-I81-I04-G125 SIMULATION EXIT DOOR				6000-NHTI CONCORD
NHTI-GRAPPONE-I81-I06-SOUTHEAST STAIR EXIT DOOR				6000-NHTI CONCORD
NHTI-GRAPPONE-I81-I05-2ND FLOOR 227 OFFICES PANIC				6000-NHTI CONCORD
NHTI-WELLNESS-I81-I01-GYM 112 SOUTH EXIT DOORS				6000-NHTI CONCORD
NHTI-WELLNESS-I81-I02-GYM 112 EAST EXIT DOORS				6000-NHTI CONCORD
NHTI-WELLNESS-I81-I03-GYM 112 NORTH EXIT DOORS				6000-NHTI CONCORD
NHTI-WELLNESS-I81-I04-GYM 112 STAIRWELL EXIT DOOR				6000-NHTI CONCORD
NHTI-CAPITAL COMMONS-I81-I01 SOUTHEAST DINING EXTERIOR DSM				6000-NHTI CONCORD

NHTI-CAPITAL COMMONS-I81-I02 SOUTHEAST DINING EXTERIOR REX				6000-NHTI CONCORD
NHTI-CAPITAL COMMONS-I81-I03 SOUTHWEST DINING EXTERIOR DSM				6000-NHTI CONCORD
NHTI-CAPITAL COMMONS-I81-I04 SOUTHWEST DINING EXTERIOR REX				6000-NHTI CONCORD
NHTI-CAPITAL COMMONS-I81-I05 WEST CAFE PATIO EXTERIOR DSM				6000-NHTI CONCORD
NHTI-CAPITAL COMMONS-I81-I06 WEST CAFE PATIO EXTERIOR REX				6000-NHTI CONCORD
NHTI-CAPITAL COMMONS-I81-I07 SERVERY EXTERIOR DSM				6000-NHTI CONCORD
NHTI-CAPITAL COMMONS-I81-I08 SERVERY EXTERIOR REX				6000-NHTI CONCORD
NHTI-MACRURY-I01-LOBBY ENTRANCE-DSM				6000-NHTI CONCORD
NHTI-MACRURY-I02-LOBBY ENTRANCE-REX				6000-NHTI CONCORD
NHTI-MACRURY-I03-NORTH CORRIDOR EXIT DOOR-DSM				6000-NHTI CONCORD
NHTI-MACRURY-I04-SOUTH CORRIDOR EXIT DOOR-DSM				6000-NHTI CONCORD
NHTI-FARNUM REAR ENTRANCE-DSM				6000-NHTI CONCORD
NHTI-FARNUM REAR ENTRANCE-REX				6000-NHTI CONCORD
NHTI-LITTLE HALL-PRESIDENTS OFFICE-PANIC				6000-NHTI CONCORD
NHTI-SWEENEY-I81-I03-BISTRO EXTERIOR ENTRANCE-DSM				6000-NHTI CONCORD
NHTI-SWEENEY-I81-I04-BISTRO EXTERIOR ENTRANCE-REX				6000-NHTI CONCORD
NHTI-SWEENEY-I81-I05-BISTRO LOADING ENTRANCE-DSM				6000-NHTI CONCORD
NHTI-SWEENEY-I81-I06-BISTRO LOADING ENTRANCE-REX				6000-NHTI CONCORD
NHTI-SWEENEY-I81-I07-BISTRO FOYER ENTRANCE-DSM				6000-NHTI CONCORD
NHTI-SWEENEY-I81-I08-BISTRO FOYER ENTRANCE-REX				6000-NHTI CONCORD
NHTI-MACRURY-112 RAIDOOLIGY SECTRETARY PANIC				6000-NHTI CONCORD
NHTI-SWEENEY-I82-I01-CONTINUING ED 103-PANIC				6000-NHTI CONCORD
NHTI-SWEENEY-I82-I02-FINANCIAL AID 104-PANIC				6000-NHTI CONCORD
NHTI-SWEENEY-I82-I03-REGISTRAR 113-PANIC				6000-NHTI CONCORD
NHTI-SWEENEY-I82-I04-OFFICE 148-PANIC				6000-NHTI CONCORD
NHTI-SWEENEY-I82-I05-ADMISSIONS 145-PANIC				6000-NHTI CONCORD
NHTI-MACRURY-I07-ELECTRICAL ROOM EXIT DOOR-DSM				6000-NHTI CONCORD
NHTI-SWEENEY-I82-I07-EXTERIOR MECHANICAL ROOM-DSM				6000-NHTI CONCORD
NHTI-SWEENEY-I82-I08-EAST EXTERIOR STAIRWELL-DSM				6000-NHTI CONCORD
NHTI-STUDENT CENTER-I81-I05-HEALTH RECEPTION-PANIC				6000-NHTI CONCORD
NHTI-SWEENEY S301 OFFICE-DSM				6000-NHTI CONCORD
NHTI-SWEENEY S301 OFFICE-REX				6000-NHTI CONCORD
NHTI-SWEENEY S318 IT CLASSROOM-DSM				6000-NHTI CONCORD
NHTI-SWEENEY S318 IT CLASSROOM-REX				6000-NHTI CONCORD
NHTI-SWEENEY S308 CISCO LAB-DSM				6000-NHTI CONCORD
NHTI-SWEENEY S308 CISCO LAB-REX				6000-NHTI CONCORD
NHTI-SWEENEY S309 CISCO LAB CLASSROOM-DSM				6000-NHTI CONCORD
NHTI-SWEENEY S309 CISCO LAB CLASSROOM-REX				6000-NHTI CONCORD
NHTI-SWEENEY S306 DH OFFICE-DSM				6000-NHTI CONCORD
NHTI-SWEENEY S306 DH OFFICE-REX				6000-NHTI CONCORD
NHTI-SWEENEY S307 FACULTY OFFICE-DSM				6000-NHTI CONCORD
NHTI-SWEENEY S307 FACULTY OFFICE-REX				6000-NHTI CONCORD
NHTI-FARNUM F104 FACULTY ADJUNCT-DSM				6000-NHTI CONCORD
NHTI-FARNUM F104 FACULTY ADJUNCT-REX				6000-NHTI CONCORD
NHTI-CAMPUS SAFTY ENTRANCE-DSM				6000-NHTI CONCORD
NHTI-CAMPUS SAFTY ENTRANCE-REX				6000-NHTI CONCORD
NHTI-GRAPPONE-217 CONFERENCE ROOM LOCKDOWN BUTTON-BTN				6000-NHTI CONCORD
NHTI-GRAPPONE-326 OFFICE LOCKDOWN BUTTON-BTN				6000-NHTI CONCORD
NHTI-LITTLE HALL-115-125 OFFICE CONFERENCE ROOM LOCKDOWN BUTTON-BTN				6000-NHTI CONCORD
NHTI-LITTLE HALL-PRESIDENTS OFFICE LOCKDOWN BUTTON-BTN				6000-NHTI CONCORD
NHTI-CAPITOL COMMONS-MANAGERS OFFICE LOCKDOWN BUTTON-BTN				6000-NHTI CONCORD
NHTI-MACRURY-142 OFFICE LOCKDOWN BUTTON-BTN				6000-NHTI CONCORD
NHTI-MACRURY-M112 OFFICE LOCKDOWN BUTTON-BTN				6000-NHTI CONCORD
NHTI-LIBRARY ACE MAIN DESK LOCKDOWN BUTTON-BTN				6000-NHTI CONCORD
NHTI-LIBRARY MAIN OFFICE LOCKDOWN BUTTON-BTN				6000-NHTI CONCORD
NHTI-SWEENEY-S103 CONTINUING ED LOCKDOWN BUTTON-BTN				6000-NHTI CONCORD
NHTI-STUDENT CENTER-S226 STUDENT AFFAIRS LOCKDOWN BUTTON-BTN				6000-NHTI CONCORD
NHTI-WELLNESS-110 ATHLETICS OFFICE LOCKDOWN BUTTON-BTN				6000-NHTI CONCORD
NHTI-STUDENT CENTER-SC104 HEALTH SERVICES LOCKDOWN BUTTON-BTN				6000-NHTI CONCORD
NHTI-LANGLEY-116 OFFICE LOCKDOWN BUTTON-BTN				6000-NHTI CONCORD
Communication Fail-COM1iSTAR Input Board1-NHTI-MACRURY DATA ROOM 141-ISTAR EDGE #1				6000-NHTI CONCORD
NHTI-MACRURY-130 ELECTRICAL ROOM LOCKDOWN BUTTON-BTN				6000-NHTI CONCORD
NHTI-FARNUM-F108 B,C,D OFFICE LOCKDOWN BUTTON-BTN				6000-NHTI CONCORD

NHTI-GRAPPONE-136 NURSING SKILLS LAB LOCKDOWN BUTTON-BTN				6000-NHTI CONCORD
NHTI-CAMPUS SAFTY-1ST FL LOADING DOCK DOOR-CONT				6000-NHTI CONCORD
NHTI-CAMPUS SAFTY-1ST FL REAR DOOR-CONT				6000-NHTI CONCORD
NHTI-CAMPUS SAFTY-2ND FL REAR DOOR-CONT				6000-NHTI CONCORD
NHTI-CAMPUS SAFTY-1ST FL LOCKDOWN BUTTON-BTN				6000-NHTI CONCORD
Communication Fail-NHTI-MACRURY 2ND FLOOR-ISTAR-O81				6000-NHTI CONCORD
Communication Fail-NHTI-SWEENEY-ISTAR EDGE-O81				6000-NHTI CONCORD
NHTI-SWEENEY S131 FIRE ALARM ROOM-DSM				6000-NHTI CONCORD
NHTI-SWEENEY S131 FIRE ALARM ROOM-REX				6000-NHTI CONCORD
NHTI-SWEENEY S220A IT ROOM-DSM				6000-NHTI CONCORD
NHTI-SWEENEY S220A IT ROOM-REX				6000-NHTI CONCORD
NHTI-SWEENEY REAR ENTRANCE-DSM				6000-NHTI CONCORD
NHTI-SWEENEY REAR ENTRANCE-REX				6000-NHTI CONCORD
NHTI-SOUTH HALL COUNSELORS OFFICE PANIC-ALARM				6000-NHTI CONCORD
Name	Description	Armed status	Active Status	Partition Name
RVCC CLAREMONT-1ST FLOOR EMPLOYEE/STUDENT ENTRANCE-DSM	RVCC CLAREMONT-1ST FLOOR EMPLOYEE/STUDENT ENTRANCE-DSM	Armed	Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC CLAREMONT-1ST FLOOR EMPLOYEE/STUDENT ENTRANCE-REX	RVCC CLAREMONT-1ST FLOOR EMPLOYEE/STUDENT ENTRANCE-REX	Armed	Update Disabled	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC CLAREMONT-1ST FLOOR HANDICAP RESTROOM TO MAIN HALL-DSM	RVCC CLAREMONT-1ST FLOOR HANDICAP RESTROOM TO MAIN HALL-DSM	Armed	Active	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC CLAREMONT-1ST FLOOR HANDICAP RESTROOM TO MAIN HALL-REX	RVCC CLAREMONT-1ST FLOOR HANDICAP RESTROOM TO MAIN HALL-REX	Armed	Update Disabled	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC CLAREMONT-1ST FLOOR LIBRARY TO LEARNING CENTER-DSM	RVCC CLAREMONT-1ST FLOOR LIBRARY TO LEARNING CENTER-DSM	Armed	Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC CLAREMONT-1ST FLOOR LIBRARY TO LEARNING CENTER-REX	RVCC CLAREMONT-1ST FLOOR LIBRARY TO LEARNING CENTER-REX	Armed	Update Disabled	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC CLAREMONT-1ST FLOOR 100J LEARNING CENTER-DSM	RVCC CLAREMONT-1ST FLOOR 100J LEARNING CENTER-DSM	Armed	Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC CLAREMONT-1ST FLOOR 100J LEARNING CENTER-REX	RVCC CLAREMONT-1ST FLOOR 100J LEARNING CENTER-REX	Armed	Update Disabled	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC CLAREMONT-1ST FLOOR EXT FALCON-DSM	RVCC CLAREMONT-1ST FLOOR EXT FALCON-DSM	Armed	Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC CLAREMONT-1ST FLOOR EXT FALCON-REX	RVCC CLAREMONT-1ST FLOOR EXT FALCON-REX	Armed	Update Disabled	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC CLAREMONT-1ST FLOOR DOOR 14 CAFE-CONT	RVCC CLAREMONT-1ST FLOOR DOOR 14 CAFE-CONT	Armed	Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC CLAREMONT-1ST FLOOR DOOR 15 CAFE-CONT	RVCC CLAREMONT-1ST FLOOR DOOR 15 CAFE-CONT	Armed	Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC CLAREMONT-1ST FLOOR DOOR 16 CAFE-CONT	RVCC CLAREMONT-1ST FLOOR DOOR 16 CAFE-CONT	Armed	Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC CLAREMONT-1ST FLOOR DOOR 17 CAFE-CONT	RVCC CLAREMONT-1ST FLOOR DOOR 17 CAFE-CONT	Armed	Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC CLAREMONT-1ST FLOOR DOOR 7 BOILER EXIT-CONT	RVCC CLAREMONT-1ST FLOOR DOOR 7 BOILER EXIT-CONT	Armed	Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC CLAREMONT-1ST FLOOR DOOR 9 ROOM 152 EMERG EXIT-CONT	RVCC CLAREMONT-1ST FLOOR DOOR 9 ROOM 152 EMERG EXIT-CONT	Armed	Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC CLAREMONT-1ST FLOOR DOOR 10 STAIR TO COURT EMERG EXIT-CONT	RVCC CLAREMONT-1ST FLOOR DOOR 10 STAIR TO COURT EMERG EXIT-CONT	Armed	Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC CLAREMONT-1ST FLOOR DOOR 6 NORTH SCIENCE WING-CONT	RVCC CLAREMONT ISTAR01-1ST FLOOR DOOR 6 NORTH SCIENCE WING-CONT	Armed	Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC CLAREMONT-1ST FLOOR DOOR 4 EAST SCIENCE WING-CONT	RVCC CLAREMONT-1ST FLOOR DOOR 4 EAST SCIENCE WING-CONT	Armed	Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC CLAREMONT-1ST FLOOR DOOR 3 ROOM 125 EMERG EXIT-CONT	RVCC CLAREMONT-1ST FLOOR DOOR 3 ROOM 125 EMERG EXIT-CONT	Armed	Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC CLAREMONT-1ST FLOOR DOOR 2 LIBRARY EMERG EXIT-CONT	RVCC CLAREMONT-1ST FLOOR DOOR 2 LIBRARY EMERG EXIT-CONT	Armed	Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
Communication Fail-iSTAR Input Board1-ACM1-RVCC CLAREMONT ISTAR01-1ST FLOOR SERVER ROOM		Armed	Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
Communication Fail-iSTAR Input Board2-ACM1-RVCC CLAREMONT ISTAR01-1ST FLOOR SERVER ROOM		Armed	Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
Communication Fail-iSTAR Output Board1-ACM1-RVCC CLAREMONT ISTAR01-1ST FLOOR SERVER ROOM		Armed	Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
Communication Fail-iSTAR Output Board2-ACM1-RVCC CLAREMONT ISTAR01-1ST FLOOR SERVER ROOM		Armed	Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
Communication Fail-iSTAR Output Board3-ACM1-RVCC CLAREMONT ISTAR01-1ST FLOOR SERVER ROOM		Armed	Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
Communication Fail-iSTAR Output Board4-ACM1-RVCC CLAREMONT ISTAR01-1ST FLOOR SERVER ROOM		Armed	Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC CLAREMONT ISTAR01-1ST FLOOR DOOR 12 MAIN HALL TO COURTYARD-CONT	RVCC CLAREMONT-1ST FLOOR DOOR 12 MAIN HALL TO COURTYARD-CONT	Armed	Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC KEENE-1ST FLOOR FRONT ENTRANCE-REX	RVCC KEENE-1ST FLOOR FRONT ENTRANCE-REX	Armed	Update Disabled	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC KEENE-1ST FLOOR REAR ENTRANCE-DSM	RVCC KEENE-1ST FLOOR REAR ENTRANCE-DSM	Armed	Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC KEENE-1ST FLOOR REAR ENTRANCE-REX	RVCC KEENE-1ST FLOOR REAR ENTRANCE-REX	Armed	Update Disabled	2000-RVCC CLAREMONT/KEENE/LEBANON
Communication Fail-COM1iSTAR Input Board1-RVCC KEENE ISTAR EDGE01-1ST FLOOR SERVER ROOM		Armed	Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC KEENE-1ST FLOOR BOILER ROOM EMERG EXIT-CONT	RVCC KEENE-1ST FLOOR BOILER ROOM EMERG EXIT-CONT	Armed	Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
Communication Fail-COM1iSTAR Output Board1-RVCC KEENE ISTAR EDGE01-1ST FLOOR SERVER ROOM		Armed	Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
Communication Fail-COM1iSTAR Output Board2-RVCC KEENE ISTAR EDGE01-1ST FLOOR SERVER ROOM		Armed	Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC KEENE-1ST FLOOR VIRTUAL LAB 018 EMERG EXIT-CONT	RVCC KEENE-1ST FLOOR VIRTUAL LAB 018 EMERG EXIT-CONT	Armed	Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC KEENE-1ST FLOOR MACHINE TOOL ROOM 107 EMERG EXIT-CONT	RVCC KEENE-1ST FLOOR MACHINE TOOL ROOM 107 EMERG EXIT-CONT	Armed	Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC KEENE-1ST FLOOR CLASSROOM 113 EMERG EXIT-CONT	RVCC KEENE-1ST FLOOR CLASSROOM 113 EMERG EXIT-CONT	Armed	Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON

RVCC KEENE-1ST FLOOR STAIR 3 EMERG EXIT-CONT	RVCC KEENE-1ST FLOOR STAIR 3 EMERG EXIT-CONT	Armed	Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC KEENE-2ND FLOOR SCIENCE LAB 218 EMERG EXIT-CONT	RVCC KEENE-2ND FLOOR SCIENCE LAB 218 EMERG EXIT-CONT	Armed	Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC KEENE-1ST FLOOR STAIR 2 EMERG EXIT-CONT	RVCC KEENE-1ST FLOOR STAIR 2 EMERG EXIT-CONT	Armed	Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
Communication Fail-COM1iSTAR Input Board2-RVCC KEENE ISTAR EDGE01-1ST FLOOR SERVER ROOM		Armed	Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC KEENE-1ST FLOOR FRONT ENTRANCE AIPHONE-BTN	RVCC KEENE-1ST FLOOR FRONT ENTRANCE AIPHONE-BTN	Armed	Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC KEENE-1ST FLOOR REAR ENTRANCE AIPHONE-BTN	RVCC KEENE-1ST FLOOR REAR ENTRANCE AIPHONE-BTN	Armed	Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC KEENE-1ST FLOOR REAR ENTRANCE HANDICAP-BTN	RVCC KEENE-1ST FLOOR REAR ENTRANCE HANDICAP-BTN	Armed	Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
Communication Fail-COM1iSTAR Output Board3-RVCC KEENE ISTAR EDGE01-1ST FLOOR SERVER ROOM		Armed	Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC CLAREMONT-1ST FLOOR MAIN ENTRANCE-CONT	RVCC CLAREMONT-1ST FLOOR MAIN ENTRANCE-CONT	Armed	Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC CLAREMONT-1ST FLOOR LIBRARY-MOT	RVCC CLAREMONT-1ST FLOOR LIBRARY-MOT	Armed	Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC CLAREMONT-1ST FLOOR CFO OFFICE-MOT	RVCC CLAREMONT-1ST FLOOR CFO OFFICE-MOT	Armed	Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC KEENE-1ST FLOOR BOILER ROOM HALLWAY-MOT	RVCC KEENE-1ST FLOOR BOILER ROOM HALLWAY-MOT	Armed	Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC KEENE-1ST FLOOR SERVER ROOM HALLWAY-MOT	RVCC KEENE-1ST FLOOR SERVER ROOM HALLWAY-MOT	Armed	Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
2006-iSTAR01/1/I06-RVCC-CFO OFFICE-DSM		Armed	Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
2006-iSTAR01/1/I14-RVCC-CFO OFFICE-REX		Armed	Update Disabled	2000-RVCC CLAREMONT/KEENE/LEBANON
2007-iSTAR01/1/I07-RVCC-TEL-DATA CLOSET-DSM		Armed	Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
2007-iSTAR01/1/I015-RVCC-TEL-DATA CLOSET-REX		Armed	Update Disabled	2000-RVCC CLAREMONT/KEENE/LEBANON
2009-iSTAR01/2/I01-RVCC-CLASSROOM 145-DSM		Armed	Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
2010-iSTAR01/2/I02-RVCC-CLASSROOM 146-DSM		Armed	Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
2011-iSTAR01/2/I03-RVCC-CLASSROOM 147-DSM		Armed	Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
2012-iSTAR01/2/I04-RVCC-CLASSROOM 151-DSM		Armed	Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
2013-iSTAR01/2/I05-RVCC-CLASSROOM 153-DSM		Armed	Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
2014-iSTAR01/2/I06-RVCC-HR OFFICE-DSM		Armed	Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
2009-iSTAR01/2/I09-RVCC-CLASSROOM 145-REX		Armed	Update Disabled	2000-RVCC CLAREMONT/KEENE/LEBANON
2010-iSTAR01/2/I10-RVCC-CLASSROOM 146-REX		Armed	Update Disabled	2000-RVCC CLAREMONT/KEENE/LEBANON
2011-iSTAR01/2/I11-RVCC-CLASSROOM 147-REX		Armed	Update Disabled	2000-RVCC CLAREMONT/KEENE/LEBANON
2012-iSTAR01/2/I12-RVCC-CLASSROOM 151-REX		Armed	Update Disabled	2000-RVCC CLAREMONT/KEENE/LEBANON
2013-iSTAR01/2/I13-RVCC-CLASSROOM 153-REX		Armed	Update Disabled	2000-RVCC CLAREMONT/KEENE/LEBANON
2014-iSTAR01/2/I14-RVCC-HR OFFICE-REX		Armed	Update Disabled	2000-RVCC CLAREMONT/KEENE/LEBANON
2015-iSTAR01/2/I07-RVCC-PRESIDENTS OFFICE-DSM		Armed	Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
2015-iSTAR01/2/I15-RVCC-PRESIDENTS OFFICE-REX		Armed	Update Disabled	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC LEBANON 1ST FL EMPLOYEE ENTRANCE-REX	RVCC LEBANON 1ST FL EMPLOYEE ENTRANCE-REX	Armed	Update Disabled	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC LEBANON 1ST FL EMPLOYEE ENTRANCE-DSM	RVCC LEBANON 1ST FL EMPLOYEE ENTRANCE-DSM	Armed	Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC LEBANON 121 MAIL ROOM-DSM	RVCC LEBANON 121 MAIL ROOM-DSM	Armed	Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC LEBANON 121 MAIL ROOM-REX	RVCC LEBANON 121 MAIL ROOM-REX	Armed	Update Disabled	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC LEBANON 114 IT OFFICE-DSM	RVCC LEBANON 114 IT OFFICE-DSM	Armed	Active	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC LEBANON 114 IT OFFICE-REX	RVCC LEBANON 114 IT OFFICE-REX	Armed	Update Disabled	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC LEBANON 112 CLASSROOM-DSM	RVCC LEBANON 112 CLASSROOM-DSM	Armed	Active	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC LEBANON 112 CLASSROOM-REX	RVCC LEBANON 112 CLASSROOM-REX	Armed	Update Disabled	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC LEBANON 110 CLASSROOM-DSM	RVCC LEBANON 110 CLASSROOM-DSM	Armed	Active	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC LEBANON 110 CLASSROOM-REX	RVCC LEBANON 110 CLASSROOM-REX	Armed	Update Disabled	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC LEBANON 109 CLASSROOM-DSM	RVCC LEBANON 109 CLASSROOM-DSM	Armed	Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC LEBANON 109 CLASSROOM-REX	RVCC LEBANON 109 CLASSROOM-REX	Armed	Update Disabled	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC LEBANON 2ND FL REAR ENTRANCE-DSM	RVCC LEBANON 2ND FL REAR ENTRANCE-DSM	Armed	Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC LEBANON 2ND FL REAR ENTRANCE-REX	RVCC LEBANON 2ND FL REAR ENTRANCE-REX	Armed	Update Disabled	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC LEBANON 2ND FL FRONT ENTRANCE-REX	RVCC LEBANON 2ND FL FRONT ENTRANCE-REX	Armed	Update Disabled	2000-RVCC CLAREMONT/KEENE/LEBANON
Communication Fail-iSTAR Input Board1-ACM1-RVCC LEBANON ISTAR		Armed	Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
Communication Fail-iSTAR Output Board2-ACM1-RVCC LEBANON ISTAR		Armed	Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC LEBANON 1ST FL EMPLOYEE ENTRANCE HANDICAP-BTN		Armed	Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
Communication Fail-iSTAR Output Board1-ACM1-RVCC LEBANON ISTAR		Armed	Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC LEBANON 2ND FL REAR ENTRANCE HANDICAP-BTN		Armed	Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC LEBANON 2ND FL FRONT ENTRANCE HANDICAP-BTN		Armed	Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC LEBANON SIDE STAIR-CONT		Armed	Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
2016-iSTAR01/2/I08-RVCC-CLASSROOM 130-DSM		Armed	Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
2016-iSTAR01/2/I16-RVCC-CLASSROOM 130-REX		Armed	Update Disabled	2000-RVCC CLAREMONT/KEENE/LEBANON

Communication Fail-iSTAR Input Board3-ACM1-RVCC CLAREMONT ISTAR01-1ST FLOOR SERVER ROOM		Armed	Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC CLAREMONT-FRONT DESK LOCKDOWN-BTN		Armed	Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC CLAREMONT-LIBRARY LOCKDOWN-BTN		Armed	Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC CLAREMONT-PRESIDENTS OFFICE LOCKDOWN-BTN		Armed	Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC CLAREMONT-1ST FLOOR MAIN ENTRANCE-DSM		Armed	Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC CLAREMONT-1ST FLOOR MAIN ENTRANCE HANDICAP-BTN		Armed	Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC CLAREMONT-KITCHEN EXTERIOR-DC		Armed	Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC CLAREMONT-KITCHEN EXTERIOR-REX		Armed	Update Disabled	2000-RVCC CLAREMONT/KEENE/LEBANON
Name	Description	Armed status	Active Status	Partition Name
Internal Battery Fault-5000-WMCC-BERLIN-iSTAR EDGE		Armed	Inactive	5000-WMCC BERLIN
WMCC-MAIN ENT-DSM		Armed	Inactive	5000-WMCC BERLIN
WMCC-WELLNESS CENTER-DSM		Armed	Inactive	5000-WMCC BERLIN
WMCC-BACK STAIRWELL-DSM		Armed	Inactive	5000-WMCC BERLIN
WMCC-MAIN ENT-REX		Armed	Update Disabled	5000-WMCC BERLIN
WMCC-WELLNESS CENTER-REX		Armed	Update Disabled	5000-WMCC BERLIN
WMCC-BACK STAIRWELL-REX		Armed	Update Disabled	5000-WMCC BERLIN
WMCC-SIDE STAIRWELL-REX		Armed	Update Disabled	5000-WMCC BERLIN
Communication Fail-COM1iSTAR Output Board1-5000-WMCC-iSTAR EDGE		Armed	Inactive	5000-WMCC BERLIN
WMCC-MAIN OFFICE LOCKDOWN-BTN		Armed	Inactive	5000-WMCC BERLIN
Communication Fail-COM1iSTAR Input Board1-5000-WMCC-iSTAR EDGE		Armed	Inactive	5000-WMCC BERLIN
WMCC-HR OFFICE LOCKDOWN-BTN		Armed	Inactive	5000-WMCC BERLIN
WMCC-CBAO OFFICE LOCKDOWN-BTN		Armed	Inactive	5000-WMCC BERLIN

Output Report summary

Name	Description	Armed status	Active Status	Partition Name
7000-CO-SERVER ROOM FRONT-STR			Inactive	7000-CO
7000-CO-SERVER ROOM REAR-STR			Inactive	7000-CO
7000-CO-BACK ENTRANCE-STR			Inactive	7000-CO
7000-CO-FRONT ENTRANCE-MAG			Inactive	7000-CO
7000-CO-CHECK PRINTER-STR			Inactive	7000-CO
7000-CO-MIDDLE-STR			Inactive	7000-CO
Name	Description	Armed status	Active Status	Partition Name
GBCC-STUDENT CENTER REAR ENT-DSM		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-STUDENT CENTER REAR ENT-REX		Armed	Update Disabled	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-STUDENT CENTER GYM ENT-DSM		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-STUDENT CENTER GYM ENT-REX		Armed	Update Disabled	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-STUDENT CENTER HALLWALL EXIT--DSM		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-STUDENT CENTER HALLWALL ENT--DSM		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-STUDENT CENTER GREEN BEAN REAR ENT-DSM		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-STUDENT CENTER GREEN BEAN REAR ENT-REX		Armed	Update Disabled	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-STUDENT CENTER MAIN ENT-DSM		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-STUDENT CENTER MAIN ENT-REX		Armed	Update Disabled	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-STUDENT CENTER FITNESS CENTER ENT-DSM		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-STUDENT CENTER FITNESS CENTER ENT-REX		Armed	Update Disabled	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-DATA CENTER-DSM		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-LOADING DOCK-DSM		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-LOADING DOCK-REX		Armed	Update Disabled	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-NORTH ENTRANCE-DSM		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-NORTH ENTRANCE-REX		Armed	Update Disabled	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-MAIN ENT-DSM		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-MAIN ENT-REX		Armed	Update Disabled	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-BUSINESS ENT-DSM		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-BUSINESS ENT-REX		Armed	Update Disabled	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-VET TECH ENT-DSM		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-VET TECH ENT-REX		Armed	Update Disabled	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-STUDENT CENTER GYM RIGHT-DSM		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-STUDENT CENTER GYM RIGHT-REX		Armed	Update Disabled	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-STUDENT CENTER ROOM 95-DSM		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-STUDENT CENTER ROOM 95-REX		Armed	Update Disabled	4000-GBCC PORTSMOUTH/ROCHESTER

GBCC-STUDENT CENTER ROOM 96-DSM		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-STUDENT CENTER ROOM 96-REX		Armed	Update Disabled	4000-GBCC PORTSMOUTH/ROCHESTER
iSTAR Input7-4000-GBCC ROCHESTER Administration Lock Down		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
iSTAR Input8-4000-GBCC ROCHESTER Front Desk Lock down		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
Power Failure-GBCC-DATA CENTER ISTAR		Armed	Active	4000-GBCC PORTSMOUTH/ROCHESTER
External Battery Low-GBCC-DATA CENTER ISTAR		Armed	Active	4000-GBCC PORTSMOUTH/ROCHESTER
Power Failure-GBCC-STUDENT CENTER ISTAR		Armed	Active	4000-GBCC PORTSMOUTH/ROCHESTER
External Battery Low-GBCC-STUDENT CENTER ISTAR		Armed	Active	4000-GBCC PORTSMOUTH/ROCHESTER
Power Failure-4000-GBCC ROCHESTER DATA CLOSET ISTAR EDGE		Armed	Active	4000-GBCC PORTSMOUTH/ROCHESTER
External Battery Low-4000-GBCC ROCHESTER DATA CLOSET ISTAR EDGE		Armed	Active	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-STUDENT LIFE ASSISTANT OFFICE 85 LOCKDOWN-BTN		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
Communication Fail-GBCC-DATA CENTER ISTAR-INPUT BOARD 1		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-SECURITY DESK LOCKDOWN-BTN		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-ONE STOP OFFICE AREA LOCKDOWN-BTN		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-PRESIDENTS OFFICE AREA LOCKDOWN-BTN		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-BUSINESS AND TRAINING CENTER LOCKDOWN-BTN		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-HELP DESK/IT DEPT LOCKDOWN-BTN		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-ONE STOP-DSM		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-ONE STOP-REX		Armed	Update Disabled	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-CHEMESTRY LAB NE140-DSM		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-CHEMESTRY LAB NE140-REX		Armed	Update Disabled	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-LIFE SCIENCE NE141-DSM		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-LIFE SCIENCE NE141-REX		Armed	Update Disabled	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-LIFE SCIENCE NE142-DSM		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-LIFE SCIENCE NE142-REX		Armed	Update Disabled	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-LIFE SCIENCE NE143-DSM		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-LIFE SCIENCE NE143-REX		Armed	Update Disabled	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-BIO PREP NE149-DSM		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-BIO PREP NE149-REX		Armed	Update Disabled	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-BIO LAB NE149A-DSM		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-BIO LAB NE149A-REX		Armed	Update Disabled	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-BIO LAB 149C-DSM		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-BIO LAB 149C-REX		Armed	Update Disabled	4000-GBCC PORTSMOUTH/ROCHESTER

GBCC-LOADING DOCK 2-DSM		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-VET TECH NE154-DSM		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-BIOTECH EMERGENCY DOOR-CONT		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-1ST FL IDF NE151 ISTAR INPUT BOARD 1 COMM FAIL		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-NE148 MAINTENANCE-DSM		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-NE148 MAINTENANCE-REX		Armed	Update Disabled	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-LOADING DOCK 2-REX		Armed	Update Disabled	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-VET TECH NE154-REX		Armed	Update Disabled	4000-GBCC PORTSMOUTH/ROCHESTER
Power Failure-GBCC-1ST FL IDF NE151 ISTAR		Armed	Active	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-FITNESS CENTER OFFICE-DSM		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-FITNESS CENTER OFFICE-REX		Armed	Update Disabled	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-STUDENT CENTER DOOR OVER RIDE-BTN		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-DATA CENTER DOOR OVER RIDE-BTN		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
GBCC-1ST FL IDF NE151 DOOR OVER RIDE-BTN		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
Power Failure-GBCC ROCHESTER DATA CLOSET ISTAR EDGE 2		Armed	Active	4000-GBCC PORTSMOUTH/ROCHESTER
External Battery Low-GBCC ROCHESTER DATA CLOSET ISTAR EDGE 2		Armed	Active	4000-GBCC PORTSMOUTH/ROCHESTER
4000-GBCC ROCHESTER WELDING LAB TO CNC LAB-DSM		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
4000-GBCC ROCHESTER WELDING LAB TO CNC LAB-REX		Armed	Update Disabled	4000-GBCC PORTSMOUTH/ROCHESTER
4000-GBCC ROCHESTER VESTIBULE 140 TO WELDING LAB-DSM		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
4000-GBCC ROCHESTER VESTIBULE 140 TO WELDING LAB-REX		Armed	Update Disabled	4000-GBCC PORTSMOUTH/ROCHESTER
4000-GBCC ROCHESTER VESTIBULE 140 TO CNC LAB-DSM		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
4000-GBCC ROCHESTER VESTIBULE 140 TO CNC LAB-REX		Armed	Update Disabled	4000-GBCC PORTSMOUTH/ROCHESTER
iSTAR Input3-4000-GBCC ROCHESTER Main Entrance Intercom Release		Armed	Inactive	4000-GBCC PORTSMOUTH/ROCHESTER
Name	Description	Armed status	Active Status	Partition Name
1001-iSTAR01/ACM1/I01/LRCC-TURNER-DOOR1-DMS		Armed	Inactive	1000-LRCC LACONIA
1002-iSTAR01/ACM1/I02/LRCC-TURNER-DOOR2-DSM		Armed	Inactive	1000-LRCC LACONIA
1003-iSTAR01/ACM1/I03/LRCC-TURNER-DOOR3-DSM		Armed	Inactive	1000-LRCC LACONIA
1004-iSTAR01/ACM1/I04/LRCC-TURNER-DOOR4-DSM		Armed	Inactive	1000-LRCC LACONIA
1005-iSTAR01/ACM1/I05/LRCC-TURNER-DOOR5-DSM		Armed	Inactive	1000-LRCC LACONIA
1001-iSTAR01/ACM1/I09/LRCC-TURNER-DOOR1-REX		Armed	Update Disabled	1000-LRCC LACONIA
1002-iSTAR01/ACM1/I10/LRCC-TURNER-DOOR2-REX		Armed	Update Disabled	1000-LRCC LACONIA
1003-iSTAR01/ACM1/I11/LRCC-TURNER-DOOR3-REX		Armed	Update Disabled	1000-LRCC LACONIA

1004-iSTAR01/ACM1/I12/LRCC-TURNER-DOOR4-REX		Armed	Update Disabled	1000-LRCC LACONIA
1005-iSTAR01/ACM1/I13/LRCC-TURNER-DOOR5-REX		Armed	Update Disabled	1000-LRCC LACONIA
1008-iSTAR01/ACM1/R08I1/LRCC-CAT-DOOR8-DSM		Armed	Inactive	1000-LRCC LACONIA
1008-iSTAR01/ACM1/R08I2/LRCC-CAT-DOOR8-REX		Armed	Update Disabled	1000-LRCC LACONIA
1007-iSTAR01/ACM1/R07I1/LRCC-CAT-DOOR7-DSM		Armed	Inactive	1000-LRCC LACONIA
1007-iSTAR01/ACM1/R07I2/LRCC-CAT-DOOR7-REX		Armed	Update Disabled	1000-LRCC LACONIA
1130-iSTAR01/1I01-LR CAT-G-IT CLOSET-DSM		Armed	Inactive	1000-LRCC LACONIA
1135-iSTAR01/1I02-LR CAT-G-CLASSROOM-DSM		Armed	Inactive	1000-LRCC LACONIA
1136-iSTAR01/1I03-LR CAT-G-NURSE FAC-DSM		Armed	Inactive	1000-LRCC LACONIA
1137-iSTAR01/1I04-LR CAT-G-NURSE FAC-DSM		Armed	Inactive	1000-LRCC LACONIA
1138-iSTAR01/1I05-LR CAT-G-NURSE FAC-DSM		Armed	Inactive	1000-LRCC LACONIA
1140-iSTAR01/1I06-LRCC-CAT-G-ANTE/COPY-DSM		Armed	Inactive	1000-LRCC LACONIA
1130-iSTAR01/1I09-LR CAT-G-IT CLOSET-REX		Armed	Update Disabled	1000-LRCC LACONIA
1135-iSTAR01/1I10-LR CAT-G-CLASSROOM-REX		Armed	Update Disabled	1000-LRCC LACONIA
1136-iSTAR01/1I11-LR CAT-G-NURSE FAC-REX		Armed	Update Disabled	1000-LRCC LACONIA
1138-iSTAR01/1I13-LR CAT-G-NURSE FAC-REX		Armed	Update Disabled	1000-LRCC LACONIA
1137-iSTAR01/1I12-LR CAT-G-NURSE FAC-REX		Armed	Update Disabled	1000-LRCC LACONIA
1140-iSTAR01/1I14-LRCC-CAT-G-ANTE/COPY-REX		Armed	Update Disabled	1000-LRCC LACONIA
1142-iSTAR01/2I01-LRCC-CAT-G-CLASSROOM-DSM		Armed	Inactive	1000-LRCC LACONIA
1147-iSTAR01/2I02-LRCC-CAT-G-SIDE ENT-DSM		Armed	Inactive	1000-LRCC LACONIA
1148-iSTAR01/2I03-LRCC-CAT-G-FACULTY-DSM		Armed	Inactive	1000-LRCC LACONIA
1149-iSTAR01/2I04-LRCC-CAT-G-FACULTY-DSM		Armed	Inactive	1000-LRCC LACONIA
1151-iSTAR01/2I05-LRCC-CAT-G-STORAGE-DSM		Armed	Inactive	1000-LRCC LACONIA
1152A-iSTAR01/2I06-LRCC-CAT-G-CLASSROOM-DSM		Armed	Inactive	1000-LRCC LACONIA
1152B-iSTAR01/2I07-LRCC-CAT-G-CLASSROOM EXT-DSM		Armed	Inactive	1000-LRCC LACONIA
1153A-iSTAR01/2I08-LRCC-CAT-G-CLASSROOM-DSM		Armed	Inactive	1000-LRCC LACONIA
1142-iSTAR01/2I09-LRCC-CAT-G-CLASSROOM-REX		Armed	Update Disabled	1000-LRCC LACONIA
1147-iSTAR01/2I10-LRCC-CAT-G-SIDE ENT-REX		Armed	Inactive	1000-LRCC LACONIA
1148-iSTAR01/2I11-LRCC-CAT-G-FACULTY-REX		Armed	Update Disabled	1000-LRCC LACONIA
1149-iSTAR01/2I12-LRCC-CAT-G-FACULTY-REX		Armed	Update Disabled	1000-LRCC LACONIA
1151-iSTAR01/2I13-LRCC-CAT-G-STORAGE-REX		Armed	Update Disabled	1000-LRCC LACONIA
1152A-iSTAR01/2I14-LRCC-CAT-G-CLASSROOM-REX		Armed	Update Disabled	1000-LRCC LACONIA

1152B-iSTAR01/2I15-LRCC-CAT-G-CLASSROOM EXT-REX		Armed	Update Disabled	1000-LRCC LACONIA
1153A-iSTAR01/2I16-LRCC-CAT-G-CLASSROOM-REX		Armed	Update Disabled	1000-LRCC LACONIA
1153B-iSTAR02/1I01-LRCC-CAT-G-BETWEEN CLASSROOMS-DSM		Armed	Inactive	1000-LRCC LACONIA
1154-iSTAR02/1I02-LRCC-CAT-G-STORAGE-DSM		Armed	Inactive	1000-LRCC LACONIA
1155-iSTAR02/1I03-LRCC-CAT-G-CONFERENCE RM-DSM		Armed	Inactive	1000-LRCC LACONIA
1156-iSTAR02/1I04-LRCC-CAT-G-NURSE STORAGE-DSM		Armed	Inactive	1000-LRCC LACONIA
1157-iSTAR02/1I05-LRCC-CAT-G-NURSE SIM-DSM		Armed	Inactive	1000-LRCC LACONIA
1158-iSTAR02/1I06-LRCC-CAT-G-CONTROL RM-DSM		Armed	Inactive	1000-LRCC LACONIA
1159-iSTAR02/1I07-LRCC-CAT-G-NURSE SIM-DSM		Armed	Inactive	1000-LRCC LACONIA
1160-iSTAR02/1I08-LRCC-CAT-G-NURSE CLASSROOM-DSM		Armed	Inactive	1000-LRCC LACONIA
1153B-iSTAR02/1I09-LRCC-CAT-G-BETWEEN CLASSROOMS-REX		Armed	Update Disabled	1000-LRCC LACONIA
1154-iSTAR02/1I10-LRCC-CAT-G-STORAGE-REX		Armed	Update Disabled	1000-LRCC LACONIA
1155-iSTAR02/1I11-LRCC-CAT-G-CONFERENCE RM-REX		Armed	Update Disabled	1000-LRCC LACONIA
1156-iSTAR02/1I12-LRCC-CAT-G-NURSE STORAGE-REX		Armed	Update Disabled	1000-LRCC LACONIA
1157-iSTAR02/1I13-LRCC-CAT-G-NURSE SIM-REX		Armed	Update Disabled	1000-LRCC LACONIA
1158-iSTAR02/1I14-LRCC-CAT-G-CONTROL RM-REX		Armed	Update Disabled	1000-LRCC LACONIA
1159-iSTAR02/1I15-LRCC-CAT-G-NURSE SIM-REX		Armed	Update Disabled	1000-LRCC LACONIA
1160-iSTAR02/1I16-LRCC-CAT-G-NURSE CLASSROOM-REX		Armed	Update Disabled	1000-LRCC LACONIA
1162-iSTAR02/2I01-LRCC-CAT-G-NURSE STORAGE-DSM		Armed	Inactive	1000-LRCC LACONIA
1163-iSTAR02/2I02-LRCC-CAT-G-MED STORAGE-DSM		Armed	Inactive	1000-LRCC LACONIA
1163A-iSTAR02/2I03-LRCC-CAT-G-NURSE STORAGE-DSM		Armed	Inactive	1000-LRCC LACONIA
1164-iSTAR02/2I04-LRCC-CAT-G-NURSE CLASSROOM-DSM		Armed	Inactive	1000-LRCC LACONIA
1162-iSTAR02/2I09-LRCC-CAT-G-NURSE STORAGE-REX		Armed	Update Disabled	1000-LRCC LACONIA
1163-iSTAR02/2I10-LRCC-CAT-G-MED STORAGE-REX		Armed	Update Disabled	1000-LRCC LACONIA
1163A-iSTAR02/2I11-LRCC-CAT-G-NURSE STORAGE-REX		Armed	Update Disabled	1000-LRCC LACONIA
1164-iSTAR02/2I12-LRCC-CAT-G-NURSE CLASSROOM-REX		Armed	Update Disabled	1000-LRCC LACONIA
1236-iSTAR03/1I01-LRCC-CAT-1ST-ACADEMIC COMMONS-DSM		Armed	Inactive	1000-LRCC LACONIA
1236A-iSTAR03/1I02-LRCC-CAT-1ST-ACADEMIC COMMONS REAR-DSM		Armed	Inactive	1000-LRCC LACONIA
1238-iSTAR03/1I03-LRCC-CAT-1ST-STORAGE-DSM		Armed	Inactive	1000-LRCC LACONIA
1239-iSTAR03/1I04-LRCC-CAT-1ST-KITCHEN-DSM		Armed	Inactive	1000-LRCC LACONIA
1243-iSTAR03/1I05-LRCC-CAT-1ST-CLASSROOM-DSM		Armed	Inactive	1000-LRCC LACONIA
1244-iSTAR03/1I06-LRCC-CAT-1ST-ANTE/COPY-DSM		Armed	Inactive	1000-LRCC LACONIA

1246-iSTAR03/1I07-LRCC-CAT-1ST-BIO/MICRO FAC-DSM		Armed	Inactive	1000-LRCC LACONIA
1247-iSTAR03/1I08-LRCC-CAT-1ST-PHYSICS STORAGE-DSM		Armed	Inactive	1000-LRCC LACONIA
1236-iSTAR03/1I09-LRCC-CAT-1ST-ACADEMIC COMMONS-REX		Armed	Update Disabled	1000-LRCC LACONIA
1236A-iSTAR03/1I10-LRCC-CAT-1ST-ACADEMIC COMMONS REAR-REX		Armed	Update Disabled	1000-LRCC LACONIA
1238-iSTAR03/1I11-LRCC-CAT-1ST-STORAGE-REX		Armed	Update Disabled	1000-LRCC LACONIA
1239-iSTAR03/1I12-LRCC-CAT-1ST-KITCHEN-REX		Armed	Update Disabled	1000-LRCC LACONIA
1243-iSTAR03/1I13-LRCC-CAT-1ST-CLASSROOM-REX		Armed	Update Disabled	1000-LRCC LACONIA
1244-iSTAR03/1I14-LRCC-CAT-1ST-ANTE/COPY-REX		Armed	Update Disabled	1000-LRCC LACONIA
1246-iSTAR03/1I15-LRCC-CAT-1ST-BIO/MICRO FAC-REX		Armed	Update Disabled	1000-LRCC LACONIA
1247-iSTAR03/1I16-LRCC-CAT-1ST-PHYSICS STORAGE-REX		Armed	Update Disabled	1000-LRCC LACONIA
1248-iSTAR03/2I01-LRCC-CAT-1ST-PHYSICS FAC-DSM		Armed	Inactive	1000-LRCC LACONIA
1249-iSTAR03/2I02-LRCC-CAT-1ST-PHYSICS LAB-DSM		Armed	Inactive	1000-LRCC LACONIA
1255-iSTAR03/2I03-LRCC-CAT-1ST-CONF RM-DSM		Armed	Inactive	1000-LRCC LACONIA
1256-iSTAR03/2I04-LRCC-CAT-1ST-CHEM STORAGE-DSM		Armed	Inactive	1000-LRCC LACONIA
1257-iSTAR03/2I05-LRCC-CAT-1ST-CHEM PREP-DSM		Armed	Inactive	1000-LRCC LACONIA
1258-iSTAR03/2I06-LRCC-CAT-1ST-CHEM LAB-DSM		Armed	Inactive	1000-LRCC LACONIA
1260A-iSTAR03/2I07-LRCC-CAT-1ST-PREP STORAGE-DSM		Armed	Inactive	1000-LRCC LACONIA
1260B-iSTAR03/2I08-LRCC-CAT-1ST-PREP STORAGE-DSM		Armed	Inactive	1000-LRCC LACONIA
1248-iSTAR03/2I09-LRCC-CAT-1ST-PHYSICS FAC-REX		Armed	Update Disabled	1000-LRCC LACONIA
1249-iSTAR03/2I10-LRCC-CAT-1ST-PHYSICS LAB-REX		Armed	Update Disabled	1000-LRCC LACONIA
1255-iSTAR03/2I11-LRCC-CAT-1ST-CONF RM-REX		Armed	Update Disabled	1000-LRCC LACONIA
1256-iSTAR03/2I12-LRCC-CAT-1ST-CHEM STORAGE-REX		Armed	Update Disabled	1000-LRCC LACONIA
1257-iSTAR03/2I13-LRCC-CAT-1ST-CHEM PREP-REX		Armed	Update Disabled	1000-LRCC LACONIA
1258-iSTAR03/2I14-LRCC-CAT-1ST-CHEM LAB-REX		Armed	Update Disabled	1000-LRCC LACONIA
1260A-iSTAR03/2I15-LRCC-CAT-1ST-PREP STORAGE-REX		Armed	Update Disabled	1000-LRCC LACONIA
1260B-iSTAR03/2I16-LRCC-CAT-1ST-PREP STORAGE-REX		Armed	Update Disabled	1000-LRCC LACONIA
1261A-iSTAR04/1I01-LRCC-CAT-1ST-261 TO 158 CLASSROOM-DSM		Armed	Inactive	1000-LRCC LACONIA
1261B-iSTAR04/1I02-LRCC-CAT-1ST-MICRO/BIO LAB-DSM		Armed	Inactive	1000-LRCC LACONIA
1261C-iSTAR04/1I03-LRCC-CAT-1ST-MICRO/BIO LAB-DSM		Armed	Inactive	1000-LRCC LACONIA
1262A-iSTAR04/1I04-LRCC-CAT-1ST-MICRO/BIO PREP-DSM		Armed	Inactive	1000-LRCC LACONIA
1262B-iSTAR04/1I05-LRCC-CAT-1ST-MICRO/BIO PREP-DSM		Armed	Inactive	1000-LRCC LACONIA

1263A-iSTAR04/1I06-LRCC-CAT-1ST-BIO LAB-DSM		Armed	Inactive	1000-LRCC LACONIA
1263B-iSTAR04/1I07-LRCC-CAT-1ST-BIO LAB-DSM		Armed	Inactive	1000-LRCC LACONIA
1264A-iSTAR04/1I08-LRCC-CAT-1ST-PREP STORAGE-DSM		Armed	Inactive	1000-LRCC LACONIA
1261A-iSTAR04/1I09-LRCC-CAT-1ST-261 TO 158 CLASSROOM-REX		Armed	Update Disabled	1000-LRCC LACONIA
1261B-iSTAR04/1I10-LRCC-CAT-1ST-MICRO/BIO LAB-REX		Armed	Update Disabled	1000-LRCC LACONIA
1261C-iSTAR04/1I11-LRCC-CAT-1ST-MICRO/BIO LAB-REX		Armed	Update Disabled	1000-LRCC LACONIA
1262A-iSTAR04/1I12-LRCC-CAT-1ST-MICRO/BIO PREP-REX		Armed	Update Disabled	1000-LRCC LACONIA
1262B-iSTAR04/1I13-LRCC-CAT-1ST-MICRO/BIO PREP-REX		Armed	Update Disabled	1000-LRCC LACONIA
1263A-iSTAR04/1I14-LRCC-CAT-1ST-BIO LAB-REX		Armed	Update Disabled	1000-LRCC LACONIA
1263B-iSTAR04/1I15-LRCC-CAT-1ST-BIO LAB-REX		Armed	Update Disabled	1000-LRCC LACONIA
1264A-iSTAR04/1I16-LRCC-CAT-1ST-PREP STORAGE-REX		Armed	Update Disabled	1000-LRCC LACONIA
1264B-iSTAR04/2I01-LRCC-CAT-1ST-PREP STORAGE-DSM		Armed	Inactive	1000-LRCC LACONIA
1265-iSTAR04/2I02-LRCC-CAT-1ST-STORAGE-DSM		Armed	Inactive	1000-LRCC LACONIA
1234-iSTAR04/2I03-LRCC-CAT-1ST-MAIN ENT-DSM		Armed	Inactive	1000-LRCC LACONIA
1264B-iSTAR04/2I09-LRCC-CAT-1ST-PREP STORAGE-REX		Armed	Update Disabled	1000-LRCC LACONIA
1265-iSTAR04/2I10-LRCC-CAT-1ST-STORAGE-REX		Armed	Update Disabled	1000-LRCC LACONIA
1234-iSTAR04/2I11-LRCC-CAT-1ST-MAIN ENT-REX		Armed	Update Disabled	1000-LRCC LACONIA
1008-iSTAR01/ACM1/I06-LRCC-TURNER-MAINT SHOP-DSM		Armed	Inactive	1000-LRCC LACONIA
1008-iSTAR01/ACM1/I06-LRCC-TURNER-MAINT SHOP-REX		Armed	Update Disabled	1000-LRCC LACONIA
LRCC OLD BUILDING ISTAR 1 LOCK DOORS-BTN	LRCC OLD BUILDING ISTAR 1 LOCK DOORS-BTN BUTTON IS ON THE ISTAR DOOR TO LOCK ALL DOORS ON THE PANEL INCASE OF NETWORK FAILURE	Armed	Inactive	1000-LRCC LACONIA

LRCC-CAT BUILDING ISTAR 1 AND 2 DOOR LOCK-BTN	LRCC-CAT BUILDING ISTAR 1 AND 2 DOOR LOCK-BTN BUTTON IS ON THE ISTAR DOOR TO LOCK ALL DOORS ON THE PANEL INCASE OF NETWORK FAILURE	Armed	Inactive	1000-LRCC LACONIA
LRCC-CAT BUILDING ISTAR 4 AND 4 DOOR LOCK-BTN	LRCC-CAT BUILDING ISTAR 4 AND 4 DOOR LOCK-BTN BUTTON LOCATED ON ISTAR 3 IN CAT BUILDING TO LOCK DOORS INCASE OF NETWORK LOSS	Armed	Inactive	1000-LRCC LACONIA
LRCC-AUTOMOTIVE REAR MAN DOOR-DSM	LRCC-AUTOMOTIVE REAR MAN DOOR-DSM	Armed	Inactive	1000-LRCC LACONIA
LRCC-AUTOMOTIVE REAR MAN DOOR-REX	LRCC-AUTOMOTIVE REAR MAN DOOR-REX	Armed	Update Disabled	1000-LRCC LACONIA
LRCC-AUTOMOTIVE MAIN LOBBY HC BUTTON-TRIP	LRCC-AUTOMOTIVE MAIN LOBBY HC BUTTON-TRIP	Armed	Inactive	1000-LRCC LACONIA
LRCC-AUTOMOTIVE MAIN ENTRANCE-DSM	LRCC-AUTOMOTIVE MAIN ENTRANCE-DSM	Armed	Inactive	1000-LRCC LACONIA
LRCC-AUTOMOTIVE MAIN ENTRANCE-REX	LRCC-AUTOMOTIVE MAIN ENTRANCE-REX	Armed	Update Disabled	1000-LRCC LACONIA
LRCC-AUTOMOTIVE MAIN LOBBY-DSM	LRCC-AUTOMOTIVE MAIN LOBBY-DSM	Armed	Inactive	1000-LRCC LACONIA

LRCC-AUTOMOTIVE MAIN LOBBY-REX	LRCC-AUTOMOTIVE MAIN LOBBY-REX	Armed	Update Disabled	1000-LRCC LACONIA
LRCC-AUTOMOTIVE CLASSROOM/LAB 115-DSM	LRCC-AUTOMOTIVE CLASSROOM/LAB 115-DSM	Armed	Inactive	1000-LRCC LACONIA
LRCC-AUTOMOTIVE CLASSROOM/LAB 115-REX	LRCC-AUTOMOTIVE CLASSROOM/LAB 115-REX	Armed	Update Disabled	1000-LRCC LACONIA
LRCC-AUTOMOTIVE CLASSROOM/LAB 114-DSM	LRCC-AUTOMOTIVE CLASSROOM/LAB 114-DSM	Armed	Inactive	1000-LRCC LACONIA
LRCC-AUTOMOTIVE CLASSROOM/LAB 114-REX	LRCC-AUTOMOTIVE CLASSROOM/LAB 114-REX	Armed	Update Disabled	1000-LRCC LACONIA
Communication Fail-iSTAR Output Board1-ACM1-LRCC-AUTOMOTIVE ISTAR		Armed	Inactive	1000-LRCC LACONIA
Communication Fail-iSTAR Input Board1-ACM1-LRCC-AUTOMOTIVE ISTAR		Armed	Inactive	1000-LRCC LACONIA
LRCC-AUTOMOTIVE REAR OVERHEAD-CONT	LRCC-AUTOMOTIVE REAR OVERHEAD-CONT	Armed	Inactive	1000-LRCC LACONIA
LRCC-AUTOMOTIVE CLASSROOM/LAB 115 OVERHEAD-CONT	LRCC-AUTOMOTIVE CLASSROOM/LAB 115 OVERHEAD-CONT	Armed	Inactive	1000-LRCC LACONIA
LRCC-AUTOMOTIVE CLASSROOM/LAB 114 OVERHEAD-CONT	LRCC-AUTOMOTIVE CLASSROOM/LAB 114 OVERHEAD-CONT	Armed	Inactive	1000-LRCC LACONIA
LRCC-EXT DOOR NEAR ROOM 113-DSM	LRCC-EXT DOOR NEAR ROOM 113-DSM	Armed	Active	1000-LRCC LACONIA
LRCC-EXT DOOR NEAR ROOM 113-REX	LRCC-EXT DOOR NEAR ROOM 113-REX	Armed	Update Disabled	1000-LRCC LACONIA

LRCC-AUTOMOTIVE BOILER-ALARM	LRCC-AUTOMOTIVE BOILER-ALARM	Armed	Inactive	1000-LRCC LACONIA
LRCC-EXT DOOR NEAR ROOM 124-DSM	LRCC-EXT DOOR NEAR ROOM 124-DSM	Armed	Inactive	1000-LRCC LACONIA
LRCC-EXT DOOR NEAR ROOM 124-REX	LRCC-EXT DOOR NEAR ROOM 124-REX	Armed	Update Disabled	1000-LRCC LACONIA
LRCC-CAT-1ST FLOOR EXT NEAR ROOM 124-DSM	LRCC-CAT-1ST FLOOR EXT NEAR ROOM 124-DSM	Armed	Inactive	1000-LRCC LACONIA
LRCC-CAT-1ST FLOOR EXT NEAR ROOM 124-REX	LRCC-CAT-1ST FLOOR EXT NEAR ROOM 124-REX	Armed	Update Disabled	1000-LRCC LACONIA
LRCC-AUTOMOTIVE IT CLOSET-DSM	LRCC-AUTOMOTIVE IT CLOSET-DSM	Armed	Inactive	1000-LRCC LACONIA
LRCC-AUTOMOTIVE IT CLOSET-REX	LRCC-AUTOMOTIVE IT CLOSET-REX	Armed	Update Disabled	1000-LRCC LACONIA
Wireless Reader Tamper - LRCC-AUTOMOTIVE IT CLOSET		Armed	Inactive	1000-LRCC LACONIA
Low Battery - LRCC-AUTOMOTIVE IT CLOSET		Armed	Inactive	1000-LRCC LACONIA
Manual Lock Override - LRCC-AUTOMOTIVE IT CLOSET		Armed	Inactive	1000-LRCC LACONIA
Push Button - LRCC-AUTOMOTIVE IT CLOSET		Unknown	Unknown	1000-LRCC LACONIA
LRCC-AUTOMOTIVE BOILER ROOM-DSM	LRCC-AUTOMOTIVE BOILER ROOM-DSM	Armed	Inactive	1000-LRCC LACONIA
LRCC-AUTOMOTIVE BOILER ROOM-REX	LRCC-AUTOMOTIVE BOILER ROOM-REX	Armed	Update Disabled	1000-LRCC LACONIA
Wireless Reader Tamper - LRCC-AUTOMOTIVE BOILER ROOM		Armed	Inactive	1000-LRCC LACONIA
Low Battery - LRCC-AUTOMOTIVE BOILER ROOM		Armed	Inactive	1000-LRCC LACONIA
Manual Lock Override - LRCC-AUTOMOTIVE BOILER ROOM		Armed	Inactive	1000-LRCC LACONIA
Push Button - LRCC-AUTOMOTIVE BOILER ROOM		Unknown	Unknown	1000-LRCC LACONIA
LRCC-AUTOMOTIVE STORAGE ROOM 103-DSM		Armed	Inactive	1000-LRCC LACONIA

LRCC-AUTOMOTIVE STORAGE ROOM 103-REX	LRCC-AUTOMOTIVE STORAGE ROOM 103-REX	Armed	Update Disabled	1000-LRCC LACONIA
Wireless Reader Tamper - LRCC-AUTOMOTIVE STORAGE ROOM		Armed	Inactive	1000-LRCC LACONIA
Low Battery - LRCC-AUTOMOTIVE STORAGE ROOM		Armed	Inactive	1000-LRCC LACONIA
Manual Lock Override - LRCC-AUTOMOTIVE STORAGE ROOM		Armed	Inactive	1000-LRCC LACONIA
Push Button - LRCC-AUTOMOTIVE STORAGE ROOM		Unknown	Unknown	1000-LRCC LACONIA
LRCC-AUTOMOTIVE ADMIN OFFICE-DSM	LRCC-AUTOMOTIVE ADMIN OFFICE-DSM	Armed	Inactive	1000-LRCC LACONIA
LRCC-AUTOMOTIVE ADMIN OFFICE-REX	LRCC-AUTOMOTIVE ADMIN OFFICE-REX	Armed	Update Disabled	1000-LRCC LACONIA
Wireless Reader Tamper - LRCC-AUTOMOTIVE ADMIN OFFICE		Armed	Inactive	1000-LRCC LACONIA
Low Battery - LRCC-AUTOMOTIVE ADMIN OFFICE		Armed	Inactive	1000-LRCC LACONIA
Manual Lock Override - LRCC-AUTOMOTIVE ADMIN OFFICE		Armed	Inactive	1000-LRCC LACONIA
Push Button - LRCC-AUTOMOTIVE ADMIN OFFICE		Unknown	Unknown	1000-LRCC LACONIA
LRCC-AUTOMOTIVE CLASSROOM 113-DSM	LRCC-AUTOMOTIVE CLASSROOM 113-DSM	Armed	Inactive	1000-LRCC LACONIA
LRCC-AUTOMOTIVE CLASSROOM 113-REX	LRCC-AUTOMOTIVE CLASSROOM 113-REX	Armed	Update Disabled	1000-LRCC LACONIA
Low Battery - LRCC DOOR 2-RDR		Armed	Inactive	1000-LRCC LACONIA
Manual Lock Override - LRCC DOOR 2-RDR		Armed	Inactive	1000-LRCC LACONIA
Push Button - LRCC DOOR 2-RDR		Unknown	Unknown	1000-LRCC LACONIA
LRCC-AUTOMOTIVE STORAGE ROOM 110-DSM	LRCC-AUTOMOTIVE STORAGE ROOM 110-DSM	Armed	Inactive	1000-LRCC LACONIA
LRCC-AUTOMOTIVE STORAGE ROOM 110-REX	LRCC-AUTOMOTIVE STORAGE ROOM 110-REX	Armed	Update Disabled	1000-LRCC LACONIA
Wireless Reader Tamper - LRCC DOOR 3-RDR		Armed	Inactive	1000-LRCC LACONIA
Low Battery - LRCC DOOR 3-RDR		Armed	Inactive	1000-LRCC LACONIA
Manual Lock Override - LRCC DOOR 3-RDR		Armed	Inactive	1000-LRCC LACONIA
Push Button - LRCC DOOR 3-RDR		Unknown	Unknown	1000-LRCC LACONIA

LRCC-AUTOMOTIVE CLASSROOM 115-DSM	LRCC-AUTOMOTIVE CLASSROOM 115-DSM	Armed	Inactive	1000-LRCC LACONIA
LRCC-AUTOMOTIVE CLASSROOM 115-REX	LRCC-AUTOMOTIVE CLASSROOM 115-REX	Armed	Update Disabled	1000-LRCC LACONIA
Wireless Reader Tamper - LRCC DOOR 4-RDR		Armed	Inactive	1000-LRCC LACONIA
Low Battery - LRCC DOOR 4-RDR		Armed	Inactive	1000-LRCC LACONIA
Manual Lock Override - LRCC DOOR 4-RDR		Armed	Inactive	1000-LRCC LACONIA
Push Button - LRCC DOOR 4-RDR		Armed	Inactive	1000-LRCC LACONIA
LRCC-AUTOMOTIVE CLASSROOM 114-DSM	LRCC-AUTOMOTIVE CLASSROOM 114-DSM	Armed	Active	1000-LRCC LACONIA
LRCC-AUTOMOTIVE CLASSROOM 114-REX	LRCC-AUTOMOTIVE CLASSROOM 114-REX	Armed	Update Disabled	1000-LRCC LACONIA
Low Battery - LRCC DOOR 1-RDR		Armed	Inactive	1000-LRCC LACONIA
Manual Lock Override - LRCC DOOR 1-RDR		Armed	Inactive	1000-LRCC LACONIA
Push Button - LRCC DOOR 1-RDR		Unknown	Unknown	1000-LRCC LACONIA
Wireless Reader Tamper - LRCC-AUTOMOTIVE CLASSROOM 113-RDR		Armed	Inactive	1000-LRCC LACONIA
Wireless Reader Tamper - LRCC DOOR 1-RDR		Armed	Inactive	1000-LRCC LACONIA
LRCC-AUTOMOTIVE LOCKDOWN-BTN		Armed	Inactive	1000-LRCC LACONIA
LRCC ISTAR 03 OUTPUT BOARD COMM FAIL		Armed	Active	1000-LRCC LACONIA
000000TEST		Armed	Inactive	1000-LRCC LACONIA
iSTAR04/2I04-LRCC-CAT BUILDING-LOCKDOWN BUTTON		Armed	Inactive	1000-LRCC LACONIA
Name	Description	Armed status	Active Status	Partition Name
MCC-A KNOX BLDG 2ND FLOOR ENTRANCE-MAG	MCC-A KNOX BLDG 2ND FLOOR ENTRANCE-MAG		Inactive	3000-MCC MANCHESTER
MCC-231 AMT LAB-STR	MCC-231 AMT LAB-STR		Inactive	3000-MCC MANCHESTER
MCC-235 COMPUTER SCIENCE CLASSROOM-STR	MCC-235 COMPUTER SCIENCE CLASSROOM-STR		Inactive	3000-MCC MANCHESTER
MCC-243 EXERCISE CLASSROOM-STR	MCC-243 EXERCISE CLASSROOM-STR		Inactive	3000-MCC MANCHESTER

MCC-241 EXERCISE SCIENCE LAB LEFT-STR	MCC-241 EXERCISE SCIENCE LAB LEFT-STR		Inactive	3000-MCC MANCHESTER
MCC-241 EXERCISE SCIENCE LAB RIGHT-STR	MCC-241 EXERCISE SCIENCE LAB RIGHT-STR		Inactive	3000-MCC MANCHESTER
MCC-237 COMPUTER CLASSROOM-STR	MCC-237 COMPUTER CLASSROOM-STR		Inactive	3000-MCC MANCHESTER
MCC-CHILD DEVELOPMENT CENTER REAR ENTRANCE-MAG	MCC-CHILD DEVELOPMENT CENTER REAR ENTRANCE-MAG		Inactive	3000-MCC MANCHESTER
MCC-CHILD DEVELOPMENT CENTER MAIN ENTRANCE-MAG	MCC-CHILD DEVELOPMENT CENTER MAIN ENTRANCE-MAG		Inactive	3000-MCC MANCHESTER
MCC-253 COMPUTER LAB-STR	MCC-253 COMPUTER LAB-STR		Inactive	3000-MCC MANCHESTER
MCC-COMPUTER/EXERCISE HALL ENTRANCE-CB	MCC-COMPUTER/EXERCISE HALL ENTRANCE-CB		Inactive	3000-MCC MANCHESTER
MCC-231 AMT LAB EMERGENCY EXIT-HORN	MCC-231 AMT LAB EMERGENCY EXIT-HORN		Inactive	3000-MCC MANCHESTER
MCC-249 MARKETING EMERGENCY EXIT-HORN	MCC-249 MARKETING EMERGENCY EXIT-HORN		Inactive	3000-MCC MANCHESTER
MCC-259-1 CHILD DEVELOPMENT CENTER EMERGENCY EXIT-HORN	MCC-259-1 CHILD DEVELOPMENT CENTER EMERGENCY EXIT-HORN		Inactive	3000-MCC MANCHESTER
MCC-CHILD DEVELOPMENT CENTER MAIN ENT-HORN	MCC-CHILD DEVELOPMENT CENTER MAIN ENT-HORN		Inactive	3000-MCC MANCHESTER

MCC-259-3 CHILD DEVELOPMENT CENTER EMERGENCY EXIT-HORN	MCC-259-3 CHILD DEVELOPMENT CENTER EMERGENCY EXIT-HORN		Inactive	3000-MCC MANCHESTER
MCC-259-4 CHILD DEVELOPMENT CENTER EMERGENCY EXIT-HORN	MCC-259-4 CHILD DEVELOPMENT CENTER EMERGENCY EXIT-HORN		Inactive	3000-MCC MANCHESTER
MCC-2 KNOX HALL DOOR 2 MAG BYPASS-RLY	MCC-2 KNOX HALL DOOR 2 MAG BYPASS-RLY		Inactive	3000-MCC MANCHESTER
MCC-2 KNOX HALL DOOR 1 MAG BYPASS-RLY	MCC-2 KNOX HALL DOOR 1 MAG BYPASS-RLY		Inactive	3000-MCC MANCHESTER
MCC-321 NURSING LAB RIGHT-STR	MCC-321 NURSING LAB RIGHT-STR		Inactive	3000-MCC MANCHESTER
MCC-321 NURSING LAB LEFT-STR	MCC-321 NURSING LAB LEFTSTR		Inactive	3000-MCC MANCHESTER
MCC-325 COMPUTER LAB-STR	MCC-325 COMPUTER LAB-STR		Inactive	3000-MCC MANCHESTER
MCC-327 MEDICAL ASSISTING LAB RIGHT-STR	MCC-327 MEDICAL ASSISTING LAB RIGHT-STR		Inactive	3000-MCC MANCHESTER
MCC-327 MEDICAL ASSISTING LAB LEFT-STR	MCC-327 MEDICAL ASSISTING LAB LEFT-STR		Inactive	3000-MCC MANCHESTER
MCC-HSCI TO UPPER CAFE MAG BYPASS-RLY	MCC-HSCI TO UPPER CAFE MAG BYPASS-RLY		Inactive	3000-MCC MANCHESTER
MCC-258 HUMAN RESOURCES-STR	MCC-258 HUMAN RESOURCES-STR		Inactive	3000-MCC MANCHESTER
MCC-MAIN LOBBY-STR	MCC-MAIN LOBBY-STR		Inactive	3000-MCC MANCHESTER

MCC-285 MICROBIOLOGY LAB-STR	MCC-285 MICROBIOLOGY LAB-STR		Inactive	3000-MCC MANCHESTER
MCC-289 SCIENCE LAB-STR	MCC-289 SCIENCE LAB-STR		Inactive	3000-MCC MANCHESTER
MCC-295 SCIENCE LAB-STR	MCC-295 SCIENCE LAB-STR		Inactive	3000-MCC MANCHESTER
MCC-297 PHYSICS/EARTH SCIENCE LAB-STR	MCC-297 PHYSICS/EARTH SCIENCE LAB-STR		Inactive	3000-MCC MANCHESTER
MCC-HSCI SIDE ENTRANCE-STR	MCC-HSCI SIDE ENTRANCE-STR		Inactive	3000-MCC MANCHESTER
MCC-276 COMPUTER LAB-STR	MCC-276 COMPUTER LAB-STR		Inactive	3000-MCC MANCHESTER
MCC-279 CHEMISTRY LAB LEFT-STR	MCC-279 CHEMISTRY LAB LEFT-STR		Inactive	3000-MCC MANCHESTER
MCC-279 CHEMISTRY LAB RIGHT-STR	MCC-279 CHEMISTRY LAB RIGHT-STR		Inactive	3000-MCC MANCHESTER
MCC-268 LIBRARY-CB	MCC-268 LIBRARY-CB		Inactive	3000-MCC MANCHESTER
MCC-287 BOILER ROOM EMERGENCY EXIT-HORN	MCC-287 BOILER ROOM EMERGENCY EXIT-HORN		Inactive	3000-MCC MANCHESTER
MCC-297 PHYSICS/EARTH SCIENCE LAB EMERGENCY EXIT-HORN	MCC-297 PHYSICS/EARTH SCIENCE LAB EMERGENCY EXIT-HORN		Inactive	3000-MCC MANCHESTER
MCC-268 LIBRARY EMERGENCY EXIT LEFT-HORN	MCC-268 LIBRARY EMERGENCY EXIT LEFT-HORN		Inactive	3000-MCC MANCHESTER
MCC-268 LIBRARY EMERGENCY EXIT RIGHT-HORN	MCC-268 LIBRARY EMERGENCY EXIT RIGHT-HORN		Inactive	3000-MCC MANCHESTER
MCC-225-1 METALLURGY LABLEFT-STR	MCC-225-1 METALLURGY LAB LEFT-STR		Inactive	3000-MCC MANCHESTER

MCC-225-METALLURGY LAB RIGHT-STR	MCC-225-METALLURGY LAB RIGHT-STR		Inactive	3000-MCC MANCHESTER
MCC-219 COMPUTER LAB-STR	MCC-219 COMPUTER LAB-STR		Inactive	3000-MCC MANCHESTER
MCC-222-COMPUTER LAB RIGHT-STR	MCC-222-COMPUTER LAB RIGHT-STR		Inactive	3000-MCC MANCHESTER
MCC-222-COMPUTER LAB LEFT-STR	MCC-222-COMPUTER LAB LEFT-STR		Inactive	3000-MCC MANCHESTER
MCC-217 ELECTRICAL TECH LAB-STR	MCC-217 ELECTRICAL TECH LAB-STR		Inactive	3000-MCC MANCHESTER
MCC-215-ELECTRICAL TECH LAB LEFT-STR	MCC-215-ELECTRICAL TECH LAB LEFT-STR		Inactive	3000-MCC MANCHESTER
MCC-215-ELECTRICAL TECH LAB RIGHT-STR	MCC-215-ELECTRICAL TECH LAB RIGHT-STR		Inactive	3000-MCC MANCHESTER
MCC-216 COMPUTER LAB-STR	MCC-216 COMPUTER LAB-STR		Inactive	3000-MCC MANCHESTER
MCC-211 WELDING LAB-STR	MCC-211 WELDING LAB-STR		Inactive	3000-MCC MANCHESTER
MCC-209 HVAC-STR	MCC-209 HVAC-STR		Inactive	3000-MCC MANCHESTER
MCC-207 HVAC CLASSROOM-STR	MCC-207 HVAC CLASSROOM-STR		Inactive	3000-MCC MANCHESTER
MCC-203 CAD LAB-STR	MCC-203 CAD LAB-STR		Inactive	3000-MCC MANCHESTER
MCC-133-WELDING LAB-STR	MCC-133-WELDING LAB-STR		Inactive	3000-MCC MANCHESTER
MCC-133-WELDING LAB REAR-STR	MCC-133-WELDING LAB REAR-STR		Inactive	3000-MCC MANCHESTER
MCC-135-AIR CON LAB--MAG	MCC-135-AIR CON LAB-MAG		Inactive	3000-MCC MANCHESTER
MCC-135-AIR CON LAB REAR-MAG	MCC-135-AIR CON LAB REAR-MAG		Inactive	3000-MCC MANCHESTER
MCC-137-HEATING LAB-MAG	MCC-137-HEATING LAB-MAG		Inactive	3000-MCC MANCHESTER
MCC-137-HEATING LAB REAR-MAG	MCC-137-HEATING LAB REAR-MAG		Inactive	3000-MCC MANCHESTER

MCC-139-BUILDING CONSTRUCTION-MAG	MCC-139-BUILDING CONSTRUCTION-MAG		Inactive	3000-MCC MANCHESTER
MCC-139-BUILDING CONSTRUCTION REAR-STR	MCC-139-BUILDING CONSTRUCTION REAR-STR		Inactive	3000-MCC MANCHESTER
MCC-GYM EMERGENCY EXIT LEFT-HORN	MCC-GYM EMERGENCY EXIT LEFT-HORN		Inactive	3000-MCC MANCHESTER
MCC-CAFE SERVING AREA EMERGENCY EXIT-HORN	MCC-CAFE SERVING AREA EMERGENCY EXIT-HORN		Inactive	3000-MCC MANCHESTER
MCC-CAFE SITTING AREA EXIT-STR	MCC-CAFE SITTING AREA EXIT-STR		Active	3000-MCC MANCHESTER
MCC-PRESIDENTS OFFICE-STR	MCC-PRESIDENTS OFFICE-STR		Inactive	3000-MCC MANCHESTER
MCC-VAULT-STR	MCC-VAULT-STR		Inactive	3000-MCC MANCHESTER
MCC-GYM EMERGENCY EXIT RIGHT-HORN	MCC-GYM EMERGENCY EXIT RIGHT-HORN		Inactive	3000-MCC MANCHESTER
MCC-STUDENT SERVICES EMERGENCY EXIT-HORN	MCC-STUDENT SERVICES EMERGENCY EXIT-HORN		Inactive	3000-MCC MANCHESTER
MCC-KH2-3 HALL DOOR MAG BYPASS-RLY	MCC-KH2-3 HALL DOOR MAG BYPASS-RLY		Inactive	3000-MCC MANCHESTER
MCC-LECTURE HALL EMERGENCY EXIT-HORN	MCC-LECTURE HALL EMERGENCY EXIT-HORN		Inactive	3000-MCC MANCHESTER
MCC-C BUILDING STAIR 1 EMERGENCY EXIT-HORN	MCC-C BUILDING STAIR 1 EMERGENCY EXIT-HORN		Inactive	3000-MCC MANCHESTER
MCC-C BUILDING STAIR 2 EMERGENCY EXIT-HORN	MCC-C BUILDING STAIR 2 EMERGENCY EXIT-HORN		Inactive	3000-MCC MANCHESTER

MCC-Entrance 43 Doors A & B	aka MCC-NORTH WING 1ST FL ENTRANCE LEFT-STR		Active	3000-MCC MANCHESTER
MCC-CENTRAL WING ENTRANCE DOOR 1ST FLOOR-CB	MCC-CENTRAL WING ENTRANCE DOOR 1ST FLOOR-CB		Inactive	3000-MCC MANCHESTER
MCC-106 GRAPHIC DESIGN LAB-STR	MCC-106 GRAPHIC DESIGN LAB-STR		Inactive	3000-MCC MANCHESTER
MCC-108 ART AND DESIGN LAB-STR	MCC-108 ART AND DESIGN LAB-STR		Inactive	3000-MCC MANCHESTER
MCC-110 ART AND DESIGN LAB-STR	MCC-110 ART AND DESIGN LAB-STR		Inactive	3000-MCC MANCHESTER
MCC-100 LECTURE HALL EMERGENCY EXIT-HORN	MCC-100 LECTURE HALL EMERGENCY EXIT-HORN		Inactive	3000-MCC MANCHESTER
MCC-102 GRAPHIC DESIGN EMERGENCY EXIT-HORN	MCC-102 GRAPHIC DESIGN EMERGENCY EXIT-HORN		Inactive	3000-MCC MANCHESTER
MCC-2ND FL HSCI HALL DOOR-STR	MCC-2ND FL HSCI HALL DOORSTR		Active	3000-MCC MANCHESTER
MCC-141 BUILDING CONSTRUCTION REAR-STR	MCC-141 BUILDING CONSTRUCTION REAR-STR		Inactive	3000-MCC MANCHESTER
MCC-MAIN LOBBY DOOR C,D, E and F-STR	MCC-MAIN LOBBY RIGHT/LEFT DOOR--STR. Center and Right doors when standing outside the building		Active	3000-MCC MANCHESTER
MCC-GYM GLASS DOORS-MAG	MCC-GYM GLASS DOORS-MAG		Active	3000-MCC MANCHESTER

MCC-CAFE EMPLOYEE ENTRANCE-STR	MCC-CAFE EMPLOYEE ENTRANCE-STR		Inactive	3000-MCC MANCHESTER
MCC-1B-1 HALL DOORS MAG BYPASS-RLY	MCC-1B-1 HALL DOORS MAG BYPASS--RLY		Inactive	3000-MCC MANCHESTER
MCC-1B-2 HALL DOORS MAG BYPASS-RLY	MCC-1B-2 HALL DOORS MAG BYPASS-RLY		Inactive	3000-MCC MANCHESTER
MCC-1B-7 HALL DOORS MAG BYPASS-RLY	MCC-1B-7 HALL DOORS MAG BYPASS-RLY		Inactive	3000-MCC MANCHESTER
MCC-KNOX 1 HALL DOOR MAG BYPASS-RLY			Inactive	3000-MCC MANCHESTER
MCC-2B-1 HALL DOORS MAG BYPASS-RLY	MCC-2B-1 HALL DOORS MAG BYPASS-RLY		Inactive	3000-MCC MANCHESTER
MCC-2B-2 HALL DOORS MAG BYPASS-RLY	MCC-2B-2 HALL DOORS MAG BYPASS-RLY		Inactive	3000-MCC MANCHESTER
MCC-2B-4 HALL DOORS MAG BYPASS-RLY	MCC-2B-4 HALL DOORS MAG BYPASS-RLY		Inactive	3000-MCC MANCHESTER
MCC-287 BOILER ROOM EMERGENCY EXIT DMP-RLY	MCC-287 BOILER ROOM EMERGENCY EXIT DMP-RLY		Inactive	3000-MCC MANCHESTER
MCC-297 PHYSICS/EARTH SCIENCE LAB EMERGENCY EXIT DMP-RLY	MCC-297 PHYSICS/EARTH SCIENCE LAB EMERGENCY EXIT DMP-RLY		Inactive	3000-MCC MANCHESTER
MCC-268 LIBRARY EMERGENCY EXIT LEFT DMP-RLY	MCC-268 LIBRARY EMERGENCY EXIT LEFT DMP-RLY		Inactive	3000-MCC MANCHESTER

MCC-268 LIBRARY EMERGENCY EXIT RIGHT DMP-RLY	MCC-268 LIBRARY EMERGENCY EXIT RIGHT DMP-RLY		Inactive	3000-MCC MANCHESTER
MCC-STUDENT ENTRANCE-CB	MCC-STUDENT ENTRANCE-CB		Inactive	3000-MCC MANCHESTER
MCC-HSCI SIDE ENTRANCE DMP-RLY	MCC-HSCI SIDE ENTRANCE DMP-RLY		Inactive	3000-MCC MANCHESTER
MCC-MAIN LOBBY DMP-RLY	MCC-MAIN LOBBY DMP-RLY		Inactive	3000-MCC MANCHESTER
MCC-MAIN LOBBY RIGHT/LEFT DOOR DMP-RLY	MCC-MAIN LOBBY RIGHT/LEFT DOOR DMP-RLY		Inactive	3000-MCC MANCHESTER
MCC-STUDENT SERVICES EMERGENCY EXIT DMP-RLY	MCC-STUDENT SERVICES EMERGENCY EXIT DMP-RLY		Inactive	3000-MCC MANCHESTER
MCC-GYM EMERGENCY EXIT RIGHT DMP-RLY	MCC-GYM EMERGENCY EXIT RIGHT DMP-RLY		Inactive	3000-MCC MANCHESTER
MCC-GYM EMERGENCY EXIT LEFT DMP-RLY	MCC-GYM EMERGENCY EXIT LEFT DMP-RLY		Inactive	3000-MCC MANCHESTER
MCC-CAFE SERVING AREA EMERGENCY EXIT DMP-RLY	MCC-CAFE SERVING AREA EMERGENCY EXIT DMP-RLY		Inactive	3000-MCC MANCHESTER
MCC-CAFE SITTING AREA EXIT DMP-RLY	MCC-CAFE SITTING AREA EXIT DMP-RLY		Inactive	3000-MCC MANCHESTER
MCC-CAFE EMPLOYEE ENTRANCE DMP-RLY	MCC-CAFE EMPLOYEE ENTRANCE DMP-RLY		Inactive	3000-MCC MANCHESTER
MCC-A KNOX BLDG 2ND FLOOR ENTRANCE DMP-RLY	MCC-A KNOX BLDG 2ND FLOOR ENTRANCE DMP-RLY		Inactive	3000-MCC MANCHESTER
MCC-231 AMT LAB EMERG EXIT DMP-RLY	MCC-231 AMT LAB EMERG EXIT DMP-RLY		Inactive	3000-MCC MANCHESTER

MCC-COMPUTER/EXERCISE HALL ENTRANCE DMP-RLY	MCC-COMPUTER /EXERCISE HALL ENTRANCE DMP-RLY		Inactive	3000-MCC MANCHESTER
MCC-252C-1 CAD HALL DOOR MAG BYPASS-RLY	MCC-252C-1 CAD HALL DOOR MAG BYPASS-RLY		Inactive	3000-MCC MANCHESTER
MCC-252C-2 CAD STAIRS DOOR MAG BYPASS-RLY	MCC-252C-2 CAD STAIRS DOOR MAG BYPASS-RLY		Inactive	3000-MCC MANCHESTER
MCC-1 KNOX 2 HALLWAY DOORS 2 BYPASS-RLY	MCC-1 KNOX 2 HALLWAY DOORS 2 BYPASS-RLY		Inactive	3000-MCC MANCHESTER
MCC-LOBBY TO CAFE DOORS BYPASS-RLY	MCC-LOBBY TO CAFE DOORS BYPASS-RLY		Inactive	3000-MCC MANCHESTER
MCC-249 MARKETING EMERG EXIT DMP-RLY	MCC-249 MARKETING EMERG EXIT DMP-RLY		Inactive	3000-MCC MANCHESTER
MCC-KNOX 6 MAIN ENTRANCE DMP-RLY	MCC-KNOX 6 MAIN ENTRANCE DMP-RLY		Inactive	3000-MCC MANCHESTER
MCC-100 LECTURE HALL EMERGENCY EXIT DMP-RLY	MCC-100 LECTURE HALL EMERGENCY EXIT DMP-RLY		Inactive	3000-MCC MANCHESTER
MCC-102 GRAPHIC DESIGN EMERGENCY EXIT DMP-RLY	MCC-102 GRAPHIC DESIGN EMERGENCY EXIT DMP-RLY		Inactive	3000-MCC MANCHESTER
MCC-ACADEMIC AFFAIRS MAIN ENTRANCE LEFT Door 43 A & B DMP-RLY	MCC-ACADEMIC AFFAIRS MAIN ENTRANCE LEFT DMP-RLY		Active	3000-MCC MANCHESTER

MCC-ACADEMIC AFFAIRS MAIN ENTRANCE Door 43 C & D DMP-RLY	MCC-ACADEMIC AFFAIRS MAIN ENTRANCE DMP-RLY		Inactive	3000-MCC MANCHESTER
MCC-LECTURE HALL EMERGENCY EXIT DMP-RLY	MCC-LECTURE HALL EMERGENCY EXIT DMP-RLY		Inactive	3000-MCC MANCHESTER
MCC-STUDENT ENTRANCE DMP-RLY	MCC-STUDENT ENTRANCE DMP-RLY		Inactive	3000-MCC MANCHESTER
MCC-259-1 CHILD DEVELOPMENT CENTER EMERGENCY EXIT DMP-RLY	MCC-259-1 CHILD DEVELOPMENT CENTER EMERGENCY EXIT DMP-RLY		Inactive	3000-MCC MANCHESTER
MCC-CHILD DEVELOPMENT CENTER MAIN ENT DMP-RLY	MCC-CHILD DEVELOPMENT CENTER MAIN ENT DMP-RLY		Inactive	3000-MCC MANCHESTER
MCC-259-3 CHILD DEVELOPMENT CENTER EMERGENCY EXIT DMP-RLY	MCC-259-3 CHILD DEVELOPMENT CENTER EMERGENCY EXIT DMP-RLY		Inactive	3000-MCC MANCHESTER
MCC-259-4 CHILD DEVELOPMENT CENTER EMERGENCY EXIT DMP-RLY	MCC-259-4 CHILD DEVELOPMENT CENTER EMERGENCY EXIT DMP-RLY		Inactive	3000-MCC MANCHESTER
MCC-133-9 WELDING LAB MAN DOOR DMP-RLY	MCC-133-9 WELDING LAB MAN DOOR DMP-RLY		Inactive	3000-MCC MANCHESTER
MCC-133-10 WELDING LAB OVERHEAD DOOR DMP-RLY	MCC-133-10 WELDING LAB OVERHEAD DOOR DMP-RLY		Inactive	3000-MCC MANCHESTER
MCC-133-7 WELDING LAB MAN DOOR DMP-RLY	MCC-133-7 WELDING LAB MAN DOOR DMP-RLY		Inactive	3000-MCC MANCHESTER

MCC-133-6 WELDING LAB SLIDING DOOR DMP-RLY	MCC-133-6 WELDING LAB SLIDING DOOR DMP-RLY		Inactive	3000-MCC MANCHESTER
MCC-133-5 WELDING LAB MAN DOOR DMP-RLY	MCC-133-5 WELDING LAB MAN DOOR DMP-RLY		Inactive	3000-MCC MANCHESTER
MCC-135 -7 AIR CON LAB STORAGE DOORS DMP-RLY	MCC-135 -7 AIR CON LAB STORAGE DOORS DMP-RLY		Inactive	3000-MCC MANCHESTER
MCC-135 -9 AIR CON LAB OVERHEAD DOOR DMP-RLY	MCC-135 -9 AIR CON LAB OVERHEAD DOOR DMP-RLY		Inactive	3000-MCC MANCHESTER
MCC-137-3 HEATING LAB OVERHEAD DOOR DMP-RLY	MCC-137-3 HEATING LAB OVERHEAD DOOR DMP-RLY		Inactive	3000-MCC MANCHESTER
MCC 141-BUILDING CONSTRUCTION EXT DOORS DMP-RLY	MCC 141-BUILDING CONSTRUCTION EXT DOORS DMP-RLY		Inactive	3000-MCC MANCHESTER
MCC- MAIN ENTRANCE PANIC DMP-RLY	MCC- MAIN ENTRANCE PANIC DMP-RLY		Inactive	3000-MCC MANCHESTER
MCC-268 LIBRARY PANIC DMP-RLY	MCC-268 LIBRARY PANIC DMP-RLY		Inactive	3000-MCC MANCHESTER
MCC-STUDENT SERVICES PANIC DMP-RLY	MCC-STUDENT SERVICES PANIC DMP-RLY		Inactive	3000-MCC MANCHESTER
MCC-1 KNOX 2 HALLWAY DOORS 1 BYPASS-RLY	MCC-1 KNOX 2 HALLWAY DOORS 1 BYPASS-RLY		Inactive	3000-MCC MANCHESTER
MCC-MAG HOLDER RELEASE			Inactive	3000-MCC MANCHESTER
MCC-B BUILDING DELAY EGRESS MAG POWER-RLY	MCC-B BUILDING DELAY EGRESS MAG POWER-RLY		Inactive	3000-MCC MANCHESTER
MCC-2 KNOX HALL DELAY EGRESS MAG POWER-RLY			Inactive	3000-MCC MANCHESTER

MCC-STUDENT CENTER ONE STOP DELAY EGRESS MAG POWER			Inactive	3000-MCC MANCHESTER
MCC-HSCI 2ND FL-ISTAR DELAY EGRESS MAG PWR-RLY			Inactive	3000-MCC MANCHESTER
MCC-HSCI 3RD FL DELAY EGRESS MAG PWR-RLY			Inactive	3000-MCC MANCHESTER
MCC-KNOX 1ST FL TELEDATA DELAY EGRESS MAG PWR-RLY			Inactive	3000-MCC MANCHESTER
MCC-SERVER ROOM TEMP SENSOR DMP-RLY			Inactive	3000-MCC MANCHESTER
MCC-3rd FL weightroom ENTRANCE DOOR-STR			Inactive	3000-MCC MANCHESTER
MCC-AUTO LAB 1 REAR ENTRANCE-EL			Inactive	3000-MCC MANCHESTER
MCC-AUTO LAB 1 ENTRANCE-EL			Inactive	3000-MCC MANCHESTER
MCC-AUTO LAB 2 ENTRANCE-EL			Inactive	3000-MCC MANCHESTER
MCC-AUTO 123 CLASSROOM 4-EL			Inactive	3000-MCC MANCHESTER
MCC-AUTO 122 CLASSROOM 3-EL			Inactive	3000-MCC MANCHESTER
MCC-AUTO 121 CLASSROOM 2-EL			Inactive	3000-MCC MANCHESTER
MCC-AUTO 120 CLASSROOM 1-EL			Inactive	3000-MCC MANCHESTER
MCC-AUTO LAB 2 REAR ENTRANCE-EL			Inactive	3000-MCC MANCHESTER
MCC-AUTO MAIN ENTRANCE-CB			Inactive	3000-MCC MANCHESTER
MCC-AUTO STUDENT ENTRANCE-CB			Inactive	3000-MCC MANCHESTER
MCC-AUTO 121 CLASSROOM 2 REAR-EL			Inactive	3000-MCC MANCHESTER
MCC-AUTO 122 CLASSROOM 3 REAR-EL			Inactive	3000-MCC MANCHESTER
MCC-102 ROBOTICS CLASS-STR			Inactive	3000-MCC MANCHESTER
MCC-102 ROBOTICS LAB-STR			Inactive	3000-MCC MANCHESTER
MCC-ADVANCED TECH 101 HVAC MOTORS-EL			Inactive	3000-MCC MANCHESTER
MCC-ADVANCED TECH 102 ETECH MOTORS 2-EL			Inactive	3000-MCC MANCHESTER
MCC-ADVANCED TECH 103 ETECH MOTORS 1-EL			Inactive	3000-MCC MANCHESTER
MCC-ADVANCED TECH 113 TELE/DATA-EL			Inactive	3000-MCC MANCHESTER
MCC-ADVANCED TECH 109 PLC LAB-EL			Inactive	3000-MCC MANCHESTER
MCC-ADVANCED TECH CHILLER LAB-EL			Inactive	3000-MCC MANCHESTER
MCC-ADVANCED TECH 224 HVAC 101-EL			Inactive	3000-MCC MANCHESTER
MCC-ADVANCED TECH 219 ETEC DOC-EL			Inactive	3000-MCC MANCHESTER
MCC-ADVANCED TECH OUTDOOR LAB-EL			Inactive	3000-MCC MANCHESTER
MCC-ADVANCED TECH 213 AHU LAB-EL			Inactive	3000-MCC MANCHESTER
MCC-ADVANCED TECH 223 RELATED ELECTRICITY-EL			Inactive	3000-MCC MANCHESTER
MCC-ADVANCED TECH 218 COMPUTER LAB LEFT-EL			Inactive	3000-MCC MANCHESTER
MCC-ADVANCED TECH 218 COMPUTER LAB RIGHT-EL			Inactive	3000-MCC MANCHESTER
MCC-ADVANCED TECH 217 HVAC DDC-EL			Inactive	3000-MCC MANCHESTER
MCC-ADVANCED TECH MAIN ENTRANCE-EL			Inactive	3000-MCC MANCHESTER

MCC-BURSAR FRONT ENTRANCE-STR			Inactive	3000-MCC MANCHESTER
MCC-BURSAR REAR ENTRANCE-STR			Inactive	3000-MCC MANCHESTER
MCC-240 ADVANCED MANUFACTURING SINGLE-STR			Inactive	3000-MCC MANCHESTER
Output1-MCC-SERVER ROOM EDGE			Inactive	3000-MCC MANCHESTER
MCC-ENTRANCE 43 doors c&d -CB	aka MCC-NORTH WING 1ST FL ENTRANCE-CB		Inactive	3000-MCC MANCHESTER
Name	Description	Armed status	Active Status	Partition Name
NCC-H325-3-NURSING LAB LEFT-STRIKE			Inactive	4500-NCC NASHUA
NCC-H321-CONFERENCE ROOM-STRIKE			Inactive	4500-NCC NASHUA
NCC-H325-2-NURSING LAB STORAGE-STRIKE			Inactive	4500-NCC NASHUA
NCC-3RD FLOOR IDF-STRIKE			Inactive	4500-NCC NASHUA
NCC-H325-3-NURSING LAB RIGHT-STRIKE			Inactive	4500-NCC NASHUA
NCC-2ND FLOOR IDF-STRIKE			Inactive	4500-NCC NASHUA
NCC-H285-LAB CLASSROOM-STRIKE			Inactive	4500-NCC NASHUA
NCC-H281-LAB CLASSROOM-STRIKE			Inactive	4500-NCC NASHUA
NCC-H283-LAB CLASSROOM-STRIKE			Inactive	4500-NCC NASHUA
NCC-H278-LABS OFFICE-STRIKE			Inactive	4500-NCC NASHUA
NCC-AUTO LAB GENERAL SHOP ENTRANCE-STRIKE			Inactive	4500-NCC NASHUA
NCC-AUTO LAB NORTH ENTRANCE EXTERIOR-STRIKE			Inactive	4500-NCC NASHUA
NCC-AUTO REPAIR LAB 8-STRIKE			Inactive	4500-NCC NASHUA
NCC AUTO LAB SOUTH ENTRANCE EXTERIOR-STRIKE			Inactive	4500-NCC NASHUA
NCC-H BUILDING MAIN ENTRANCE EXTERIOR-STRIKE			Inactive	4500-NCC NASHUA
NCC-H BUILDING NORTH SIDE ENTRANCE EXTERIOR-STRIKE			Inactive	4500-NCC NASHUA
NCC-AUTO MAIN LOBBY ENTRANCE EXTERIOR-STRIKE			Inactive	4500-NCC NASHUA
NCC-H BUILDING SOUTH SIDE ENTRANCE EXTERIOR-STRIKE			Inactive	4500-NCC NASHUA
NCC-N101-1-GYM ENTRANCE-STRIKE			Inactive	4500-NCC NASHUA
NCC-201-2-FITNESS CENTER REAR TO TRACK-STRIKE			Inactive	4500-NCC NASHUA
NCC-N110-MENS LOCKER ROOM-STRIKE			Inactive	4500-NCC NASHUA
NCC-201-1-FITNESS CENTER FRONT-STRIKE			Inactive	4500-NCC NASHUA
NCC-203-1-MULTI PURPOSE ROOM-STRIKE			Inactive	4500-NCC NASHUA
NCC-N109-WOMENS LOCKER ROOM-STRIKE			Inactive	4500-NCC NASHUA
NCC-240-1-TRACK ENTRANCE-STRIKE			Inactive	4500-NCC NASHUA
NCC-N102-A-IDF-STRIKE			Inactive	4500-NCC NASHUA

NCC-120-CHRISTINE GAGNON OFFICE-STRIKE			Inactive	4500-NCC NASHUA
NCC-144-2-MACHINE SHOP ENTRANCE EXTERIOR-STRIKE			Inactive	4500-NCC NASHUA
NCC-152-3-MAINTENANCE ENTRANCE EXTERIOR-STRIKE			Inactive	4500-NCC NASHUA
NCC-EAST ENTRANCE EXTERIOR-STRIKE			Inactive	4500-NCC NASHUA
NCC-123-1-CAMPUS SAFETY-STRIKE			Inactive	4500-NCC NASHUA
NCC-156-1-ADMISSIONS ENTRANCE-STRIKE			Inactive	4500-NCC NASHUA
NCC-MAIN ENTRANCE EXTERIOR-STRIKE			Inactive	4500-NCC NASHUA
NCC-SOUTH SIDE ENTRANCE EXTERIOR-STRIKE			Inactive	4500-NCC NASHUA
117-1-NCC-STRIKE			Inactive	4500-NCC NASHUA
NCC-100-1-ACADEMIC SUCCESS CENTER-STRIKE			Inactive	4500-NCC NASHUA
NCC-93-1-AVAITION TECH DEPARTMENT-STRIKE			Inactive	4500-NCC NASHUA
NCC-89-4-AVAITION EXTERIOR-STRIKE			Inactive	4500-NCC NASHUA
NCC-97-1-FINANCIAL AID-STRIKE			Inactive	4500-NCC NASHUA
NCC-99-1-ACADEMIC ADVISING CENTER-STRIKE			Inactive	4500-NCC NASHUA
NCC-102-COMPUTER CLASSROOM-STRIKE			Inactive	4500-NCC NASHUA
NCC-98-1-MAIL ROOM-STRIKE			Inactive	4500-NCC NASHUA
NCC-SOUTH WEST EXTERIOR-STRIKE			Inactive	4500-NCC NASHUA
NCC-159-3-BUSINESS OFFICE VAULT-STRIKE			Inactive	4500-NCC NASHUA
NCC-171-1-CAD LAB-STRIKE			Inactive	4500-NCC NASHUA
NCC-159-1-BUSINESS OFFICE-STRIKE			Inactive	4500-NCC NASHUA
NCC-104-COMPUTER CLASSROOM-STRIKE			Inactive	4500-NCC NASHUA
NCC-170-1-CAD LAB-STRIKE			Inactive	4500-NCC NASHUA
NCC-218-1-MICROSCOPE LAB-STRIKE			Inactive	4500-NCC NASHUA
NCC-220-1-COMPUTER LAB-STRIKE			Inactive	4500-NCC NASHUA
NCC-232-1-COMPUTER LAB-STRIKE			Inactive	4500-NCC NASHUA
NCC-233-1-CLASSROOM-STRIKE			Inactive	4500-NCC NASHUA
NCC-307-1-COMPUTER NETWORKING-STRIKE			Inactive	4500-NCC NASHUA
NCC-307-COMPUTER NETWORKING-STRIKE			Inactive	4500-NCC NASHUA
NCC-310-1-COMPUTER LAB-STRIKE			Inactive	4500-NCC NASHUA
NCC-310-2-COMPUTER LAB-STRIKE			Inactive	4500-NCC NASHUA
NCC-130-LIBRARY ENTRANCE-LOCK			Inactive	4500-NCC NASHUA
95-4-NCC-HORN			Inactive	4500-NCC NASHUA
93-2-NCC-HORN			Inactive	4500-NCC NASHUA
89-3-NCC-HORN			Inactive	4500-NCC NASHUA
94-2-NCC-HORN			Inactive	4500-NCC NASHUA
890-3-NCC-HORN			Inactive	4500-NCC NASHUA

ME-12-HORN			Inactive	4500-NCC NASHUA
NCC-COURTYARD EXIT-HORN			Inactive	4500-NCC NASHUA
NCC-NORTH EAST ENTRANCE EXTERIOR-HORN			Inactive	4500-NCC NASHUA
89-3-NCC-DMP-RLY			Inactive	4500-NCC NASHUA
HALL-8-NCC-DMP-RLY			Inactive	4500-NCC NASHUA
94-2-NCC-DMP-RLY			Inactive	4500-NCC NASHUA
93-2-NCC-DMP-RLY			Inactive	4500-NCC NASHUA
95-4-NCC-DMP-RLY			Inactive	4500-NCC NASHUA
890-3-NCC-DMP-RLY			Inactive	4500-NCC NASHUA
89-2-NCC-DMP-RLY			Inactive	4500-NCC NASHUA
ME-12-NCC-DMP-RLY			Inactive	4500-NCC NASHUA
OVERHEAD-MC-1-NCC-DMP-RLY			Inactive	4500-NCC NASHUA
OVERHEAD-152-NCC-DMP-RLY			Inactive	4500-NCC NASHUA
NCC-NORTH EAST ENTRANCE EXTERIOR DMP-RLY			Inactive	4500-NCC NASHUA
OVERHEAD-144-2-NCC-DMP-RLY			Inactive	4500-NCC NASHUA
NCC-COURTYARD EXIT DMP-RLY			Inactive	4500-NCC NASHUA
RM-121-PANIC-NCC-DMP-RLY			Inactive	4500-NCC NASHUA
NCC-NORTH EAST ENTRANCE EXTERIOR-MAG			Inactive	4500-NCC NASHUA
NCC-COURTYARD EXIT-MAG			Inactive	4500-NCC NASHUA
NCC-MAIN ENTRANCE EXTERIOR DMP-RLY			Active	4500-NCC NASHUA
NCC-H BUILDING MAIN ENTRANCE EXTERIOR DMP-RLY			Active	4500-NCC NASHUA
Name	Description	Armed status	Active Status	Partition Name
NHTI-GRAPPONE MAIN ENTRANCE-CB	NHTI-GRAPPONE MAIN ENTRANCE-CB		Inactive	6000-NHTI CONCORD
NHTI-GRAPPONE REAR ENTRANCE-CB	NHTI-GRAPPONE REAR ENTRANCE-CB		Inactive	6000-NHTI CONCORD
NHTI-GRAPPONE NURSING LAB AREA-CB	NHTI-GRAPPONE NURSING LAB AREA-CB		Inactive	6000-NHTI CONCORD
NHTI-GRAPPONE 133 CLASSROOM-STR	NHTI-GRAPPONE 133 CLASSROOM-STR		Inactive	6000-NHTI CONCORD
NHTI-GRAPPONE 136 NURSING SKILLS LAB-STR	NHTI-GRAPPONE 136 NURSING SKILLS LAB-STR		Inactive	6000-NHTI CONCORD
NHTI-GRAPPONE 218 COMPUTER LAB-STR	NHTI-GRAPPONE 218 COMPUTER LAB-STR		Inactive	6000-NHTI CONCORD

NHTI-GRAPPONE MAIN ENTRANCE-RLY	NHTI-GRAPPONE MAIN ENTRANCE-RLY		Inactive	6000-NHTI CONCORD
NHTI-FARNUM F103 NETWORKING-STR	NHTI-FARNUM F103 NETWORKING-STR		Inactive	6000-NHTI CONCORD
NHTI-FARNUM MAIN ENTRANCE-STR	NHTI-FARNUM MAIN ENTRANCE-STR		Inactive	6000-NHTI CONCORD
NHTI-SWEENEY MAIN ENTRANCE-CB	NHTI-SWEENEY MAIN ENTRANCE-CB		Inactive	6000-NHTI CONCORD
NHTI-SWEENEY BISTRO EMPLOYEE ENTRANCE-STR	NHTI-SWEENEY BISTRO EMPLOYEE ENTRANCE-STR		Inactive	6000-NHTI CONCORD
NHTI-SWEENEY REAR ENTRANCE-CB	NHTI-SWEENEY REAR ENTRANCE-CB		Inactive	6000-NHTI CONCORD
NHTI-LIBRARY BOOK STORE ENTRANCE-STR	NHTI-LIBRARY BOOK STORE ENTRANCE-STR		Inactive	6000-NHTI CONCORD
NHTI-LIBRARY SHIPPING/RECIEVING-MAG	NHTI-LIBRARY SHIPPING/RECIEVING-MAG		Inactive	6000-NHTI CONCORD
NHTI-LIBRARY REAR DOOR-STR	NHTI-LIBRARY REAR DOOR-STR		Inactive	6000-NHTI CONCORD
NHTI-LIBRARY REAR DOOR-HORN	NHTI-LIBRARY REAR DOOR-HORN		Inactive	6000-NHTI CONCORD
NHTI-MAINTENANCE ENTRANCE-STR	NHTI-MAINTENANCE ENTRANCE-STR		Inactive	6000-NHTI CONCORD
NHTI-MACRURY DENTAL COMPUTER ROOM-STR	NHTI-MACRURY DENTAL COMPUTER ROOM--STR		Inactive	6000-NHTI CONCORD

NHTI-MACRURY QUAD ENTRANCE-STR	NHTI-MACRURY QUAD ENTRANCE-STR		Inactive	6000-NHTI CONCORD
NHTI-MACRURY MAIN ENTRANCE-CB	NHTI-MACRURY MAIN ENTRANCE-CB		Inactive	6000-NHTI CONCORD
NHTI-MACRURY REAR ENTRANCE-CB	NHTI-MACRURY REAR ENTRANCE-CB		Inactive	6000-NHTI CONCORD
NHTI-MACRURY M113 LIBRARY-STR	NHTI-MACRURY M113 LIBRARY-STR		Inactive	6000-NHTI CONCORD
NHTI-MACRURY M208 COMPUTER LAB-STR	NHTI-MACRURY M208 COMPUTER LAB-STR		Inactive	6000-NHTI CONCORD
NHTI-MACRURY M201 PARAMEDIC SUITE-STR	NHTI-MACRURY M201 PARAMEDIC SUITE-STR		Inactive	6000-NHTI CONCORD
NHTI-MACRURY M201C PARAMEDIC AMBULANCE-STR	NHTI-MACRURY M201C PARAMEDIC AMBULANCE-STR		Inactive	6000-NHTI CONCORD
NHTI-MACRURY M201D PARAMEDIC BREAKOUT-STR	NHTI-MACRURY M201D PARAMEDIC BREAKOUT-STR		Inactive	6000-NHTI CONCORD
NHTI-LANGLEY HALL A WING 1ST FLOOR INTERIOR-MAG	NHTI-LANGLEY HALL A WING 1ST FLOOR INTERIOR-MAG		Active	6000-NHTI CONCORD
NHTI-LANGLEY HALL A WING 2ND FLOOR HALL-CB	NHTI-LANGLEY HALL A WING 2ND FLOOR HALL-CB		Active	6000-NHTI CONCORD
NHTI-LANGLEY HALL A WING EXTERIOR-STR	NHTI-LANGLEY HALL A WING EXTERIOR-STR		Inactive	6000-NHTI CONCORD

NHTI-LANGLEY HALL MAIN LOBBY-STR	NHTI-LANGLEY HALL MAIN LOBBY-STR		Inactive	6000-NHTI CONCORD
NHTI-LANGLEY HALL BOILER ROOM EXTERIOR-STR	NHTI-LANGLEY HALL BOILER ROOM EXTERIOR-STR		Inactive	6000-NHTI CONCORD
NHTI-LANGLEY HALL DOOR HELD ALARM-RLY	NHTI-LANGLEY HALL DOOR HELD ALARM-RLY		Inactive	6000-NHTI CONCORD
NHTI-LANGLEY HALL PANIC ALARM-RLY	NHTI-LANGLEY HALL PANIC ALARM-RLY		Inactive	6000-NHTI CONCORD
NHTI-LANGLEY HALL BURG ALARM-RLY	NHTI-LANGLEY HALL BURG ALARM-RLY		Inactive	6000-NHTI CONCORD
NHTI-LAGNLEY HALL PHOTO BURG ALARM-RLY	NHTI-LANGLEY HALL PHOTO BURG ALARM-RLY		Inactive	6000-NHTI CONCORD
NHTI-SOUTH HALL EAST-STR	NHTI-SOUTH HALL EAST-STR		Inactive	6000-NHTI CONCORD
NHTI-SOUTH HALL WEST-STR	NHTI-SOUTH HALL WEST-STR		Inactive	6000-NHTI CONCORD
NHTI-SOUTH HALL FRONT-STR	NHTI-SOUTH HALL FRONT-STR		Inactive	6000-NHTI CONCORD
NHTI-SOUTH HALL ELECTRICAL-STR	NHTI-SOUTH HALL ELECTRICAL-STR		Inactive	6000-NHTI CONCORD
NHTI-SOUTH HALL DOOR HELD ALARM-RLY	NHTI-SOUTH HALL DOOR HELD ALARM-RLY		Inactive	6000-NHTI CONCORD

NHTI-SOUTH HALL PANIC ALARM-RLY	NHTI-SOUTH HALL PANIC ALARM-RLY		Inactive	6000-NHTI CONCORD
NHTI-SOUTH HALL BURG ALARM-RLY	NHTI-SOUTH HALL BURG ALARM-RLY		Inactive	6000-NHTI CONCORD
NHTI-LITTLE HALL SLIDER TO STREET-RLY	NHTI-LITTLE HALL SLIDER TO STREET-RLY		Inactive	6000-NHTI CONCORD
NHTI-LITTLE HALL L128 CLASSROOM-STR	NHTI-LITTLE HALL L128 CLASSROOM-STR		Inactive	6000-NHTI CONCORD
NHTI-LITTLE HALL L204 CLASSROOM-STR	NHTI-LITTLE HALL L204 CLASSROOM-STR		Inactive	6000-NHTI CONCORD
NHTI-CHILDHOOD MAIN ENTRANCE-STR	NHTI-CHILDHOOD MAIN ENTRANCE-STR		Inactive	6000-NHTI CONCORD
NHTI-CAPITAL COMMONS DATA CLOSET-STR	NHTI-CAPITAL COMMONS DATA CLOSET-STR		Inactive	6000-NHTI CONCORD
NHTI-CAPITAL COMMONS MANAGERS OFFICE-STR	NHTI-CAPITAL COMMONS MANAGERS OFFICE-STR		Inactive	6000-NHTI CONCORD
NHTI-CAPITAL COMMONS RECIEVING-STR	NHTI-CAPITAL COMMONS RECIEVING-STR		Inactive	6000-NHTI CONCORD
NHTI-WELLNESS CENTER FITNESS ROOM-STR	NHTI-WELLNESS CENTER FITNESS ROOM-STR		Inactive	6000-NHTI CONCORD
NHTI-STUDENT CENTER ENTRANCE-EL	NHTI-STUDENT CENTER ENTRANCE-EL		Inactive	6000-NHTI CONCORD
NHTI-WELLNESS CENTER ENTRANCE-EL	NHTI-WELNESS CENTER ENTRANCE-EL		Inactive	6000-NHTI CONCORD

NHTI-STUDENT CENTER AFFAIR-STR	NHTI-STUDENT CENTER AFFAIR-STR		Inactive	6000-NHTI CONCORD
NHTI-WELLNESS CENTER OFFICE-STR	NHTI-WELLNESS CENTER OFFICE-STR		Inactive	6000-NHTI CONCORD
NHTI-LITTLE HALL SLIDER TO CAPITAL COMMONS-RLY			Inactive	6000-NHTI CONCORD
NHTI-STROUT HALL PANIC ALARM-RLY	NHTI-STROUT HALL PANIC ALARM-RLY		Inactive	6000-NHTI CONCORD
NHTI-STROUT HALL DOOR HELD ALARM-RLY	NHTI-STROUT HALL DOOR HELD ALARM-RLY		Inactive	6000-NHTI CONCORD
NHTI-STROUT HALL BURG ALARM-RLY	NHTI-STROUT HALL BURG ALARM-RLY		Inactive	6000-NHTI CONCORD
NHTI-STROUT HALL EAST-STR	NHTI-STROUT HALL EAST-STR		Inactive	6000-NHTI CONCORD
NHTI-STROUT HALL WEST-STR	NHTI-STROUT HALL WEST-STR		Inactive	6000-NHTI CONCORD
NHTI-STROUT HALL FRONT-STR	NHTI-STROUT HALL FRONT-STR		Inactive	6000-NHTI CONCORD
NHTI-LIBRARY DOOR HELD ALARM-RLY			Inactive	6000-NHTI CONCORD
NHTI-LIBRARY PANIC ALARM-RLY			Inactive	6000-NHTI CONCORD
NHTI-LIBRARY BURG ALARM-RLY			Inactive	6000-NHTI CONCORD
NHTI-MACRURY SIDE ENTRANCE-CB	NHTI-MACRURY SIDE ENTRANCE-CB		Inactive	6000-NHTI CONCORD
NHTI-LAGNLEY HALL C WING EXTERIOR-STR	NHTI-LANGLEY HALL C WING EXTERIOR-STR		Inactive	6000-NHTI CONCORD

NHTI-LITTLE HALL L112 CLASSROOM-STR	NHTI-LITTLE HALL L112 CLASSROOM-STR		Inactive	6000-NHTI CONCORD
NHTI-LITTLE HALL L231 CLASSROOM-STR	NHTI-LITTLE HALL L231 CLASSROOM-STR		Inactive	6000-NHTI CONCORD
NHTI-CFDC MAIN ENTRANCE-STR	NHTI-CFDC MAIN ENTRANCE-STR		Inactive	6500-NHTI CFDC
NHTI-LANGLEY HALL B WING EXTERIOR-STR	NHTI-LANGLEY HALL B WING EXTERIOR-STR		Inactive	6000-NHTI CONCORD
NHTI-SWEENEY RECEPTION DESK PANIC-RLY	ACTIVATES AUTO DIALER		Inactive	6000-NHTI CONCORD
NHTI-SWEENEY BURSAR OFFICE PANIC-RLY	ACTIVATES AUTO DIALER		Inactive	6000-NHTI CONCORD
NHTI-MACRURY PANIC-RLY	ACTIVATES AUTO DIALER		Inactive	6000-NHTI CONCORD
NHTI-LITTLE HALL OFFICE PANIC-RLY			Inactive	6000-NHTI CONCORD
NHTI-LANGLEY HALL A WING 1ST FLOOR HALL-CB			Active	6000-NHTI CONCORD
7000-CO-SERVER ROOM FRONT-STR			Inactive	7000-CO
7000-CO-SERVER ROOM REAR-STR			Inactive	7000-CO
7000-CO-BACK ENTRANCE-STR			Inactive	7000-CO
7000-CO-FRONT ENTRANCE-MAG			Inactive	7000-CO
7000-CO-CHECK PRINTER-STR			Inactive	7000-CO
7000-CO-MIDDLE-STR			Inactive	7000-CO
NHTI-LIBRARY EXTERIOR MAIN ENTRANCE-ELR			Inactive	6000-NHTI CONCORD
NHTI-LIBRARY INTERIOR MAIN ENTRANCE-ELR			Inactive	6000-NHTI CONCORD
NHTI-CAPITAL COMMONS-O81-O01 SOUTHEAST DINING EXTERIOR-MAGLOCK			Inactive	6000-NHTI CONCORD
NHTI-CAPITAL COMMONS-O81-O02 SOUTHWEST DINING EXTERIOR-MAGLOCK			Inactive	6000-NHTI CONCORD
NHTI-CAPITAL COMMONS-O81-O03 WEST CAFE PATIO EXTERIOR-ELR			Inactive	6000-NHTI CONCORD
NHTI-MACRURY-O01-LOBBY ENTRANCE-ELR			Inactive	6000-NHTI CONCORD
NHTI-FARNUM REAR ENTRANCE			Inactive	6000-NHTI CONCORD
NHTI-SWEENEY-ISTAR EDGE-O81-O01-BISTRO EXTERIOR ENTRANCE			Inactive	6000-NHTI CONCORD
NHTI-SWEENEY-ISTAR EDGE-O81-O02-BISTRO LOADING ENTRANCE			Inactive	6000-NHTI CONCORD

NHTI-SWEENEY-ISTAR EDGE-O81-O03-BISTRO FOYER ENTRANCE			Inactive	6000-NHTI CONCORD
NHTI-SWEENEY-ISTAR EDGE-O81-O04-CONTINUING ED 103-DIALER			Inactive	6000-NHTI CONCORD
NHTI-SWEENEY-ISTAR EDGE-O81-O05-FINANCIAL AID 104-DIALER			Inactive	6000-NHTI CONCORD
NHTI-SWEENEY-ISTAR EDGE-O81-O06-ADMISSIONS 113-DIALER			Inactive	6000-NHTI CONCORD
NHTI-SWEENEY-ISTAR EDGE-O81-O07-OFFICE 148-DIALER			Inactive	6000-NHTI CONCORD
NHTI-SWEENEY-ISTAR EDGE-O81-O08-REGISTRARS 145-DIALER			Inactive	6000-NHTI CONCORD
NHTI-GRAPPONE 113 MDF TELE/DATA ISTAR-O81-O01-2ND FLOOR 227 OFFICES-DIALER			Inactive	6000-NHTI CONCORD
NHTI-MACRURY-112 RAIDOOLIGY SECTRETARY PANIC-DIALER			Active	6000-NHTI CONCORD
NHTI-SWEENEY S301 OFFICE-EL			Inactive	6000-NHTI CONCORD
NHTI-SWEENEY S318 IT CLASSROOM-EL			Inactive	6000-NHTI CONCORD
NHTI-SWEENEY S308 CISCO LAB-MAG			Inactive	6000-NHTI CONCORD
NHTI-SWEENEY S309 CISCO LAB CLASSROOM-EL			Inactive	6000-NHTI CONCORD
NHTI-SWEENEY S306 DH OFFICE-EL			Inactive	6000-NHTI CONCORD
NHTI-SWEENEY S307 FACULTY OFFICE-EL			Inactive	6000-NHTI CONCORD
NHTI-FARNUM F104 FACULTY ADJUNCT-STR			Inactive	6000-NHTI CONCORD
NHTI-CAMPUS SAFTY ENTRANCE-STR			Inactive	6000-NHTI CONCORD
NHTI-STUDENT CENTER-I81-I05-HEALTH RECEPTION-DIALER			Inactive	6000-NHTI CONCORD
NHTI-SWEENEY S131 FIRE ALARM ROOM-STR			Inactive	6000-NHTI CONCORD
NHTI-SWEENEY S220A IT ROOM-EL			Inactive	6000-NHTI CONCORD
NHTI-SWEENEY PLANETARIUM DOUBLE-CB			Inactive	6000-NHTI CONCORD
NHTI-LITTLE HALL REAR DOUBLE-CB			Inactive	6000-NHTI CONCORD
NHTI-CAPITAL COMMONS DINING SLIDER-LOCK			Inactive	6000-NHTI CONCORD
NHTI- LANGLEY HALL A WING 2ND FLOOR INTERIOR-MAG	NHTI-LANGLEY HALL A WING 2ND FLOOR INTERIOR DOOR MAG		Active	6000-NHTI CONCORD
Name	Description	Armed status	Active Status	Partition Name

RVCC CLAREMONT-1ST FLOOR EMPLOYEE/STUDENT ENTRANCE-LOCK	RVCC CLAREMONT-1ST FLOOR EMPLOYEE/STUDENT ENTRANCE-LOCK		Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC CLAREMONT-1ST FLOOR HANDICAP RESTROOM TO MAIN HALL-LOCK	RVCC CLAREMONT-1ST FLOOR HANDICAP RESTROOM TO MAIN HALL-LOCK		Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC CLAREMONT-1ST FLOOR LIBRARY TO LEARNING CENTER-LOCK	RVCC CLAREMONT-1ST FLOOR LIBRARY TO LEARNING CENTER-LOCK		Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC CLAREMONT-1ST FLOOR 100J LEARNING CENTER-LOCK	RVCC CLAREMONT-1ST FLOOR 100J LEARNING CENTER-LOCK		Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC CLAREMONT-1ST FLOOR EXT FALCON-LOCK	RVCC CLAREMONT-1ST FLOOR EXT FALCON-LOCK		Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC CLAREMONT-1ST FLOOR EMPLOYEE/STUDENT ENTRANCE DMP-ALARM	RVCC CLAREMONT-1ST FLOOR EMPLOYEE/STUDENT ENTRANCE DMP-ALARM		Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC CLAREMONT-1ST FLOOR EXT FALCON DMP-ALARM	RVCC CLAREMONT-1ST FLOOR EXT FALCON DMP-ALARM		Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC CLAREMONT-1ST FLOOR DOOR 14 CAFE DMP-ALARM	RVCC CLAREMONT-1ST FLOOR DOOR 14 CAFE DMP-ALARM		Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON

RVCC CLAREMONT-1ST FLOOR DOOR 14 CAFE-HORN	RVCC CLAREMONT-1ST FLOOR DOOR 14 CAFE-HORN		Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC CLAREMONT-1ST FLOOR DOOR 15 CAFE-HORN	RVCC CLAREMONT-1ST FLOOR DOOR 15 CAFE-HORN		Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC CLAREMONT-1ST FLOOR DOOR 15 CAFE DMP-ALARM	RVCC CLAREMONT-1ST FLOOR DOOR 15 CAFE DMP-ALARM		Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC CLAREMONT-1ST FLOOR DOOR 16 CAFE-HORN	RVCC CLAREMONT-1ST FLOOR DOOR 16 CAFE-HORN		Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC CLAREMONT-1ST FLOOR DOOR 16 CAFE DMP-ALARM	RVCC CLAREMONT-1ST FLOOR DOOR 16 CAFE DMP-ALARM		Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC CLAREMONT-1ST FLOOR DOOR 17 CAFE-HORN	RVCC CLAREMONT-1ST FLOOR DOOR 17 CAFE-HORN		Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC CLAREMONT-1ST FLOOR DOOR 17 CAFE DMP-ALARM	RVCC CLAREMONT-1ST FLOOR DOOR 17 CAFE DMP-ALARM		Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC CLAREMONT-1ST FLOOR DOOR 7 BOILER EXIT-HORN	RVCC CLAREMONT-1ST FLOOR DOOR 7 BOILER EXIT-HORN		Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC CLAREMONT-1ST FLOOR DOOR 7 BOILER EXIT DMP-ALARM	RVCC CLAREMONT-1ST FLOOR DOOR 7 BOILER EXIT DMP-ALARM		Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON

RVCC CLAREMONT-1ST FLOOR DOOR 9 ROOM 152 EMERG EXIT-HORN	RVCC CLAREMONT-1ST FLOOR DOOR 9 ROOM 152 EMERG EXIT-HORN		Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC CLAREMONT-1ST FLOOR DOOR 9 ROOM 152 EMERG EXIT DMP-ALARM	RVCC CLAREMONT-1ST FLOOR DOOR 9 ROOM 152 EMERG EXIT-DMP-ALARM		Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC CLAREMONT-1ST FLOOR DOOR 10 STAIR TO COURT EMERG EXIT-HORN	RVCC CLAREMONT-1ST FLOOR DOOR 10 STAIR TO COURT EMERG EXIT-HORN		Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC CLAREMONT-1ST FLOOR DOOR 10 STAIR TO COURT EMERG EXIT DMP-ALARM	RVCC CLAREMONT-1ST FLOOR DOOR 10 STAIR TO COURT EMERG EXITDMP-ALARM		Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC CLAREMONT-1ST FLOOR DOOR 6 NORTH SCIENCE WING-HORN	RVCC CLAREMONT-1ST FLOOR DOOR 6 NORTH SCIENCE WING-HORN		Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC CLAREMONT-1ST FLOOR DOOR 6 NORTH SCIENCE WING DMP-ALARM	RVCC CLAREMONT-1ST FLOOR DOOR 6 NORTH SCIENCE WING DMP-ALARM		Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC CLAREMONT-1ST FLOOR DOOR 4 EAST SCIENCE WING-HORN	RVCC CLAREMONT-1ST FLOOR DOOR 4 EAST SCIENCE WING-HORN		Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON

RVCC CLAREMONT-1ST FLOOR DOOR 4 EAST SCIENCE WING DMP-ALARM	RVCC CLAREMONT-1ST FLOOR DOOR 4 EAST SCIENCE WING DMP-ALARM		Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC CLAREMONT-1ST FLOOR DOOR 3 ROOM 125 EMERG EXIT-HORN	RVCC CLAREMONT-1ST FLOOR DOOR 3 ROOM 125 EMERG EXIT-HORN		Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC CLAREMONT-1ST FLOOR DOOR 3 ROOM 125 EMERG EXIT DMP-ALARM	RVCC CLAREMONT-1ST FLOOR DOOR 3 ROOM 125 EMERG EXIT DMP-ALARM		Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC CLAREMONT-1ST FLOOR DOOR 2 LIBRARY EMERG EXIT-HORN	RVCC CLAREMONT-1ST FLOOR DOOR 2 LIBRARY EMERG EXIT-HORN		Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC CLAREMONT-1ST FLOOR DOOR 2 LIBRARY EMERG EXIT DMP-ALARM	RVCC CLAREMONT-1ST FLOOR DOOR 2 LIBRARY EMERG EXIT DMP-ALARM		Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC CLAREMONT-1ST FLOOR DOOR 12 MAIN HALL TO COURTYARD-HORN	RVCC CLAREMONT-1ST FLOOR DOOR 12 MAIN HALL TO COURTYARD-HORN		Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC CLAREMONT-1ST FLOOR DOOR 12 MAIN HALL TO COURTYARD DMP-ALARM	RVCC CLAREMONT-1ST FLOOR DOOR 12 MAIN HALL TO COURTYARD DMP-ALARM		Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON

RVCC KEENE-1ST FLOOR FRONT ENTRANCE-LOCK	RVCC KEENE-1ST FLOOR FRONT ENTRANCE-LOCK		Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC KEENE-1ST FLOOR REAR ENTRANCE-LOCK	RVCC KEENE-1ST FLOOR REAR ENTRANCE-LOCK		Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC KEENE-1ST FLOOR BOILER ROOM EMERG EXIT-HORN	RVCC KEENE-1ST FLOOR BOILER ROOM EMERG EXIT-HORN		Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC KEENE-1ST FLOOR BOILER ROOM EMERG EXIT DMP-ALARM	RVCC KEENE-1ST FLOOR BOILER ROOM EMERG EXIT DMP-ALARM		Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC KEENE-1ST FLOOR VIRTUAL LAB 018 EMERG EXIT-HORN	RVCC KEENE-1ST FLOOR VIRTUAL LAB 018 EMERG EXIT-HORN		Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC KEENE-1ST FLOOR VIRTUAL LAB 018 EMERG EXIT DMP-ALARM	RVCC KEENE-1ST FLOOR VIRTUAL LAB 018 EMERG EXIT DMP-ALARM		Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC KEENE-1ST FLOOR MACHINE TOOL ROOM 107 EMERG EXIT-HORN	RVCC KEENE-1ST FLOOR MACHINE TOOL ROOM 107 EMERG EXIT-HORN		Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC KEENE-1ST FLOOR MACHINE TOOL ROOM 107 EMERG EXIT DMP-ALARM	RVCC KEENE-1ST FLOOR MACHINE TOOL ROOM 107 EMERG EXIT DMP-ALARM		Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON

RVCC KEENE-1ST FLOOR CLASSROOM 113 EMERG EXIT-HORN	RVCC KEENE-1ST FLOOR CLASSROOM 113 EMERG EXIT-HORN		Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC KEENE-1ST FLOOR STAIR 3 EMERG EXIT-HORN	RVCC KEENE-1ST FLOOR STAIR 3 EMERG EXIT-HORN		Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC KEENE-1ST FLOOR STAIR 3 EMERG EXIT DMP-ALARM	RVCC KEENE-1ST FLOOR STAIR 3 EMERG EXIT DMP-ALARM		Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC KEENE-2ND FLOOR SCIENCE LAB 218 EMERG EXIT-HORN	RVCC KEENE-2ND FLOOR SCIENCE LAB 218 EMERG EXIT-HORN		Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC KEENE-2ND FLOOR SCIENCE LAB 218 EMERG EXIT DMP-ALARM	RVCC KEENE-2ND FLOOR SCIENCE LAB 218 EMERG EXIT DMP-ALARM		Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC KEENE-1ST FLOOR STAIR 2 EMERG EXIT-HORN	RVCC KEENE-1ST FLOOR STAIR 2 EMERG EXIT-HORN		Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC KEENE-1ST FLOOR STAIR 2 EMERG EXIT DMP-ALARM	RVCC KEENE-1ST FLOOR STAIR 2 EMERG EXIT DMP-ALARM		Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC KEENE-1ST FLOOR REAR ENTRANCE HANDICAP OPENER-TRIP	RVCC KEENE-1ST FLOOR REAR ENTRANCE HANDICAP OPENER-TRIPRVCC KEENE-1ST FLOOR REAR ENTRANCE HANDICAP		Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON

RVCC CLAREMONT-1ST FLOOR LIBRARY TO LEARNING CENTER DMP-ALARM	RVCC CLAREMONT-1ST FLOOR LIBRARY TO LEARNING CENTER DMP-ALARM		Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC CLAREMONT-1ST FLOOR 100J LEARNING CENTER DMP-ALARM	RVCC CLAREMONT-1ST FLOOR 100J LEARNING CENTER DOOR DMP-ALARM		Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC KEENE-1ST FLOOR FRONT ENTRANCE DMP-ALARM	RVCC KEENE-1ST FLOOR FRONT ENTRANCE DMP-ALARM		Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC KEENE-1ST FLOOR REAR ENTRANCE DOOR DMP-ALARM	RVCC KEENE-1ST FLOOR REAR ENTRANCE DOOR DMP-ALARM		Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC CLAREMONT-1ST FLOOR MAIN ENTRANCE DMP-ALARM	RVCC CLAREMONT-1ST FLOOR MAIN ENTRANCE DMP-ALARM		Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC CLAREMONT-1ST FLOOR LIBRARY DMP-ALARM	RVCC CLAREMONT-1ST FLOOR LIBRARY DMP-ALARM		Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC CLAREMONT-1ST FLOOR CFO OFFICE DMP-ALARM	RVCC CLAREMONT-1ST FLOOR CFO OFFICE DMP-ALARM		Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC KEENE-1ST FLOOR BOILER ROOM HALLWAY DMP-ALARM	RVCC KEENE-1ST FLOOR BOILER ROOM HALLWAY DMP-ALARM		Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON

RVCC KEENE-1ST FLOOR SERVER ROOM HALLWAY DMP-ALARM	RVCC KEENE-1ST FLOOR SERVER ROOM HALLWAY DMP-ALARM		Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
2006-iSTAR01/1/O06-RVCC-CFO OFFICE-LOCK			Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
2007-iSTAR01/1/O07-RVCC-TEL-DATA CLOSET-LOCK			Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
2009-iSTAR01/2/O01-RVCC-CLASSROOM 145-LOCK			Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
2010-iSTAR01/2/O02-RVCC-CLASSROOM 146-LOCK			Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
2011-iSTAR01/2/O03-RVCC-CLASSROOM 147-LOCK			Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
2012-iSTAR01/2/O04-RVCC-CLASSROOM 151-LOCK			Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
2013-iSTAR01/2/O05-RVCC-CLASSROOM 153-LOCK			Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
2014-iSTAR01/2/O06-RVCC-HR OFFICE-LOCK			Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
2015-iSTAR01/2/O07-RVCC-PRESIDENTS OFFICE-LOCK			Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC LEBANON 1ST FL EMPLOYEE ENTRANCE-CB	RVCC LEBANON 1ST FL EMPLOYEE ENTRANCE-CB		Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC LEBANON 121 MAIL ROOM-STR	RVCC LEBANON 121 MAIL ROOM-STR		Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC LEBANON 114 IT OFFICE-STR	RVCC LEBANON 114 IT OFFICE-STR		Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC LEBANON 112 CLASSROOM-STR	RVCC LEBANON 112 CLASSROOM-STR		Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC LEBANON 110 CLASSROOM-STR	RVCC LEBANON 110 CLASSROOM-STR		Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC LEBANON 109 CLASSROOM-STR	RVCC LEBANON 109 CLASSROOM-STR		Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC LEBANON 2ND FL REAR ENTRANCE-CB	RVCC LEBANON 2ND FL REAR ENTRANCE-CB		Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON

RVCC LEBANON 2ND FL FRONT ENTRANCE-CB	RVCC LEBANON 2ND FL FRONT ENTRANCE-CB		Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC LEBANON SIDE STAIR DMP-RLY			Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC LEBANON 2ND FL FRONT ENTRANCE DMP-RLY	RVCC LEBANON 2ND FL FRONT ENTRANCE DMP-RLY		Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC LEBANON 2ND FL REAR ENTRANCE DMP-RLY	RVCC LEBANON 2ND FL REAR ENTRANCE DMP-RLY		Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC LEBANON 1ST FL EMPLOYEE ENTRANCE HANDICAP-RLY			Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC LEBANON 2ND FL REAR ENTRANCE HANDICAP-RLY			Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC LEBANON 2ND FL FRONT ENTRANCE HANDICAP-RLY			Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
2016-iSTAR01/2/O07-RVCC-CLASSROOM 130-LOCK			Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC CLAREMONT-1ST FLOOR MAIN ENTRANCE-CB			Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
RVCC CLAREMONT-KITCHEN EXTERIOR-STRIKE			Inactive	2000-RVCC CLAREMONT/KEENE/LEBANON
Name	Description	Armed status	Active Status	Partition Name
WMCC-MAIN ENT-LOCK			Inactive	5000-WMCC BERLIN
WMCC-WELLNESS CENTER-LOCK			Inactive	5000-WMCC BERLIN
WMCC-BACK STAIRWELL-LOCK			Inactive	5000-WMCC BERLIN
WMCC-SIDE STAIRWELL-LOCK			Inactive	5000-WMCC BERLIN
WMCC-WELLNESS CENTER DMP-RLY	WMCC-WELLNESS CENTER DMP-RLY		Inactive	5000-WMCC BERLIN
WMCC-BACK STAIRWELL DMP-RLY			Inactive	5000-WMCC BERLIN
WMCC-MAIN ENTRANCE DMP-RLY			Inactive	5000-WMCC BERLIN
WMCC-MAIN OFFICE LOCKDOWN DMP-RLY			Inactive	5000-WMCC BERLIN
WMCC-HR OFFICE LOCKDOWN DMP-RLY			Inactive	5000-WMCC BERLIN
WMCC-CBAO OFFICE LOCKDOWN DMP-RLY			Inactive	5000-WMCC BERLIN
WMCC-WELCOME CENTER LOCKDOWN DMP-RLY			Inactive	5000-WMCC BERLIN

Armed status

EXHIBIT "C" REVISED FOR ADDENDUM #3

Campus	Project Type	Project Description	Recommended Action
GBCC	2. Access Control	**Card Reader Adds for IDF Closets.** None of the IDF Closests at GBCC Portsmouth have Card Reader Access on them. We have eight IDF closets that need access monitoring to control and document who should be entering these areas. This was also an issue addressed in the Berry Dunn Report for IT.	Add card access readers to all eight IDF closets at GBCC Portsmouth. Rooms 425, 329, 211, 115A, NE151, 149B(X2) & 97A.
GBCC	2. Access Control	To allow for the implementation of requested devices, etc an ACM board needs to be added.	Add ACM Board
GBCC	2. Access Control	**3rd Floor iSTAR Panel Add.** This panel will need to be added for Card Reader Access on any floors above the 1st floor at GBCC Ports.	Add new 16 card iSTAR Panel on the 3rd floor of GBCC Ports. to support any Card Reader Access on floors 2, 3, and 4. This includes IDF closets and any future areas such as classrooms or labs.
GBCC	2. Access Control	**Card Reader Adds Nursing Area.** None of the nursing labs have card reader access at Ports. These labs area setup to mimic hospital rooms and emergency rooms. They also contain many nursing supplies and expensive equipment.	Add card readers to the three doors into the Nursing Lab, room 300(X2) and 302 interior door
GBCC	2. Access Control	**Card Reader Adds Surgical Area.** None of the doors to the Surg Tech labs have card readers at the Ports. campus. These labs contain lots of Surgical instruments, supplies and expensive surgical equipment.	Add card readers to the three doors into the Surg Tech Lab, room 304(X2) and 306 interior door
LRCC	1. Surveillance	**CAT Fixed Camera Ext. Door Near 102.** This entrance to the building has no video monitoring and an individual can easily gain access to advanced manufacturing equipment without be observed on any cameras.	Add wide angle camera, at corner, for building entrance coverage as recommended by audit.
LRCC	1. Surveillance	**RTB Room 255 360 camera.** The student lounge area has no video monitoring where there is regular daily activity. There is an IT data closet as well as a student club office/storage off of this area. This area now Culinary Resturant.	IT Data closets per Berry Dunn Audit report should be monitored and area is a popular hangout, video coverage is important.
LRCC	2. Access Control	Swap lock down proxy card reader in RTB Room 102 to push button lock down	Dueto relocation of offices this card reader can be removed and the cabling repurposed to accommodate a lock down push button.
LRCC	2. Access Control	**RTB Room 219 Reader**. Area is a server room. No current proximity card access through either of the two entry ways. Limited surveillance.	IT Data closets per Berry Dunn Audit report should be monitored and control access to them.
LRCC	2. Access Control	**RTB Room 259 Reader.** Area is a server room. No current proximity card access and no video surveillance monitoring entry into room.	IT Data closets per Berry Dunn Audit report should be monitored and control access to them.
MCC	1. Surveillance	IT Data Closets per Berry Dunn Audit report should have video coverage to reference in the event of an incident.	Install a camera in the hallway outside the data closet to cover the data closet 318Q and existing office spaces.
MCC	1. Surveillance	IT Data Closets per Berry Dunn Audit report should have video coverage to reference in the event of an incident.	Replace camera in the area of the Student Center Kiosk Data/Electrical/Telephone Room
MCC	1. Surveillance	IT Data Closets per Berry Dunn Audit report should have video coverage to reference in the event of an incident.	Install a camera in the area outside IT/Data closet Room 256 Main Building to cover area and nearby spaces.
MCC	1. Surveillance	Add Istar Panel and ACM to accommodate for additional card readers being installed	Install a 16 card Istar panel and ACM centrally to accommodate for additional devices being added.
MCC	1. Surveillance	IT Data Closets per Berry Dunn Audit report should have video coverage to reference in the event of an incident.	Install a camera in the IT/Data closet that's inside room 224. Cant install outside as it's a shared office space.
MCC	1. Surveillance	IT Data Closets per Berry Dunn Audit report should have video coverage to reference in the event of an incident.	Install a camera in the hallway outside room 203 to monitor entrance to space. IT Box on wall in room.. Cant install inside as it's a classroom space.
MCC	1. Surveillance	IT Data Closets per Berry Dunn Audit report should have video coverage to reference in the event of an incident.	Install a camera in the IT/Data closet that's inside room 238. Cant install outside as it's a classroom space.
MCC	2. Access Control	IT Data Closets per Berry Dunn Audit report should monitor and control access into them.	Add Card reader to Data/Electrical/Telephone Room 270 in the HS Building
MCC	2. Access Control	IT Data Closets per Berry Dunn Audit report should monitor and control access into them.	Add Card reader to Data/Electrical/Telephone Room 318Q in the HS Building
MCC	2. Access Control	IT Data Closets per Berry Dunn Audit report should monitor and control access into them.	Add Card reader to Data/Electrical/Telephone Room 271 in the multi purpose room
MCC	2. Access Control	IT Data Closets per Berry Dunn Audit report should have separate keyed access to restrict accessability	Add Card reader to the Student Center Kiosk Data/Electrical/Telephone Room
MCC	2. Access Control	IT Data Closets per Berry Dunn Audit report should monitor and control access into them.	Add Card reader to Data/Electrical/Telephone Hub IT closet door (Onestop/Hub)
MCC	2. Access Control	IT Data Closets per Berry Dunn Audit report should monitor and control access into them.	Add Card reader to Data/Electrical/Telephone room that's inside room 238 (no room#)
MCC	2. Access Control	IT Data Closets per Berry Dunn Audit report should monitor and control access into them. The IT Department door controls access to the main server room and would need to have monitoring capabilities should an issue arise with the main server space.	Add Card reader with keypad to IT Department Office Door, room 224, B Building
MCC	2. Access Control	IT Data Closets per Berry Dunn Audit report should monitor and control access into them.	Add Card reader to Data/Electrical/Telephone room that's inside room 131 B Wing 1st floor Main (no room#)
MCC	3. Emergency Alerting	Students, faculty & staff have voiceed concern about their ability to utilize their cell phones to receive emergency alerts and to call emergency services in an emergency in the Welding & HVAC Labs	Enhance cell phone coverage by adding boosters to the Welding & HVAC labs
MCC	3. Emergency Alerting	Students, faculty & staff have voiceed concern about their ability to utilize their cell phones to receive emergency alerts and to call emergency services in an emergency in the Café	Enhance cell phone coverage by adding boosters to the Café

MCC	3. Emergency Alerting	Students, faculty & staff have voiceed concern about their ability to utilize their cell phones to receive emergency alerts and to call emergency services in an emergency in the ground level connecting area	Enhance cell phone coverage by adding boosters to the ground level connecting area
MCC	3. Emergency Alerting	Students, faculty & staff have voiceed concern about their ability to utilize their cell phones to receive emergency alerts and to call emergency services in an emergency in the Learning Commons	Enhance cell phone coverage by adding boosters to the Learning Commons
MCC	3. Emergency Alerting	Students, faculty & staff have voiceed concern about their ability to utilize their cell phones to receive emergency alerts and to call emergency services in an emergency in the Automotive areas	Enhance cell phone coverage by adding boosters to the Automotive Area
MCC	3. Emergency Alerting	Students, faculty & staff have voiceed concern about their ability to utilize their cell phones to receive emergency alerts and to call emergency services in an emergency in the Advanced Tachnologies areas	Enhance cell phone coverage by adding boosters to Advanced Technologies
NCC	2. Access Control	Install three lock down push buttons throughout the campus. Currently NCC only has one button on campus and would be best to have additional in case of emergency.	Install three (3) lock down buttons, one at main entrance, one at the Campus Safety Office and one in the ticket booth.
NCC	1. Access Control	Add Istar Panel and ACM to accommodate for additional card readers being installed	Install a 16 card Istar panel and ACM centrally to accommodate for additional devices being added.
NCC	2. Access Control	IT Data Closets per Berry Dunn Audit report should monitor and control access into them. The IT Department door controls access to the main server room and would need to have monitoring capabilities should an issue arise with the main server space.	Add two (2) card readers to Room 101 Main Server one in hallway and one for inside door.
NCC	2. Access Control	IT Data Closets per Berry Dunn Audit report should monitor and control access into them. The IT Department door controls access to the main server room and would need to have monitoring capabilities should an issue arise with the main server space.	Add card reader to Admission's Back Room 156
NCC	2. Access Control	IT Data Closets per Berry Dunn Audit report should monitor and control access into them. The IT Department door controls access to the main server room and would need to have monitoring capabilities should an issue arise with the main server space.	Add card reader to IT space inside Machine Tool Network room 147. (Inside classroom)
NCC	1. Access Control	Add ACM board to Library to accommodate for additional card readers being installed	Install ACM to accommodate for additional devices being added.
NCC	1. Access Control	Add ACM board to second floor to accommodate for additional card readers being installed	Install ACM to accommodate for additional devices being added.
NCC	2. Access Control	IT Data Closets per Berry Dunn Audit report should monitor and control access into them. The IT Department door controls access to the main server room and would need to have monitoring capabilities should an issue arise with the main server space.	Add card reader to IT closet in Library Network room 132
NCC	2. Access Control	IT Data Closets per Berry Dunn Audit report should monitor and control access into them. The IT Department door controls access to the main server room and would need to have monitoring capabilities should an issue arise with the main server space.	Add card reader to IT Network Closet Hallway near room G186
NCC	2. Access Control	IT Data Closets per Berry Dunn Audit report should monitor and control access into them. The IT Department door controls access to the main server room and would need to have monitoring capabilities should an issue arise with the main server space.	Add card reader (X2) to IT Network Closet space between 310/307.
NCC	2. Access Control	IT Data Closets per Berry Dunn Audit report should monitor and control access into them. The IT Department door controls access to the main server room and would need to have monitoring capabilities should an issue arise with the main server space.	Add card reader (X2) to IT Network Room Cabinet between Room 218/220
NCC	2. Access Control	IT Data Closets per Berry Dunn Audit report should monitor and control access into them. The IT Department door controls access to the main server room and would need to have monitoring capabilities should an issue arise with the main server space.	Add Card reader to Judd Gregg Hallway Box Office IT Closet
NCC	2. Access Control	IT Data Closets per Berry Dunn Audit report should monitor and control access into them. The IT Department door controls access to the main server room and would need to have monitoring capabilities should an issue arise with the main server space.	Add card reader to IT closet in Auto building
NHTI	1. Surveillance	**Library camera rear building covering walkway.** • Unable to effectively monitor area to avoid/assist with crime occurrences and incidents. • High traffic area with low visibility making it an area susceptible to crimes or incidents.	Install Axis Q6010-E with Q60-EPTZ camera in high foot traffic location, currently no video coverage of this space exists.
NHTI	1. Surveillance	**MacRury camera dental main entrance.** • Unable to effectively monitor area to avoid/assist with crime occurrences and incidents. • High traffic area with low visibility making it an area susceptible to crimes or incidents.	Install camera inside buildings main entrance to pickup individuals as they enter the facility, high foot traffic location, currently no video coverage of this space exists.
NHTI	1. Surveillance	**Tunnel camera Fort Eddy side (to point towards campus).** • Unable to effectively monitor area to avoid/assist with crime occurrences and incidents. • High traffic area with low visibility making it an area susceptible to crimes or incidents.	Install camera to cover tunnell opening and side walls on outer tunnel wall. Believe power can be obtained through lighting system in tunnell or outside.

NHTI	1. Surveillance	**Fan Road end camera @ solar unit.** • Unable to effectively monitor area to avoid/assist with crime occurrences and incidents. • High traffic area with no visibility making it an area susceptible to crimes or incidents.	Install Axis Q6010-E with Q60-EPTZ camera to cover parking lot and turnaround area at solar power unit.
NHTI	1. Surveillance 2. Access Control	**Library IT closet reader data room 161.** • Risk identified in the Barry Dunn Report. All IT closets cannot be secured effectively or monitored from the alarm monitoring. **Add camera in room.**	Install Card reader on IT closet door and install camera in room per Berry Dunn Audit report.
NHTI	1. Surveillance 2. Access Control	**MacRury 1st floor (North Wing) IT closet reader entrance data/tel room.** • Risk identified in the Barry Dunn Report. All IT closets cannot be secured effectively or monitored from the alarm monitoring.	Install Card reader on IT closet door and install camera outside room per Berry Dunn Audit report.
NHTI	1. Surveillance 2. Access Control	**MacRury 1st floor IT closet reader 141(data closet).** • Risk identified in the Berry Dunn Report. All IT closets cannot be secured effectively or monitored from the alarm monitoring. **Add camera.**	Install Card reader on IT closet door and install camera outside room per Berry Dunn Audit report.
NHTI	1. Surveillance 2. Access Control	**Student Center 2nd floor IT closet reader data closet.** • Risk identified in the Berry Dunn Report. All IT closets cannot be secured effectively or monitored from the alarm monitoring.	Install Card reader on IT closet door and install camera in room per Berry Dunn Audit report.
NHTI	2. Access Control	**Grappone 1st floor IT closet reader 113.** • Risk identified in the Barry Dunn Report. All IT closets cannot be secured effectively or monitored from the alarm monitoring.	Install Card reader on IT closet door per Berry Dunn Audit report.
NHTI	1. Surveillance 2. Access Control	**Grappone 2nd floor IT closet reader 206 & 305** • Risk identified in the Barry Dunn Report. All IT closets cannot be secured effectively or monitored from the alarm monitoring. **Add cameras outside for maximum coverage.**	Install Card reader on IT closet door and install camera outside room per Berry Dunn Audit report.
NHTI	1. Surveillance 2. Access Control	**Little Hall 1st floor IT closet reader between L109 & L107/108.** • Risk identified in the Barry Dunn Report. All IT closets cannot be secured effectively or monitored from the alarm monitoring. **Needs camera in room. Room 107 needs cage installed to close off open gap from wall to ceiling.**	Install Card reader on IT closet door inside room 109 and install camera in room per Berry Dunn Audit report.
NHTI	1. Surveillance 2. Access Control	**Little Hall 2nd floor IT closet reader L232/233.** • Risk identified in the Barry Dunn Report. All IT closets cannot be secured effectively or monitored from the alarm monitoring. **Needs camera inside.**	Install Card reader on IT closet door and install camera in room per Berry Dunn Audit report.
NHTI	1. Surveillance 2. Access Control	**MacRury 2nd floor IT closet reader 207.** • Risk identified in the Berry Dunn Report. All IT closets cannot be secured effectively or monitored from the alarm monitoring. **Camera needed on wall across door.**	Install Card reader on IT closet door and install camera outside room per Berry Dunn Audit report.
NHTI	1. Surveillance 2. Access Control	**North Hall 2nd floor A wing IT closet reader data closet.** • Risk identified in the Berry Dunn Report. All IT closets cannot be secured effectively or monitored from the alarm monitoring. **Needs new door, hardware. Add camera at closet door**	Install Card reader on IT closet door and install camera in room per Berry Dunn Audit report.
NHTI	1. Surveillance 2. Access Control	**South Hall 2nd floor IT closet reader outside 214.** • Risk identified in the Berry Dunn Report. All IT closets cannot be secured effectively or monitored from the alarm monitoring. **Camera inside.**	Install Card reader on IT closet door and install camera in room per Berry Dunn Audit report.
NHTI	1. Surveillance 2. Access Control	**Strout Hall 2nd floor IT closet reader behind janitor closet.** • Risk identified in the Berry Dunn Report. All IT closets cannot be secured effectively or monitored from the alarm monitoring. **Camera inside**	Install Card reader on IT closet door and install camera in room per Berry Dunn Audit report.
NHTI	3. Emergency Alerting	**Student Center 2nd floor panic alarm - SC227 suite - One each in Reception, Student Conduct and VPSA Office** • Unable to contact Campus Safety effectively in an emergency discreetly when someone is being threatening or disruptive.	Install panic switch under desks which contact Campus Safety in an emergency (autodialer may be needed)
NHTI	3. Surviellence	**Replace all HikVision Cameras -** Camera need to be replaced per US Governement requirement took effect August 13, 2019 and due to camera age. There are a total of 7 cameras to replace. Cameras are located at: Code Blue Unit 1 on Fan Rd, Strout Hall NW Corner of building, Main Parking Lot poles B2, B7, B7 & A11 and Langley Hall NE Exterior. 3 cameras are PTZ and are to be repalced with Axis Q6010-E with Q60-EPTZ.	US Federal Government requires all Hikvision cameras to be replaced and were banned effect August 13, 2019
RVCC	1. Surveillance	**Update Exaqvision server at Lebanon campus.** Server hardware is dated and can no longer be updated to the current software version. The current server cannot accommodate any new camera upgrades due to technological limitations	Replace server and update software. Replace PoE switch with Poe+ switch

RVCC	2. Access Control	**Move 2 two cardreaders in library claremont campus.** The library is unable to be independantly secured. Access control from the student center to the library allows access via REX	Change the direction of card access, requiring id badging to enter the library or computer lab from the ACT center using access control vendor. Vendor is required to coordinate with fire alarm company for the installation of mag lock.
RVCC	2. Access Control	**Add prox readers to business hallway claremont.** Currently on a door code system ad-200 with batteries. High traffic door. Add card readers to allow roll based access. 3 doors into business office suite	Install prox card readers and door strikes at business hallway doors and hallway access to office 164 .add required 16 outlet access control panel.
RVCC	2. Access Control	**Rear student entrance needs redon**e- and frame rotted due to salt. Doors do not secure properly. have had several unauthorized entrys due to door not closing properly	replace doors, frame and add mag locks to access control, use Von Duprin hardware when replacing panic hardware.
RVCC	2. Access Control	Card reader 203 & 155A Chemical storage	Add card reader and strike to room 203 and room 155A. Both are live chemical storage areas
RVCC	3. Emergency alerting	911 panic in safety office	Add a 911 panic button to the campus safety office near the video monitoring
RVCC	3. Emergency alerting	Internal switch for safety contact in HR	Add an internal panic button to HR desk
WMCC	1. Surveillance 2. Access Control	**Main Campus Card Reader Adds for IDF and MDF Closets.** None of the closests have Card Reader Access on them. We have two closets that need access monitoring to control and document who should be entering these areas.	Add card access readers to two closets, Rm 303 and 115A, at WMCC Main Campus. Add cameras inside each closet.
WMCC	3. Emergency Alerting	Main Campus Access Control Panel Addition - needed to accommodate panic buttons and additional card access readers.	Install new 16 card iSTAR Panel to accommodate panic buttons and additional card readers.
WMCC	3. Emergency Alerting	Encorporate new (existing) PA system into old PA speaker system within classrooms/offices. If old speakers are inoperable add new speaker into space.	