



BID # LRC24-01

ADDENDUM NUMBER 01

REQUEST FOR BIDS FOR:

Building Automation System Replacement

At Lakes Region Community College, 379 Belmont Rd, Laconia, NH 03246

A component of the Community College System of New Hampshire

26 College Drive, Concord, NH 03301

August 8th, 2024

TO: ALL CONTRACT BIDDERS OF RECORD

This Addendum forms a part of the Contract Documents and modifies the Request for Bids dated August 22, 2024, with amendments and additions noted below. This Addendum consists of a total of One (1) page.

CLARIFICATIONS TO THE REQUEST FOR PROPOSAL:

Bid date: Remains the same – August 13th, 2024 at 2pm.

Per RFP for the BAS replacement, Pg 3, Substitutions, Section A, line a:

A substitution may be a single front end with a single BAS for the campus. Achieve this through BACnet discovery which allows to fully control any existing controller and communicate/program it according to how it is needed. Quote the RFQ exactly how it is stated but an equal can be by providing Automated Logic Controllers and front end instead of Reliable. This will still result in one singular system for the campus.

Acknowledge receipt of this Addendum with the Proposal Form. Failure to do so may disqualify the Bidder.

NOTE: IN THE EVENT THAT YOUR BID HAS BEEN SENT TO THIS OFFICE PRIOR TO RECEIVING THIS ADDENDUM, RETURN THE ADDENDUM WITHIN THE SPECIFIED TIME WITH ANY CHANGES YOU MAY WISH TO MAKE AND MARK ON THE REMITTANCE ENVELOPE BID INVITATION NUMBER AND OPENING DATE. RETURNED ADDENDA WILL SUPERSEDE PREVIOUSLY SUBMITTED BID.

Bidder _____

By _____ Date _____

(This Document Must Be Signed)

Name _____

(Please Print or Type Name)

Matthew Moore, P.E.

Director of Capitol Planning & Development
Community College System of New Hampshire
26 College Drive, Concord, N.H. 0330