

BID # WMC24-03

ADDENDUM NUMBER 02 REQUEST FOR BIDS FOR:

Library Roof Replacement
at White Mountains Community College
2020 Riverside Drive, Berlin NH 03570

A component of the Community College System of New Hampshire 26 College Drive, Concord, NH 03301 September 16, 2024

TO: ALL CONTRACT BIDDERS OF RECORD

This Addendum forms a part of the Contract Documents and modifies the Request for Bids dated August 6, 2024, with amendments and additions noted below. This Addendum consists of a total of one (1) page.

CLARIFICATIONS TO THE REQUEST FOR PROPOSAL:

BID DATE: Remains the same – September 25th, 2024 at 2pm.

SUBSTANTIAL COMPLETION DATE: Date for work remains the same: August 23rd, 2025

Question #1: Please clarify if a compressible tube expansion joint is acceptable at detail 5/A501 to match detail 4/A501.

Answer: No. One detail is for an expansion joint with new membrane roof systems on each side. The other details is where on side of the expansion joint is an existing roof membrane system to remain and the other side is the new roof membrane system. Based on the design information available from various manufactures of roof membrane systems these are two different conditions that require different details.

Question #2:

Spec section 00204 10.2 A 4 calls to maintain CGL coverage for itself and the city of keene for at least 7 years after complete of this work. Just confirming this spec does not apply to this project. Answer: This is true. Does not apply

Acknowledge receipt of this Addendum with the Proposal Form. Failure to do so may disqualify the Bidder.

NOTE: IN THE EVENT THAT YOUR BID HAS BEEN SENT TO THIS OFFICE PRIOR TO RECEIVING THIS

WISH T DATE. I	IDUM, RETURN THE ADDENDUM WITHIN THE SPECIFIED TIME WITH AITO MAKE AND MARK ON THE REMITTANCE ENVELOPE BID INVITATION RETURNED ADDENDA WILL SUPERSEDE PREVIOUSLY SUBMITTED BID.	
Ву	(This Document Must Be Signed)	_Date
Name_	(Please Print or Type Name)	



Matthew Moore, P.E.

Director of Capitol Planning & Development Community College System of New Hampshire 26 College Drive, Concord, N.H. 0330